



DLP-TH1

USB-Based Temperature & Humidity Sensor



The DLP-TH1 is a USB-based digital temperature and humidity sensor. Software provided with the DLP-TH1 sensor displays temperature, humidity, and dew-point data in both Fahrenheit and Celsius, plots graphically to the screen, and logs to a data file on the hard drive. The software will also send an email to user-specified recipients if the temperature or humidity exceeds specified setpoints.

The DLP-TH1 sensor uses a fully calibrated capacitive polymer-sensing element for relative humidity and a bandgap temperature sensor providing excellent long-term stability. Calibration coefficients for the sensors are permanently stored in digital memory within the DLP-TH1 module so that the module is fully interchangeable with any other DLP-TH1 module.

The DLP-TH1 is shipped with Windows 98/ME/2000/XP compatible software and USB drivers. Additionally, the most recent versions of the application software and USB drivers for the DLP-TH1 are available as a free download from www.dlpdesign.com/usb/th1.html.

No external power source is required--all power (30mA max @ 5V) is taken from the USB port via the provided 6-foot USB cable.

QUICK-START GUIDE

This guide requires the use of a Windows 98/ME/2000/XP PC that is equipped with at least one available USB 1.1- or 2.0-compatible port.

1. If the DLP-TH1 board is connected to your PC, disconnect it at this time.
2. Insert the supplied program disk into the PC's drive. Run the setup.exe program, and follow the prompts. (You can also download the install software from www.dlpdesign.com/usb/th1.html) Download the DLP-TH1 application software, then unzip and run the setup program.
3. Connect the DLP-TH1 to the PC via the provided USB cable. This action initiates the loading of the USB drivers. When prompted, select the

C:\Program Files\DLPDesign\DLP-TH1\USB Drivers

folder where the USB drivers are located (written in Step 2). Windows will then complete the installation of the device drivers for the DLP-TH1. The next time the DLP-TH1 module is attached, the host PC will immediately load the correct drivers without any prompting. Reboot the PC if prompted to do so.

At this point, the DLP-TH1 is ready for use. Run the application program and "Open" the sensor module to start acquiring temperature and humidity data.

SPECIFICATIONS


<u>Temperature</u>	°C	°F
Range	-40 to 123.8°C	-40 to 254.9°F
Accuracy	±2.0°C (-30 to 80°C)	±3.6°F (-22°F to 176°F)
Resolution	0.01°C	0.02°F
Repeatability	±0.1°C	±0.2°F
Response Time	5-30 Sec.	5-30 Sec.

Humidity

Range	0-100%RH
Accuracy	±3%RH (20 to 80%RH), ±5%RH (0 to 100%RH)
Resolution	0.03%RH
Repeatability	±0.1%RH
Response Time	4 Sec.

BASIC OPERATION


The DLP-TH1 application software is compatible with 98/ME/2000/XP versions of the Windows operating system.




Since multiple DLP-TH1 units can be connected to the PC at the same time, when the program is run, the first required step is to select the sensor that is to be monitored. When the Open button is clicked, a selection window will appear that presents a list of all sensors connected to the PC. To select a specific sensor, simply click on the description string for the desired sensor and then click on OK.

Each sensor can be given a specific name (Computer Room, Baby Room, etc.) using the Rename function. The sensor's name is written to the non-volatile memory in the sensor itself such that the name stays with the sensor should it be moved to a different PC. Click on Rename and enter a new name for the sensor. Note that the new name will not take effect until the sensor is disconnected and reconnected to the PC as the description strings for a USB device are only read at power-up.


To enable charting, simply click on the check box for Charting. Different time and temperature scales can be selected to suit user needs. Additionally, the chart can be resized with the mouse to show more detailed time or temperature resolution.



To enable logging, simply click on the check-box for Logging. A dialog window will appear allowing the selection of a file name for the log file as shown below. A filename is automatically created based on the sensor's name, date, and time. A different filename can be entered if desired.



To enable email notification of the temperature or humidity alarms, simply click on the check box for Charting in the main window. The following setup window will appear:



The image shows a software dialog box titled "Alarm email setup dialog". The title bar includes a close button (X). The main content area is titled "Temperature alarm setup screen for sensor: Computer Room". In the top right corner, there are "OK" and "Cancel" buttons. The dialog is configured for a temperature alarm. It features two radio buttons: "above" (checked) with a value of "86.0" °F, and "below" (unchecked) with a value of "32.0" °F. Below this, there are input fields for "TO:" (containing "youraddress@youraccount.com"), "CC:" (containing "youraddress2@youraccount.com, youraddress3@"), "FROM:" (containing "myaddress@myaccount.com"), and "SUBJECT:" (containing "my subject"). A "Send test email to all TO: and CC: addresses listed" button is positioned to the right of the TO and CC fields. A note below the CC field reads "NOTE: Multiple CC: recipients separated by commas." The "BODY:" section contains four lines of text: "Line 1: Sensor: Computer Room Temp: 80.2°F Hum: 35.5% Dew: 50.4*", "Line 2: line 1", "Line 3: line 2", and "Line 4: line 2". At the bottom, there are "Server:" and "Port:" labels with corresponding input fields (Server: "mail.advantexmail.net", Port: "25"). "Update" and "View Log" buttons are located to the right of the Port field.

Valid email addresses and server data must be used. The Send test email button will help to verify that the email addresses and server name entered are working as expected. The View Log button will allow you to review the responses from the email service provider as each email is sent.

Only one email will be sent if a temperature or humidity setpoint is exceeded. The ability to send an email will be reactivated if the temperature of humidity falls below the setpoint by more than 1 degree or 1% RH.

DISCLAIMER

Neither the whole nor any part of the information contained herein or the product described in this datasheet may be adapted or reproduced in any material or electronic form without the prior written consent of the copyright holder.

This product and its documentation are supplied on an as-is basis, and no warranty as to their suitability for any particular purpose is either made or implied. DLP Design, Inc. will not accept any claim for damages whatsoever arising as a result of use or failure of this product. Your statutory rights are not affected.

This product or any variant of it is not intended for use in any medical appliance, device, or system in which the failure of the product might reasonably be expected to result in personal injury.

This document provides preliminary information that may be subject to change without notice.

CONTACT INFORMATION

DLP Design, Inc.
205 Benton Drive #2201
Allen, TX 75013

Phone: 469-964-8027
Fax: 415-901-4859
Email: support@dlpdesign.com
Internet <http://www.dlpdesign.com>