No.	LD –19Z60A						
DATE	DEC . 19 . 2007						

TECHNICAL LITERATURE

FOR

TFT - LCD module

These parts have corresponded with the RoHS directive.

MODEL No. LQ084V3DG02

The technical literature is subject to change without notice. So, please contact SHARP or its representative before designing your product based on this literature.

Engineering department Mobile LCD Division MOBILE LIQUID CRYSTAL DISPLY GROUP SHARP CORPORATION

RECORDS OF REVISION

LQ084V3DG02

SPEC No.	DATE	REVISED		SUMMARY	NOTE
		No.	PAGE		
LD-19Z60A	DEC.19.2007	-	-	-	1st Issue

NOTICE

This publication is the proprietary of SHARP and is copyrighted, with all rights reserved. Under the copyright laws, no part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical for any purpose, in whole or in part, without the express written permission of SHARP. Express written permission is also required before any use of this publication may be made by a third party.

The application circuit examples in this publication are provided to explain the representative applications of SHARP's devices and are not intended to guarantee any circuit design or permit any industrial property right or other rights to be executed. SHARP takes no responsibility for any problems related to any industrial property right or a third party resulting from the use of SHARP's devices, except for those resulting directly from device manufacturing processes.

In the absence of confirmation by device specification sheets, SHARP takes no responsibility for any defects that occur in equipment using any of SHARP's devices, shown in catalogs, data books, etc. Contact SHARP in order to obtain the latest device specification sheets before using any SHARP's device.

SHARP reserves the right to make changes in the specifications, characteristics, data, materials, structures and other contents described herein at any time without notice in order to improve design or reliability. Contact SHARP in order to obtain the latest specification sheets before using any SHARP's device. Manufacturing locations are also subject to change without notice.

Observe the following points when using any device in this publication. SHARP takes no responsibility for damage caused by improper use of the devices.

The devices in this publication are designed for general electronic equipment use.

The appropriate design measures should be taken to ensure reliability and safety when SHARP's devices are used for equipment such as:

- Transportation control and safety equipment(i.e.,aircraft, trains, automobiles, etc.)
- Traffic signals Gas leakage sensor breakers Alarm equipment Various safety devices etc.

SHARP's devices shall not be used for equipment that requires extremely high level of reliability, such as:

- Military and space applications
 Nuclear power control equipment
- Medical equipment for life support

Contact a SHARP representative, in advance, when intending to use SHARP's devices for any "specific" applications other than those recommended by SHARP.

Contact and consult with a SHARP representative if there are any questions about the contents of this publication.

1 Applicable TFT-LCD module

This specification applies to the color TFT-LCD module, LQ084V3DG02.

2 Overview

This module is a color active matrix transmissive LCD module incorporating amorphous silicon TFT (Thin Film Transistor).

It is composed of a color TFT-LCD panel, driver ICs, control circuits and power supply circuitry and a backlight unit. Graphics and texts can be displayed on a 640 x RGB x 480 dots panel with 262,144 colors by feeding 18 bit data signal (6bit/each of R,G,B), 4(four) timing signals, +3.3V DC power supply for TFT-LCD and AC power supply for backlight.

(Note: Backlight-driving DC/DC converter and the wire harness are not built in this module.)

- · Fine images with stripe aligned 307,200 pixels on 8.4 inch diagonal screen
- · Adapting a wide viewing angle technology [best viewing angle: 6 o'clock direction]
- · High contrast, thanks to active matrix drive system
- · AG(Anti Glare) polarizing filter
- · Light and slim compact module (12 o'clock direction is also available by the function to flip the screen horizontally or vertically)
- · Natural coloring reproducibility by employing normally-white-mode, which has good nature in coloring
- · Image inversion both horizontally and vertically
- · This module is adapted to RoHS compliance.

3 Mechanical Specifications

items	specifications	unit
Display size (Diagonal)	21.4 (8.4")	cm
Active display area	170.88 (H) x 128.16 (V)	mm
Pixel format	640(H) x RGB x 480(V)	dot
	(1 pixel=R+G+B dots)	-
Pixel pitch	0.267 (H) x 0.267(V)	mm
Pixel configuration	R,G,B vertical stripe	-
LCD mode	Normally white/Twisted Nematic	-
Dimension *	199.5 (W) x 149.5 (H) x T.B.D.(D)	mm
Mass	T.B.D.	g

^{*}Fig.1 shows dimensions of the module.

4 Input Signal Assignment

4.1 TFT-LCD Panel driving section

CN1 Used connector: IMSA-9637S-33Y902 (IRISO ELECTRONICS CO.,LTD.)

1	Pin No.	Symbol	Function	Polarity
3 Hsync Horizontal Sync signal Negative 4 Vsync Vertical Sync signal Negative 5 GND RED Data signal Negative 6 R0 RED Data signal (LSB) RED Data signal 7 R1 RED Data signal RED Data signal 9 R3 RED Data signal RED Data signal 10 R4 RED Data signal RED Data signal 11 R5 RED Data signal RED Data signal 12 GND GND RED Data signal 13 G0 GREEN data signal RED Data Signal 14 G1 GREEN data signal GED Data Signal 15 G2 GREEN data signal GED Data Signal 16 G3 GREEN data signal GED Data Signal 19 GND GREEN data signal GED Data Signal 20 B0 BLUE data signal LED Data Signal 21 B1 BLUE data signal LED Data Signal 22 B2<	1	GND	-	
3 Hsync Horizontal Sync signal Negative 4 Vsync Vertical Sync signal Negative 5 GND RED Data signal Negative 6 R0 RED Data signal (LSB) RED Data signal 7 R1 RED Data signal RED Data signal 9 R3 RED Data signal RED Data signal 10 R4 RED Data signal RED Data signal 11 R5 RED Data signal RED Data signal 12 GND GND RED Data signal 13 G0 GREEN data signal RED Data Signal 14 G1 GREEN data signal GED Data Signal 15 G2 GREEN data signal GED Data Signal 16 G3 GREEN data signal GED Data Signal 19 GND GREEN data signal GED Data Signal 20 B0 BLUE data signal BLUE data signal 21 B1 BLUE data signal BLUE data signal 24 B	2	CK	Clock signal for sampling each datum	
4 Vsync Vertical Sync signal Negative 5 GND RED Data signal (LSB) 7 R1 RED Data signal RED Data signal 8 R2 RED Data signal RED Data signal 10 R4 RED Data signal RED Data signal 11 R5 RED Data signal RED Data signal 11 R5 RED Data signal RED Data signal 12 GND GND GND 13 G0 GREEN data signal GED GREEN data signal 14 G1 GREEN data signal GED GREEN data signal 15 G2 GREEN data signal GED GREEN data signal 16 G3 GREEN data signal GED GREEN data signal 19 GND GREEN data signal GED GREEN data signal 20 B0 BLUE data signal GED GREEN data signal 21 B1 BLUE data signal GED GREEN data signal 22 B2 BLUE data signal GED GREEN data signal	3	Hsync		Negative
6 R0 RED Data signal 7 R1 RED Data signal 8 R2 RED Data signal 9 R3 RED Data signal 10 R4 RED Data signal 11 R5 RED Data signal 11 R5 RED Data signal 11 R5 RED Data signal 12 GND Image: Red Data signal (MSB) 13 G0 GREEN data signal (LSB) 14 G1 GREEN data signal 15 G2 GREEN data signal 16 G3 GREEN data signal 18 G5 GREEN data signal 19 GND 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal di	4	-		
7 R1 RED Data signal 8 R2 RED Data signal 9 R3 RED Data signal 10 R4 RED Data signal 11 R5 RED Data signal (MSB) 12 GND 13 G0 GREEN data signal (LSB) 14 G1 GREEN data signal 15 G2 GREEN data signal 16 G3 GREEN data signal 17 G4 GREEN data signal 18 G5 GREEN data signal 20 B0 BLUE data signal (MSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) [Note 4-1] 28 Vcc Power supply in Power supply in	5	GND	, ,	
7 R1 RED Data signal 8 R2 RED Data signal 9 R3 RED Data signal 10 R4 RED Data signal 11 R5 RED Data signal (MSB) 12 GND 13 G0 GREEN data signal (LSB) 14 G1 GREEN data signal 15 G2 GREEN data signal 16 G3 GREEN data signal 17 G4 GREEN data signal 18 G5 GREEN data signal (MSB) 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal (MSB) 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) [Note 4-1] 28 Vcc Power supply in [Note 4-2]	6	R0	RED Data signal (LSB)	
9 R3 RED Data signal 10 R4 RED Data signal 11 R5 RED Data signal (MSB) 12 GND 13 G0 GREEN data signal (LSB) 14 G1 GREEN data signal 15 G2 GREEN data signal 16 G3 GREEN data signal 17 G4 GREEN data signal 18 G5 GREEN data signal 19 GND 20 B0 BLUE data signal (MSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal (MSB) 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) [Note 4-1] 28 Vcc Power supply in [Note 4-2] 30 R/L Horizontal scanning direction control signal (Upwards/downwards)	7	R1		
10	8	R2	RED Data signal	
11	9	R3	RED Data signal	
12 GND	10	R4	RED Data signal	
13 G0 GREEN data signal (LSB) 14 G1 GREEN data signal 15 G2 GREEN data signal 16 G3 GREEN data signal 17 G4 GREEN data signal 18 G5 GREEN data signal (MSB) 19 GND 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Note 4-2) (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Note 4-2) (Upwards/downwards)	11	R5	RED Data signal (MSB)	
14 G1 GREEN data signal 15 G2 GREEN data signal 16 G3 GREEN data signal 17 G4 GREEN data signal 18 G5 GREEN data signal (MSB) 19 GND 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Note 4-2] (Upwards/downwards) 32 NC	12	GND		
15 G2 GREEN data signal 16 G3 GREEN data signal 17 G4 GREEN data signal 18 G5 GREEN data signal (MSB) 19 GND 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal 26 GND 27 ENAB Data Enable signal (MSB) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Note 4-2) (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Note 4-2) (Upwards/downwards)	13	G0	GREEN data signal (LSB)	
16 G3 GREEN data signal 17 G4 GREEN data signal 18 G5 GREEN data signal (MSB) 19 GND 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal 26 GND 27 ENAB Data Enable signal (MSB) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Note 4-2) (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Note 4-2) (Upwards/downwards)	14	G1	GREEN data signal	
17 G4 GREEN data signal 18 G5 GREEN data signal (MSB) 19 GND 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal 26 GND 27 ENAB Data Enable signal (MSB) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Note 4-2) (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Note 4-2) (Upwards/downwards)	15	G2	GREEN data signal	
18 G5 GREEN data signal (MSB) 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Note 4-2] (Upwards/downwards)	16	G3	GREEN data signal	
19 GND 20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal 26 GND 27 ENAB Data Enable signal (MSB) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal [Note 4-2] (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal [Note 4-2] (Upwards/downwards)	17	G4	GREEN data signal	
20 B0 BLUE data signal (LSB) 21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (INote 4-2) (Upwards/downwards) 32 NC	18		GREEN data signal (MSB)	
21 B1 BLUE data signal 22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	19	GND		
22 B2 BLUE data signal 23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	20	В0		
23 B3 BLUE data signal 24 B4 BLUE data signal 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	21	B1	BLUE data signal	
24 B4 BLUE data signal 25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	22	B2	· ·	
25 B5 BLUE data signal (MSB) 26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	23	В3		
26 GND 27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	24	B4	BLUE data signal	
27 ENAB Data Enable signal (Control signal for image location in horizontal direction) 28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	25	B5	BLUE data signal (MSB)	
(Control signal for image location in horizontal direction) 28	26	GND		
28 Vcc Power supply in 29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	27	ENAB	Data Enable signal	[Note 4-1]
29 Vcc Power supply in 30 R/L Horizontal scanning direction control signal [Note 4-2] (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal [Note 4-2] (Upwards/downwards) 32 NC			(Control signal for image location in horizontal direction)	
30 R/L Horizontal scanning direction control signal (Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	28	Vcc	Power supply in	
(Rightwards/Leftwards) 31 U/D Vertical scanning direction control signal (Upwards/downwards) 32 NC	29	Vcc	Power supply in	
31 U/D Vertical scanning direction control signal [Note 4-2] (Upwards/downwards) 32 NC	30	R/L	Horizontal scanning direction control signal	[Note 4-2]
(Upwards/downwards) 32 NC			(Rightwards/Leftwards)	
32 NC	31	U/D	Vertical scanning direction control signal	[Note 4-2]
			(Upwards/downwards)	
33 GND	32	NC		
	33	GND		


The front shield case and back shield case is internally grounded to GND of the module.

[Note 4-1]

The horizontal display location is designated and controlled by rising timing of ENAB signal.

However if ENAB signal is fixed to "Low", display location is designated by the default setting in the module.

(Don't use the module by fixing ENAB to "High")See: Chapter 7-2



4.2 Backlight section

Used connector: SM04B-SRSS-TB(LF)(SN) (JST)

CN2 Corresponding connector: SHR-04V-S-B (JST)

Pin no.	Symbol		Function
1	+ ch2	Power supply for LED	(ch2 High voltage side)
2	+ ch1	Power supply for LED	(ch1 High voltage side)
3	- ch1	Power supply for LED	(ch1 Low voltage side)
4	- ch2	Power supply for LED	(ch2 Low voltage side)

5 Absolute Maximum Ratings

Parameter	Symbol	Condition	Ratings	Unit	Remark
Input voltage	VI	Ta=25°C	-0.3 ~ Vcc+0.3	V	[Note 5-1]
Supply voltage	Vcc	Ta=25°C	0 ~ +4.0	V	ı
Storage temperature	Tstg	-	- 30 ∼ +80	°C	
Operating temperature (Panel surface)	Торр	-	- 30 ∼ +80	°C	[Note 5-2,3,4]

[Note 5-1] CK, $R0 \sim R5$, $G0 \sim G5$, $B0 \sim B5$, Hsync, Vsync, ENAB, R/L and U/D

[Note 5-2] Humidity: Less than 95%RH at $Ta \le 40$ °C and

Maximum wet-bulb temperature must not exceed 39°C at Ta>40°C, with no condensation.

[Note 5-3] The operating temperature only guarantees operation of the circuit. For contrast, speed response, and other factors related to display quality, judgment is done using the ambient temperature Ta = + 25°C.

[Note 5-4] This rating applies to all parts of the module and should not be exceeded.

6 Electrical characteristics

6.1 TFT-LCD Panel driving section

Ta = 25

0.1 III Deb i unei univin	1 u 23					
Parameter	Symbol	Min	Тур	Max	Unit	Remarks
Supply voltage	Vcc	+3.0	+3.3	+3.6	V	[Note6-1]
Current dissipation	Icc	-	200	360	mA	[Note6-2]Vcc=3.3V
Allowed input ripple voltage	V_{RF}	-	-	100	mV p-p	
Input voltage ("Low" state)	$V_{\rm IL}$	-	-	0.8	V	[Note6-3]
Input voltage ("High" state)	V_{IH}	2.1	-	-	V	
	T	10.0		10.0		V _I =0V
Input leakage current (low)	I _{OL1}	-10.0	-	10.0	μΑ	[Note6-4]
	I _{OL2}	900	-			V _I =0V
		-800		-	μΑ	[Note6-5]
	I _{OL3}	-10.0		10.0		V _I =0V
		-10.0	-	10.0	μA	[Note6-6]
	I _{OH1}	-10.0	-	10.0	μΑ	V _I =Vcc
Input leakage current (High)	TOHI					[Note6-4]
	I _{OH2}	-10.0	-	10.0	μΑ	V _I =Vcc
						[Note6-5]
	I _{OH3}	-	-	800	μΑ	V _I =Vcc
						[Note6-6]

[Note6-1] Vcc turn-on/off conditions

 $0 < t1 \le 15 ms$

 $0 < t2 \le 10 \text{ms}$

 $0 < t3 \le 100 ms$

 $0 < t4 \le 1s$

t5 > 200 ms


Vcc-dip conditions

- 1) At $2.5V \le Vcc$ td $\le 10ms$
- 2) At Vcc < 2.5V

Vcc dip conditions should also follow the Vcc turn-on/off conditions


[Note6-2] Current dissipation (Typ.):

When Monochrome 16 level-gray-bar pattern is displayed (Figure below, Refer Page 10 for details of RGB)




Current dissipation(Max):

When VS(V63) and V0 stripe pattern are displayed alternately at intervals of two lines. (Figure below, Refer Page 10 for details of RGB)



[Note6-3] CK, R0~R5, G0~G5, B0~B5, Hsync, Vsync, ENAB, R/L and U/D [Note6-4] CK, R0~R5, G0~G5, B0~B5, Hsync, Vsync, and ENAB [Note6-5] R/L [Note6-6] U/D



6.2 Backlight driving Section

The backlight system is an edge-lighting type with white-LED.

The characteristics of LED are shown in the following table.

(It is usually required to measure under the following condition.

condition: $I_L = 100 \text{mA/Constant}$ current drive, $Ta = 25 \pm 2$

Parameter	Symbol	Min.	Тур.	Max.	Unit	Remark
LED voltage	$V_{ m L}$	ı	(21)	-	V	
LED current range	I_{L}	ı	100	T.B.D.	mA	Value for one channel
Number of circuit channel		ı	2	-		[Note 1]
Lamp power consumption	W_{L}	ı	(4.2)	-	W	[Note 2]
Life time (LCD module)	L_{L}	ı	(50,000).	-	Hour	[Note 3]

[Note 1] The LED backlight is composed of 2 channels which 7 LED is connected in series.

[Note 2] Calculated value for reference ($I_L \times V_L \;\; \star \, 2 \; \text{channel})$

[Note 3] Lighting condition:

- The state of the LCD module installation: Landscape position and standing position
- · Atmosphere temperature: 25
- ·Lighting current: 100mA (Constant current drive / Continuous turning on)

Definition of Life time:

Brightness becomes 50% of the original value .(under condition)

7 Timing Characteristics of Input Signals

Timing diagrams of input signal are shown in Fig.2.

7.1 Timing Characteristics

	Parameter	Symbol	Min.	Тур.	Max.	Unit	Remark
Clock	Frequency	1/Tc	-	25.18	28.33	MHz	
	"High" time	Tch	5	-	-	ns	
	"Low" time	Tcl	10	-	-	ns	
Data	Setup time	Tds	5	-	-	ns	
	Hold time	Tdh	10	-	-	ns	
Hsync	Period	TH	30.00	31.78		μs	
			750	800	900	clock	
	Pulse width	THp	2	96	200	clock	
Vsync	Period	TV	515	525	560	line	
	Frequency	1/Tv	50	60	-	Hz	[Note7-1]
	Pulse width	TVp	1	-	34	line	
Horizont	al display period	THd	640	640	640	clock	
Phase dif	fference between	THc	10	-	Tc-10	ns	
Hsync ar	nd clock						
Phase dit	fference between	TVh	0	-	ТН-ТНр	clock	
Hsync and Vsync							
	display period	TVs	34	34	34	line	

Note7-1) In case of lower frequency, the deterioration of display quality, flicker etc., may occur.

Please use this module in more than 50Hz.(1/Tv)

7.2 Display Position in horizontal direction

Display position in horizontal direction is designated by rising timing of ENAB signal.


Par	Symbol	MIN	TYP	MAX	Unit	Note	
ENAB signal	Setup time	Tes	5	-	Tc -10	ns	
	Pulse width	Тер	2	640	TH-10	clock	
Phase difference ENA	THe	44	-	TH-664	clock		

When ENAB is fixed to "Low", the horizontal display will starts from the clock C104 (clock) as shown in Fig.2. When the phase difference is not greater than 104 clock, hold ENAB terminal in "High" state for more than (104-THe), otherwise display will start from C104 (clock).

7.3 Display position in vertical direction Display start position in vertical direction is fixed to the 34th line.

7.4 Input signal and display on the screen

Display position of input data






Fig 2. Input signal waveform

8 Input Signals, Basic Display Colors and Gray Scale of Each Color

1	8 Input Signals,	Dasic I	Dispi	ay C	11013	anu v	Jiay	Scare												
	Colors &									Data	sign	al								
	Gray scale	Gray Scale	R0	R1	R2	R3	R4	R5	G0	G1	G2	G3	G4	G5	В0	B1	B2	В3	B4	В5
	Black	-	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Blue	-	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1
	Green	-	0	0	0	0	0	0	1	1	1	1	1	1	0	0	0	0	0	0
olo	Cyan	-	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1
CC	Red	-	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0
Basic Color	Magenta	-	1	1	1	1	1	1	0	0	0	0	0	0	1	1	1	1	1	1
В	Yellow	-	1	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0
	White	ı	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
	Black	GS0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
eq	Û	GS1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
fR	Darker	GS2	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
le o	仓	\rightarrow		↓						\										
ca	Û	\			\	<u>ا</u>					`	ν					1	_		
Gray Scale of Red	Brighter	GS61	1	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0
Grã	Û	GS62	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0
	Red	GS63	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0
en	Black	GS0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ire	Û	GS1	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0
) Jo	Darker	GS2	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0
ale (仓	\rightarrow			,							V					1			
Sce	Û	\			\	<u>ا</u>					`	ν					1			
Gray Scale of Green	Brighter	GS61	0	0	0	0	0	0	1	0	1	1	1	1	0	0	0	0	0	0
G	Û	GS62	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	0
	Green	GS63	0	0	0	0	0	0	1	1	1	1	1	1	0	0	0	0	0	0
ne	Black	GS0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
[B]	仓	GS1	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0
e of	Darker	GS2	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0
cal	仓	+				V						l l					1			
Gray Scale of Blue	Û	+				<u>ا</u>						l					1			
Gra	Brighter	GS61	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	1	1	1
	Û	GS62	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1
	Blue	GS63	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1

^{0:} Low level voltage, 1: High level voltage

Each basic color can be displayed in 64 gray scales from 6 bit data signals. According to the combination of total 18 bit data signals, the 262,144-color display can be achieved on the screen.

9 Optical Specification

Ta=25°C, Vcc=+3.3V

Parame	ter	Symbol	Condition	Min.	Тур.	Max.	Unit	Remark
Viewing angle	Horizontal	21, 22	CR≥10	50	65	-	° (Deg.)	[Note9-1,4]
Range	Vertical	11		40	55	-	° (Deg.)	
		12		45	60	-	° (Deg.)	
Contrast ratio		CR max	Best viewing	400	600	-	-	[Note9-2]
			angle					
Response time	Rise	Tr	= 0°	-	5	15	ms	[Note9-3]
	Fall	Td		-	21	40	ms	
Chromaticity	of white	X		T.B.D.	(0.313)	T.B.D.	-	[Note9-4]
		у	IL=100mA	T.B.D.	(0.329)	T.B.D.	-	
Lumina	nce	Y		(320)	(400)	-	cd/m²	

The optical specifications are measured 30 minute after turning LED on and in a dark room or equivalent condition, according to the method shown in below. (Condition: $I_L = 100 \text{mA}$)





Fig3 Optical characteristics measurement method

[Note9-1] Definitions of viewing angle range:



The best viewing angle of this module is slightly leaned to 6 o'clock from normal line. In the field where θ_{12} exceeds this angle, gray-scale is reversed partially.


The gray-scale in the field of 12 o'clock direction is brighter than that of 6 o'clock direction and isn't reversed.

[Note9-2] Definition of contrast ratio:

The contrast ratio is defined as the following.

[Note9-3] Definition of response time:

The response time is defined as the following figure and shall be measured by switching the input signal between "black" and "white" alternatively.



[Note9-4] This parameter should be measured at the center of the screen and 30 minutes after turn-on.

The characteristics are measured when the driver circuit is not powered.

10 Display Qualities

Please refer to the Outgoing Inspection Standard.

11 Handling Instruction

- 11.1 Assembling the module
 - 1) Be sure to design the cabinet so that the module can be installed without any extra stress such as warp or twist.
 - 2) Please power off the module before you connect or disconnect input connector.
 - 3) Make sure to connect module's metal shield case to GND of DCDC converter circuit.

If its connection is not made perfectly, some of the following problems may occur.

- a) Increase of noise caused by backlight
- b) Unstable output from DCDC converter circuit
- c) Possibly over-heat in some section

11.2 Instruction for assembling

- 1) Since the front polarizer is easily damaged, pay attention to avoid rubbing with something hard or sharp.
- 2) How to eliminate dust on polarizer.
 - Blow dust away by N₂ blower having measures of electrostatics
 - Since the front polarizer is easily damaged, wiping dust off is not adequate. If the polarizer is soiled, it is suggested to peel dust off by using adhesive surface of adhesive tape.
- 3) When the metal section [shield case or shield back case] is soiled, wipe it off with dry and soft cloth. If not so easy, breathe upon it then wipe off. If the water droplet or fat is left for long term, it may cause stain or tarnish, it should be wipe off immediately.
- 4) Since TFT-LCD panel is made of glass substrate, dropping the panel or banging it against hard objects may cause cracking or fragmentation.
- 5) Since CMOS LSIs are incorporated in this module, please pay special care to electrostatic while handling it, and earth human body.

11.3 Caution in product design

- 1)The notes and cautions below should be followed when product is designed with this module.
- 2) The module should be protected with cover to prevent salt content and/or water droplet.

Take enough shielding countermeasure not to interfere to peripheral electronic device.

- 3) If a minute particle enters in the module and adheres to an optical material, it may cause display
 - non-uniformity issue, etc. Therefore, fine-pitch filters have to be installed to cooling and inhalation hole if you intend to install a fan.
 - 4) The LED used for this product is very sensitive to the temperature. Luminance decreases rapidlywhen it is used for a long time under the environment of the high temperature. Please consult our company when it is used under the environment like the above mentioned.

11.4 Others

The LCD has the nature that its performance is degradation by ultra-violet light. Don't leave the LCD module in direct sunlight or strong ultra violet ray.

If stored at the temperatures lower than the rated storage temperature, the LC may freeze and it may cause LCD panel damage. If storage temperature exceeds the specified rating, the molecular orientation of the LC may change to that of a liquid, and they may not revert to their original state. Store the module in normal room temperature.

The liquid crystal may leak out when the LCD is broken. If the liquid crystal drip into the eyes or mouth washes it out immediately.

The caution to other ordinal electronic component should be followed also.

Avoid the LCD to use and leave in the atmosphere with condensation and/or the high concentration of corrosive gases described below; Sulfurous gasses (ex; SO2(sulfur dioxide), CS2(carbon disulfide), H2S(hydrogen sulfide)), Cl2(chlorine), HCl(hydrogen chloride), NH3(ammonia) and so on.

12 Packing Form

- 12.1 Fig.4 shows packaging form.
- 12.2 Carton stock conditions
- a) Maximum number of Carton being stuck: (6)
- b) Maximum number of product contained: (10 Unit)
- c) Carton size: (408mm (W) x 203mm (H) x 244mm (D))
- d) Total mass (for 10Unit): Approximately 6kg
- e) Carton stock environment:

1) Temperature: $0 \sim 40^{\circ}\text{C}$ 2) Humidity: Up to 60%RH

3) Ambiance: No gases bite into electronic components and wiring materials

4) Period: Approximately 3month

5) Unpacking: To prevent LCD module from damaging by ESD,

unpack the module with effective measure after controlling

humidity 50%RH or more.

Marking of product name

T.B.D.		

14 Miscellaneous

- a) Variable resister has been set optimally before shipment, so do not change any adjusted value. If adjusted value is changed, the specification may be not satisfied.
- b) Don't disassemble this module, it may cause malfunction.
- c) Image retention may occur when the fixed image is display for long time.
- d) Liquid crystal panel drive input FFC/FPC specification
 - The following FFC/FPC is recommended for input connector.

 [IMSA-9637S-33Y902 (IRISO Electronics co.,ltd.), 33pin 0.5mm pitch)]
 - The terminal of FFC/FPC of input connector recommend to be gold or gold plated.

 Because point of contact of the connection is gold plated.
- e) When any question or issue occurs, it shall be solved by mutual discussion.

15 Reliability Test Items

No.	Test parameter	Conditions		
1	High temperature storage test	Leaves the module at Ta=80°C for 240h		
2	Low temperature storage test	Leaves the module at Ta=-30°C for 240h		
3	High temperature	Operates the module at Ta=40°C;90~95%RH for 240h		
	& high humidity operation test	(No condensation)		
4	High temperature operation test	Operates the module with +80°C at panel surface for 240h		
5	Low temperature operation test	Operates the module at Ta=-30°C for 240h		
6	Strength against ESD	$\pm 200 \text{V} \cdot 200 \text{pF} [0\Omega]$ one time for each terminal		
7	Shock test	Max. acceleration: 686m/s ² (70G) Pulse width: 6ms, half sine wave		
	(non- operating)	Direction: $\pm X, \pm Y, \pm Z$ once for each direction.		
8	Vibration test	Frequency: 10 ~ 57Hz/Vibration width (one side):0.15mm		
	(non- operating)	: 58 ~ 500Hz/ acceleration:19.6m/s ² Sweep time : 11 minutes		
		Test period : 3 hours (1 hour for each direction of X,Y,Z)		
9	Thermal shock test	-30 °C[0.5h] $\sim +80$ °C[0.5h] /50 cycle		

[Result Evaluation Criteria]

Under the display quality test conditions with normal operation state, these shall be no change which may affect practical display function.

[Note] The directions of X, Y, Z are defined as below:

