

# Disconnect test terminals


## SAKR SAKR/35



## SAKR-D SAKR-D/35



## DKT 4 DKT 4/35



## DKT 4 V DKT 4 V/35



### Dimensions/approvals

Width/length/height (mm)	with TS 32	
Width/length/height (mm)	with TS 35 x 7.5	
Insulation stripping length/clamping screw/screwdriver blade	8 mm/M 3/3.5 x 0.6	

### Rated data

Rated voltage/current/cross-section	400 V <sup>1)</sup> /10 A/4 mm <sup>2</sup>
Rated impulse voltage/pollution severity	6 kV/3

### Further technical data

Tightening torque range	Nm	0.5...1.0/0.5 StB
Torque setting with electric screwdriver type DMS 2		2/1

### Clampable conductor

Solid H07V-U	mm <sup>2</sup>	0.5...4
Stranded H07V-R	mm <sup>2</sup>	1.5...4
Flexible H07V-K	mm <sup>2</sup>	0.5...4
Flexible H07V-K and ferrule according to DIN 46 228/1	mm <sup>2</sup>	
With/without plastic insulating collar	mm <sup>2</sup>	0.5...4
Plug gauge according to 60 947-7-1	Size	A 3
Continuous current rating of cross-connection 2...5-pole	A	(QB 2...25) 10
Continuous current rating of cross-connection 6...10-pole	A	

### Rated data according to UL/CSA

Voltage/current/conductor size	UL	300 V/10 A/26...12 AWG
Voltage/current/conductor size	CSA	300 V/10 A/26...12 AWG

### Ordering data

Type	Qty.	Qty.
KrG	<b>0412120000</b>	100
PA	<b>0412160000</b>	100
Without diode PA	<b>0172160000</b>	100
With diode PA		
Blue PA	<b>0412180000</b>	100
Orange PA	<b>1461960000</b>	100
KrG	<b>0412220000</b>	100
PA	<b>0412260000</b>	100
without diode PA	<b>0183360000</b>	100
Blue	<b>0412280000</b>	100

### End plate (thickness mm)

Type	Cat. No.	Qty.
KrG	AP (1.5)	<b>0211320000</b> 20
PA	AP (1.5)	<b>0211360000</b> 20
Blue PA	AP (1.5)	<b>0211380000</b> 20

### Partition (thickness mm)

Type	Cat. No.	Qty.
TW HP (1.0)	<b>0297100000</b>	20

### Cross-connection

QB 4	2-pole	QB 2 <sup>4)</sup>	<b>0482700000</b>	100
	3-pole	QB 3 <sup>4)</sup>	<b>0482800000</b>	50
	4-pole	QB 4 <sup>4)</sup>	<b>0482900000</b>	50
	25-pole	QB 25 blank <sup>4)</sup>	<b>0134000000</b>	20

### Contact sleeve (spare)

Type	Cat. No.	Qty.
PS 2.3	<b>0180400000</b>	20

### Test plug

Type	Cat. No.	Qty.
PS 2.3	<b>0180400000</b>	20

### Diode plug (spare)

without diode	DLS 2	<b>0321060000</b>	50
with diode 1N4007	DLS 2 +	<b>0630160000</b>	50
with diode 1N4007	DLS 2 -	<b>0547760000</b>	50
with jumper	DLS 2	<b>0547660000</b>	25

### Marking tags

Print	DEK	Standard
	DEK 6.5	see "Accessories"

Mounting rails, end brackets, further marking material see "Accessories"

Type	Cat. No.	Qty.
UL		

Type	Cat. No.	Qty.

Type	Cat. No.	Qty.
UL		

Type	Cat. No.	Qty.










Type	Cat. No.	Qty.
PA	<b>0412960000</b> <sup>1)</sup>	100
	<b>0299960000</b> <sup>1)</sup>	50
	<b>0413060000</b> <sup>2)</sup>	50
	<b>0185760000</b> <sup>2)</sup>	50
	<b>0263660000</b> <sup>2)</sup>	50
	<b>0299560000</b> <sup>2)</sup>	50

Type	Cat. No.	Qty.
PA	<b>0687360000</b>	50
	<b>0687460000</b>	50

Type	Cat. No.	Qty.
PA	<b>1304860000</b>	50
	<b>1304960000</b>	50

<sup>1)</sup> without DLS  
<sup>2)</sup> with DLS empty  
<sup>3)</sup> with DLS 1N4007  
<sup>4)</sup> When using QB the rated cross-current reduces to max. 2.5 mm<sup>2</sup>

<sup>5)</sup> With DKT 4 only on upper terminal level  
<sup>6)</sup> As disconnect test terminal rated voltage 250 V