



FOR JO2 TO .214 WIRE INSULATION DIA.
 TONGUE MATERIAL THK = .039 ± .002

ZONE	LTR	DESCRIPTION	DATE	APPROVED
B	REDRAWN & REV	P-6077	7-20-69	RY
C	REVISED	PC-5579	10-8-70	DM
D	REVISED	PC-5578	12-6-71	RY
E	REVISED	PC-5578	7-2-73	L.D.
F	INACTIVATED	P-9257	2-1-82	DM
G	REV 6-065 & 6-2436	DAPO	4-87	DM
H	REV 3-47-5	REV G2582	8-2-87	DM
J	REV 10-20-0197-97	NE	8-20-97	5/8
K	REV 10-20-0197-97	NE	8-20-97	5/8
L	REV 10-20-0197-97	NE	8-20-97	5/8

TABLE I

BODY: COPPER (ASTM B152)
 NICKEL PLATE (QQ-N-290)
 .0003 AVG. EXT. THK.
 SLEEVE: COPPER (ASTM B152)
 NICKEL PL (QQ-N-290).00003
 AVG. EXT. THK.
 INSULATION: TEFLON (ASTM D3295)
 COLOR: BLACK

QTY	DESCRIPTION	PART NO.	MATERIAL & FINISH
1	WIRE TERMINAL	SEE TABLE II	AMP WIRE TERMINAL PIDG - STRATO-THERM - RING TONGUE WIRE SIZE: 12.10 AMP INCORPORATED HARRISBURG, PENNSYLVANIA

TABLE II

50845-2	.197	*10	50845-3
50845-1	.171	*8	50845-4
50845	.145	*6	50845-3
PART NO.	'A'	'B'	PART NO. ON TAPE

SEE TABLE I

CUSTOMER DRAWING