
Bussmann®

GLD/GBA

Pin-Indicating Type Non-Time-Delay ¼″ × 1¼″ (6.3mm × 32mm)



Catalog Symbol: GLD/GBA Non-Time-Delay; Indicating Ampere Rating: ½ to 15 Amperes Agency Approvals:

U.L. Listed, Std. 248-14 ½-5A/125 Vac, 10,000 AIC Guide JDYX, File E19180 U.L. Recognized, 6A/125Vac, 1000 AIC 10-15A/50V ac/dc, 300 AIC Guide JDYX2, File E19180 CSA Certified, ½-5A/125 Vac, 10,000 AIC Class 1422-01, File 53787


Electrical Ratings (Catalog Symbol and Amperes)

GLD-1/2	GLD-2	GLD-6
GLD-¾	GLD-3	GLD-10
GLD-1	GLD-4	GLD-12
GLD-1-1/2	GLD-5	GLD-15

Carton Quantity and Weight

Ampere	Carton	Weight		
Ratings	Qty.	Lbs.	Kg.	
½-15	100	0.86	0.390	

C€ CE logo denotes compliance with European Union Low Voltage Directive (50-1000 Vac, 75-1500 Vdc). Refer to BIF document #8002 or contact Bussmann Application Engineering at 314-527-1270 for more information.



General Information:

- Use in power electronic circuits in which a fuse opening must be quickly apparent.
- Opening of fuse results in the ejection of end pin.
- Type GLD has an albaloy-plated pin for positive, electrical signal circuit activation.
- Type GBA has a red pin for high visibility.
- The Buss Series 8000 fuseblocks are recommended for visual indication.
- For visual indication use Buss panel-mounted fuseholder HLD (15A maximum); for lamp indicating, HKA (15A maximum).
- Body material: Fibre tube.
- · Ferrule plating: Nickel plated endcaps.
- Ferrule material: Brass

The only controlled copy of this BIF document is the electronic read-only version located on the Bussmann Network Drive. All other copies of this document are by definition uncontrolled. This bulletin is intended to clearly present comprehensive product data and provide technical information that will help the end user with design applications. Bussmann reserves the right, without notice, to change design or construction of any products and to discontinue or limit distribution of any products. Bussmann also reserves the right to change or update, without notice, any technical information contained in this bulletin. Once a product has been selected, it should be tested by the user in all possible applications.



Form No. GLD Page 1 of 1 BIF Doc #2012