Indicator (Cylindrical 16-dia.)

# Cylindrical 16-dia. Indicator

■ Same basic design as the A16 Pushbutton Switch.

*LR*: *LR* 



## **List of Models**

	Appearance	Model
	Rectangular	M16-J
Solder terminals	Square	M16-A
	Round	M16-T
Voltage -reduction lighting		M16-□
Screw-less Clamp		M16-□

# **Model Number Structure**

Model Number Legend ..... The model numbers used to order sets of Units are illustrated below. One set comprises the Display, Case,

Lamp, and Socket.

For information on combinations, refer to Ordering Information on the following pages.



С

Red Green Yellow

Pure yellow

White

Pure white

Blue

### (1) Degree of Protection (2) Shape of Display (3) Color of Display

Symbol	Protection	Symbol	Shape	Symbol
No	IP40	J	Rectangular	R
symbol		A	Square	G
5	IP65 oil-resistant	Т	Round	Y
		-		PY

Display	(4) Light Source		
olor	Symbol	Туре	

Symbol	Туре	Operating voltage	Rated voltage
5	Incandescent lamp	5 VAC/VDC	6 VAC/VDC
12		12 VAC/VDC	14 VAC/VDC
24		24 VAC/VDC	28 VAC/VDC
5D	LED	5 ±5% VDC	5 VDC
12D		12 ±5% VAC/VDC	12 VAC/VDC
24D		24 ±5% VAC/VDC	24 VAC/VDC

### Voltage Reduction Unit (24-V Built-in LED)

Symbol	Туре	Operating voltage	Rated voltage
T1	LED	100/110 VAC/VDC	110 VAC/VDC
T2		200/220 VAC/VDC	220 VAC/VDC

Solder terminals are available only with 100-V models.

Screw-less clamp connectors are used for 200-V models.



W

PW

А



# **Ordering Information**

### Ordering as a Set .....

...... The model numbers used to order sets of Units are given in the following tables. One set comprises the Display, Case, Lamp, and Socket.

# M16 -J (Rectangular) Models Solder Terminal Models

Appearance	Degree of protection Lighting		IP40	IP65 oil-resistant	Display color symbol *
Square (M16-A)		5 VDC	M16-J□-5D	M165-J□-5D	R: red Y: yellow G: green A: blue W: white PY: pure yellow PW : pure white R: red Y: yellow
	LED without Voltage Reduction Unit	12 VAC/VDC	M16-J□-12D	M165-J□-12D	
		24 VAC/VDC	M16-J□-24D	M165-J□-24D	
		5 VAC/VDC	M16-J□-5	M165-J□-5	
	Incandescent lamp	12 VAC/VDC	M16-J□-12	M165-J□-12	G: green A: blue
		24 VAC/VDC	M16-J□-24	M165-J□-24	W: white PY: pure yellow

\* Enter the desired color symbol into the box in the model number.

### M16<sup>-</sup>-A (Square) Models Solder Terminal Models

Degree of protection IP40 IP65 oil-resistant Display color symbol \* Appearance Lighting R: red 5 VDC M16-A -5D M165-A -5D Y: yellow Square (M16-J) G: green A: blue LED without Voltage M16-A□-12D 12 VAC/VDC M165-A□-12D **Reduction Unit** W: white PY: pure yellow 24 VAC/VDC M16-A□-24D M165-A -24D PW : pure white R: red 5 VAC/VDC M16-A□-5 M165-A□-5 Y: yellow G: green Incandescent lamp 12 VAC/VDC M16-A□-12 M165-A□-12 A: blue W: white 24 VAC/VDC M16-A□-24 M165-A -24 PY: pure yellow

\* Enter the desired color symbol into the box in the model number.

### M16 -T (Round) Models

### **Solder Terminal Models**

Appearance	Lighting	Degree of protection	IP40	IP65 oil-resistant	Display color symbol *
Round (M16-T)		5 VDC	M16-T□-5D	M165-T□-5D	R: red Y: yellow
	LED without Voltage Reduction Unit	12 VAC/VDC	M16-T□-12D	M165-T□-12D	A: blue W: white PY: pure yellow PW : pure white R: red Y: yellow
		24 VAC/VDC	M16-T□-24D	M165-T□-24D	
	Incandescent lamp	5 VAC/VDC	M16-T⊡-5	M165-T□-5	
		12 VAC/VDC	M16-T⊡-12	M165-T□-12	G: green A: blue
		24 VAC/VDC	M16-T□-24	M165-T□-24	W: white PY: pure yellow

Note: Neon lamps are not available with models that are ordered as a set. They must be ordered individually if required. \* Enter the desired color symbol into the box in the model number.

# Specifications

## **Approved Standards**

UL, cUL

# Ratings

Ambient operating temperature	$-10^{\circ}$ C to 55°C (with no icing or condensation)
Ambient operating humidity	35% to 85%RH
Ambient storage temperature	-25°C to 65°C (with no icing or condensation)

### Super-bright LED

Rated voltage	Rated current	Operating voltage	Built-in limiting resistance
5 VDC		5 VDC ±5%	Red, yellow, white : 300 $\Omega$ Green, blue, pure white : 160 $\Omega$
12 VAC/VDC	8 mA	12 VAC/VDC ±5%	Red, yellow, white : 1 k $\Omega$ Green, blue, pure white : 910 $\Omega$
24 VACVDC		24 VAC/VDC ±5%	2.4 kΩ

### Incandescent Lamp

Rated voltage	Rated current	Operating voltage
6 VAC/VDC	60 mA	5 VAC/VDC
14 VAC/VDC	40 mA	12 VAC/VDC
28 VAC/VDC	24 mA	24 VAC/VDC

# Characteristics

# Screw-less Clamp

Item	Туре	e Screw-less Clamp			
Recommended wire size		0.5 mm <sup>2</sup> twisted wire or 0.8 mm-dia. solid wire			
Usable wires	Twisted wire	0.3 mm <sup>2</sup>	0.5 mm <sup>2</sup>	0.75 mm <sup>2</sup>	1.25 mm <sup>2</sup>
and tensile	Solid wire	0.5 mm dia.	0.8 mm dia.	1.0 mm dia.	
strength	Tensile strength	10 N	20 N	30 N	40 N
Length of exp	osed wire	10 ±1 mm			
Compliant sta	ndards	JIS C 2811 Terminal Blocks for Industrial Use		trial Use	

# M16

Dimensions (Refer to the A16 for details of panel cutout dimensions.)



# Dimensions





### **Dimensions**

### **Terminal Arrangement**



### Accessories, Replacements, and Tools

The accessories, replacements, and tools are also used with the A16 Pushbutton Switch. Refer to the A16 datasheet.

# **Safety Precautions**

### Mounting

• When mounting the Case onto the Socket Unit, ensure that the orientation is correct. Perform mounting with the dimple on the Case and the TOP mark on the Socket Unit facing in the same direction.



# Application

### Screw-less Clamps

### **Mounting Procedure**

- 1. Strip a length of 10 mm off the end of the wire (allowable range:  $10\pm1$  mm).
- 2. Bunch wire strands together and straighten them.
- Insert the wire into the insertion hole while pressing the release button at the side of the hole. (Using a precision screwdriver is recommended.)
- 4. Let go of the release button to lock the wire into place.
- 5. After locking, pull on the wire gently to confirm that it is securely locked.

### Wiring

- When using stranded wire, gather the ends of the strands together before wiring.
- When wiring, insert the wire until it comes into contact with something. After wiring is completed, pull on the wires to confirm that they are connected securely.
- After wiring, ensure that continuous pressure is not applied to the terminals.
- Refer to internal connections diagrams and confirm the terminal numbers before performing wiring.

### **Removing Procedure**

1. Remove wires by pulling them while pressing the release button.

Note: When reusing wires that have already been locked, cut off the end of the wire and strip the wire again before using.