### Lightweight and Cost-effective Solenoid Type: Plastic Housing

- · Basic unit and solenoid unit in one housing
- Plastic Housing: Light weight
- Ease of Wiring: All the terminal screws are M3.5.
- · Available with a red or green indicator
- Selectable from 4 circuit configurations
- When mounting the actuator on a movable door, and the switch on a machine body, the door is mechanically locked when closed.
- Higher Safety: The door is unlocked by a solenoid lockrelease signal from a PLC or another source after the machine has stopped.
- In the event of power failure or for machine maintenance, the door can be unlocked using a special tool.
- Flexible Installation: The actuator can be accessed from two directions.
- Available with G1/2 or PG13.5 Conduit Connection
- · Also available is a manual unlock key type.









Direct Opening Action



GS-ET-19 BG standard in Germany








Double insulation

### **Features and Functions**



### **TYPES**

Type No.	Indicator	Key	Conduit Port
HS1E- ☐ 40R	Without	Without	G1/2
HS1E- ☐ 40RP	Without	Without	PG13.5
HS1E- ☐ 44R-*	With	Without	G1/2
HS1E- ☐ 44RP-*	With	Without	PG13.5
HS1E- ☐ 40KR	Without	With	G1/2
HS1E- ☐ 40KRP	Without	With	PG13.5
HS1E- ☐ 44KR-*	With	With	G1/2
HS1E- ☐ 44KRP-*	With	With	PG13.5

Note: • Special key wrench (HS9Z-T1) for removing the cover and manual unlocking is included with the switch (the screwdriver is available separately.)
• Specity the circuit diagram No. in place of [].
• Red(R) and green(G) indicators are available.
• Specify the indicator color (R or G) in place of \*.
• Order the actuator separately (not included with the switch).


#### ACTUATORS

#### •KEY WRENCH/SCREWDRIVER FOR TORX\* SCREWS


Type No.	Description
HS9Z-A1	Straight Type Actuator (Mainly for sliding doors)
HS9Z-A2	L-shaped Type Actuator (Mainly for hinged doors)
HS9Z-A3	Angle Adjustable Type (Mainly for hinged doors)
HS9Z-T1	Special Key Wrench
HS9Z-T2	Special Screwdriver

<sup>\*</sup> TORX is a registered trade mark of Camcar Textron.

#### ORDERING INFORMATION



	COLUMN CHILL TO (ETV DO)				
Circuit Diagi					
	Main Circuit	Auxiliary Circuit			
Blank:	1NC-1NC	1NO-1NO			
1:	1NC-1NC	1NO			
2:	1NC-1NC	1NC-1NC			
3:	1NC-1NC	1NC			



Note: Refer to pages 9 and 10 for HS1E circuit configurations.

### **SPECIFICATIONS**

Cor	oforming to S	tandards	EN1088, IEC60947-5-1, EN60947-5-1,						
Conforming to Standards			GS-ET-19						
Operating Temperature		-20 to +40°C (No freezing)							
Storage Temperature		-40 to +8							
	erating Humid	dity			timum (No condens	ation)			
	lude		2,000m r						
		Voltage (Ui)			en LED or solenoid				
Imp	ulse Withsta	nd Voltage (Uimp)			n LED or solenoid a				
Insi	ulation Resis	tance	Between live and dead metal parts: $100~\text{M}\Omega$ minimum Between live metal part and ground: $100~\text{M}\Omega$ minimum Between live metal parts: $100~\text{M}\Omega$ minimum Between terminals of the same pole: $100~\text{M}\Omega$ minimum						
Ele	ctric Shock F	Protection Class	Class II (	IEC6	60536)				
Pol	lution Degree		3 (IEC60	947	-5-1)				
	gree of Prote		IP67 (IE0	2605	529)				
Vib	ration	Operating Extremes	10 to 55	Hz,	amplitude 0.35 mm				
Res	sistance	Damage Limits	50 m/s² (						
Sho	ock Resistan	ce	1,000 m/s	s² (a	pprox. 100G)		·	•	
		trength when Locked	1,500N n						
Op	erating Speed	<b>d</b> ukggar sestruk-eksus tyler	1 m/s ma	ıximı	um				
	itive Opening		11 mm r	ninim	านกา				
Pos	itive Opening	Force	20N mini	mun	n				
The	ermal Curren	t (Ith)	Main circ	uit:	10A, Auxiliary circuit	: 3A	***************************************	***************************************	
	*. **				ing voltage (Ue)	30V	125V	250V	
	Rated Operating Current (le)			AC	Resistive load (AC12)	10A	10A	6A	
			Main	AC	Inductive load (AC15)	10A	5A	ЗА	
Rat			Circuit	DC	Resistive load (DC12) Inductive load (DC13)	6A 3A	- 0.9A	_ _	
				AC	Resistive load (AC12)	-	ЗА	ЗА	
			Auxiliary	Inductive load (AC15)		<u> </u>	ЗА		
				DC	Resistive load (DC12)	3A		-	
		17 7 404 644	Inductive load (DC13)   -   0.9A   -						
	ntact Opening		Main circuit: 1.7 mm min., Auxiliary circuit: 1.2 mm min.						
	erating Frequ		900 operations/hour						
	chanical Life		1,000,00			•			
	ctrical Life				rations (rated load)				
		rt-circuit Current	100A (IE		<u>_</u>				
Circ	cuit Protectio			\ tuse	(Type D01 based on	IEC6020	59-1, 60	269-2)	
		ating Voltage	24V DC						
I⊯ŀ	Rated Curre		235 mA						
5	Coil Resista		102Ω (at 20°C)						
흥	B Energizing Voltage			Rated voltage × 85% maximum (at 20°C)					
Solenoid Unit	De-energizing Voltage Continuous Applicable Voltage			Rated voltage × 10% minimum (at 20°C)					
ကြ			Rated voltage × 110%						
	Continuous Applicable Duration			Not specifically limited					
Insulation Class			Class B						
╎╒╎	Rated Operating Voltage			24V DC					
ä	Rated Current			10 mA					
ndicator	Light Source	3	LED lamp						
	Lens Color		Red or Green (12 mm dia. Lens)						
	ight		Approx. 500g						

## **Circuit Diagrams and Application Examples**

• Circuit Diagram No.: Blank (Main Circuit: 1NC-1NC, Auxiliary Circuit: 1NO-1NO)

	Status 1	Status 2	Status 3	Status 4	When unlocked manually
Switch/ Door Status	Door closed     Machine ready to operate     Solenoid de-energized	Door closed     Machine cannot be started     Solenoid energized	Door opened     Machine cannot be started     Solenoid energized	Door opened     Machine cannot be started     Solenoid de-energized	Door closed     Machine cannot be started     Solenoid de-energized
Door					
Circuit Diagram	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is finked to solenoid mechanically  7 %  8 %
Main Circuit	3-4: Closed	3-4: Open	3-4: Open	3-4: Open	3-4: Open
Auxiliary Circuit	1-2: Open	1-2: Closed	1-2: Closed	1-2: Closed	1-2: Closed
Solenoid	5-6: Power OFF	5-6: Power ON	5-6: Power ON	5-6: Power OFF	5-6: Power OFF

#### • Circuit Diagram No.: 1 (Main Circuit: 1NC-1NC, Auxiliary Circuit: 1NO)

Switch/	Status 1	Status 2	Status 3	Status 4	When unlocked manually
Door Status	Door closed     Machine ready to operate     Solenoid de-energized	Door closed     Machine cannot be started     Solenoid energized	•Door opened •Machine cannot be started •Solenoid energized	Door opened     Machine cannot be started     Solenoid de-energized	•Door closed •Machine cannot be started •Solenoid de-energized
Door					( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( )
Circuit Diagram	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically  7 +   8 +   8 +   8 +   8 +   1
Main Circuit	3-4: Closed	3-4: Open	3-4: Open	3-4: Open	3-4: Open
Auxiliary Circuit	1-2: Open	1-2: Open	1-2: Closed	1-2: Closed	1-2: Open
Solenoid	5-6: Power OFF	5-6: Power ON	5-6: Power ON	5-6: Power OFF	5-6: Power OFF

Main Circuit: used to enable the machine to start only when the main circuit is closed. Auxiliary Circuit: used to indicate whether the main circuit or door is open or closed.

Terminals 7 and 8 are used for the LED indicator, and are isolated from solenoid or door status. Wire the terminals only when needed.

## Circuit Diagrams and Application Examples

• Circuit Diagram No.: 2 (Main Circuit: 1NC-1NC, Auxiliary Circuit: 1NC-1NC)

	Status 1	Status 2	Status 3	Status 4	When unlocked manually
Switch/ Door Status	•Door closed •Machine ready to operate •Solenoid de-energized	*Door closed *Machine cannot be started *Solenoid energized	*Door opened *Machine cannot be started *Solenoid energized	Door opened     Machine cannot be started     Solenoid de-energized	Door closed     Machine cannot be started     Solenoid de-energized
Door					
Circuit Diagram	Contact Block 2 linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Aveignan V unaugo Jamod Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically
Main Circuit	3-4: Closed	3-4: Open	3-4: Open	3-4: Open	3-4: Open
Auxiliary Circuil	1-2: Closed	1-2: Open	1-2: Open	1-2: Open	1-2: Open
Solenoid	5-6: Power OFF	5-6: Power ON	5-6: Power ON	5-6: Power OFF	5-6: Power OFF

#### • Circuit Diagram No.: 3 (Main Circuit: 1NC-1NC, Auxiliary Circuit: 1NC)


[	Status 1	Status 2	Status 3	Status 4	When unlocked manually
Switch/ Door Status	Door closed     Machine ready to operate     Solenoid de-energized	Door closed     Machine cannot be started     Solenoid energized	Door opened     Machine cannot be started     Solenoid energized	Door opened     Machine cannot be started     Solenoid de-energized	Door closed     Machine cannot be started     Solenoid de-energized
Door					
Circuit Diagram	Contact Block 2 is linked to solenoid mechanically	Are limous and the limous and the limous and the limous and the limit an	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically	Contact Block 2 is linked to solenoid mechanically
Main Circuit	3-4: Closed	3-4: Open	3-4: Open	3-4: Open	3-4: Open
Auxiliary Circuit	1-2: Glosed	1-2: Closed	1-2: Open	1-2: Open	1-2: Closed
Solenoid	5-6: Power OFF	5-6: Power ON	5-6: Power ON	5-6: Power OFF	5-6: Power OFF

Main Circuit: used to enable the machine to start only when the main circuit is closed. Auxiliary Circuit: used to indicate whether the main circuit or door is open or closed.


Terminals 7 and 8 are used for the LED indicator, and are isolated from solenoid or door status. Wire the terminals only when needed.

### **DIMENSIONS**

• HS1E with indicator - using the straight actuator (HS9Z-A1)




• HS1E with indicator - using the L-shaped actuator (HS9Z-A2)



### **ACTUATORS**

 Straight Type (mainly for sliding doors)
 HS9Z-A1



\* After installing the actuator, remove the actuator cover.

 Angle Adjustable Actuator (mainly for hinged doors)

See page 19 for photos and dimensions.

