# Timers Multifunction Types DMB51, DMB71







- Selectable time range 0.1 s to 100 h
- 7 knob selectable functions:

Op - delay on operate

In - interval

lo - interval on trigger open

Id - double interval Dr - delay on release

R - symmetrical recycler ON first Rb - symmetrical recycler OFF first

Automatic or manual start

- Repeatability: ≤ 0.2%
- Output: 5 A SPDT or 5 A DPDT relays
- For mounting on DIN-rail in accordance with DIN/EN 50 022
- 17.5 mm (DMB51C) or 35.5 mm (DMB71D) DIN-rail housing (DIN 43880)
- Combined AC and DC power supply
- . LED indication for relay status and power supply ON

# **Product Description**

Multi-voltage timer with 7 knob-selectable functions and 7 knob-selectable time ranges within 0.1s and 100h. For mounting on DIN-rail. Housing 17.5 mm wide for SPDT version and 35.5 mm

for DPDT version, suitable both for back and front panel mounting.

Wide power supply range: 24 VDC and 24 to 240 VAC or 12 to 240 VAC/DC.

# Ordering Key Housing Function Type Item number Output Power supply

# **Type Selection**

Mounting	Output	Housing	Supply: 12 to 240 VAC/DC	Supply: 24 VDC and 24 to 240 VAC
DIN-rail	SPDT	Mini-D	DMB 51 C W24	DMB 51 C M24
DIN-rail	DPDT	Mini-D	DMB 71 D W24	DMB 71 D M24

# **Time Specifications**

Time specifications	
Time ranges Knob selectable	0.1 to 1 s 1 to 10 s 6 to 60 s 60 to 600 s 0.1 to 1 h 1 to 10 h 10 to 100 h
Setting accuracy	≤ 5%
Repeatability	≤ 0.2%
Time variation Within rated power supply Within ambient temperature	≤ 0.05%/V ≤ 0.2%/°C
Reset Manual reset of time and/or relay Pulse duration Power supply interruption	Close the trigger contact between pins A1 and Y1 ≥ 100 ms ≥ 200 ms
Automatic start	Connect pins A1 and Y1

# **Output Specifications**

Output	SPDT or DPDT relay
Rated insulation voltage	250 VAC (rms)
Contact Ratings (AgSnO <sub>2</sub> ) DMB51 (SPDT):	μ
Resistive loads AC 1 DC 12	5 A @ 250 VAC 5 A @ 24 VDC
Small inductive loads AC 15 DC 13	
DMB71 (DPDT)	
Resistive loads AC 1 Small inductive loads AC 15 DC 13	
Mechanical life	≥ 30 x 10 <sup>6</sup> operations
Electrical life	$\geq$ 10 <sup>5</sup> operations (at 5 A, 250 V, cos $\phi$ = 1)
Operating frequency	< 7200 operations/h
Dielectric strength Dielectric voltage Rated impulse withstand	2 kVAC (rms)
voltage	2.5 kV (1.2/50 μs)



# Supply Specifications

Power supply Rated operations through term	tional volt	Overvoltage cat. II (IEC 60664, IEC 60038)	
(DMB51C)		M24:	24 VDC ± 15% and 24 to 240 VAC + 10% -15%, 45 to 65 Hz
		W24:	12 to 240 VDC + 10% -15% and 12 to 240 VAC
(DMB71D)	A1, A2	M24:	+ 10% -15%, 45 to 65 Hz 24 VDC ± 15% 24 to 240 VAC + 10% -15%, 45 to 65 Hz
		W24	12 to 240 VDC + 10% -15% and 12 to 240 VAC +10% -15%,
			45 to 65 Hz
Voltage inter	uption	≤ 10 ms	
Rated operat	ional pov		
(DMB51C)		upply:	4 VA
(DMB71D)	DC supply: AC supply DC supply		1.5 W 5.5 VA 2 W

Centre knob:

chosen range.

Lower knob:

Setting of time range

Time setting on relative scale:

1 to 10 with respect to the

# Time Setting

# Upper knob:

Setting of function:

Op - delay on operate

In - interval

lo - interval on trigger open

Id - double interval Dr - delay on release

R - symmetrical recycler (ON first)

Rb - symmetrical recycler

Mode of Operation

(OFF first)

# **General Specifications**

Power ON delay		≤ 100 ms	
Indication for Power supply ON Output relays ON		LED, green LED, yellow (flashing when timing)	
Environment Degree of protect Pollution degree Operating temper Storage temperat	ature	(EN 60529) IP 20 2 (IEC 60664) -20° to +60°C, R.H. < 95% -30° to +80°C, R.H. < 95%	
Housing Dimensions Material	DMB51C DMB71D	17.5 x 81 x 67.2 mm 35.5 x 81 x 67.2 mm PA66	
Weight		75 g	
Screw terminals Tightening torque		Max. 0.5 Nm according to IEC EN 60947	
Approvals		UL, CSA RINA (DMB 51 only)	
CE Marking		Yes	
EMC Immunity Emissions		Electromagnetic Compatibillity According to EN 61000-6-2 According to EN 61000-6-3	

# **Function Op** Delay on operate

The time period begins as soon as the trigger contact is closed

At the end of the set delay time the relay operates and does not release until the trigger contact is closed again or the power supply is disconnected. If the trigger contact is closed before the end of the delay time, the device resets and a new time period starts.

## **Function In** Interval

The relay operates and the time period begins as soon as the trigger contact is closed. The relay releases at

the end of this period or when the power supply is disconnected. The relay operates again when the trigger contact is closed again. If the trigger contact is closed before the end of the delay time, the device resets and a new time period starts.

# **Function Io** Interval on trigger open

The relay operates and the time period begins as soon as the trigger contact is opened. At the end of the set delay or when the power supply is disconnected the relay releases. The relay operates again when the trigger contact is opened again. If the trigger contact is opened before the end of the delay time the relay keeps ON and a new time period begins.

# **Function Id Double interval**

The relay operates and the time period begins as soon as the trigger contact is closed. The relay releases at the end of this period or when the power supply is When the disconnected. trigger contact is opened the relay operates again for the set delay period. If the trigger contact is opened before the end of the first time period the second one begins; if the trigger contact is closed before the end of


the second time period the device resets and the first time period begins again.


# **Function Dr** Delay on release


The relay operates as soon as the trigger contact is closed. The time period begins when the trigger contact is opened. The relay releases at the end of the set delay time or when the power supply is disconnected. The relay operates again when the input contact is closed again. If it is opened before the end of the delay time the relay keeps ON, a new time period begins as soon as the contact is closed again.




# **Operating Diagrams (cont.)**







# **Wiring Diagram**



# **Dimensions**

