Pressure Gauge Guide

Pressure Gauge for General Purpose

	Outside	Model	Tyme	Indication	Pressure range	Connection		Material		Indication ⁽¹⁾	Attachment ⁽²⁾	
	diameter	Woder	Туре	precision ±% FS	MPa	thread	Case	Clear cover	Stud	unit	Attachment	
10 m 1 m 1 m 1 m 1 m 1 m 1 m 1 m 1 m 1 m	ø15	G15	Back side thread	5	0 to 1.0	R ½ M5 (Female thread)	Zinc die-casted	Poly- carbonate	Zinc die-casted	MPa	_	Page
	ø26	G27	Back side thread	5	0 to 1.0	R ½6	coated	carbonate	coated	MPa		14-11-3
With limit indicator	ø37.5	G36	Back side thread	3	0 to 0.2 0 to 0.4 0 to 0.7		Aluminum die-casted Black disulfide molybdenum coated	Poly-	Aluminum die-casted Black disulfide molybdenum coated	MPa		Page
ura ac		GA36	Vertical side thread	3	0 to 1.0 0 to 1.5	R 1/8	Rolled steel Black melamine painted	carbonate	Brass	IVII a		14-11-4
With limit indicator	ø42.5	G46	Back side thread	3	0 to 0.2 0 to 0.4	R ½ R ½	Aluminum die-casted Black disulfide molybdenum coated	Poly-	Aluminum die-casted Black disulfide molybdenum coated	MPa	Cover ring assembly	Page
		GA46	Vertical side thread	3	0 to 0.7 0 to 1.0 0 to 1.5	R ½ R ¼	Rolled steel Black melamine painted	carbonate	Brass	IVII a		14-11-6
	ø30	G33	Back side thread Vertical side	3	0 to 0.2 0 to 0.3 0 to 0.4	R ½						Page
	ø43	GA33 G43	thread Back side	3	0 to 0.4 0 to 0.6 0 to 0.7		Stainless steel Glass	Brass	MPa	_	14-11-8	
	943	U43	thread		0 to 1.0	R 1/4						

Oil-free/External Parts Copper-free Pressure Gauge

Note 1) Please consult with SMC for other scale indication units and connecting thread "NPT".

Note 2) Possible for use in panel mounting.

Note 3) Please contact SMC for the pressure range 0 to 0.6 MPa of GA33.

	Outside	Model	Туре	Indication	Pressure range	Connection		Material		Indication ⁽¹⁾	A 44 - a b 4(2)	
With limit indicator	diameter	Wiodei	Туре	precision ±% FS	MPa	thread	Case	Clear cover	Stud	unit	Attachment ⁽²⁾	
	ø42.5	G46E	Back side thread	3	0 to 0.2 0 to 0.4 0 to 0.7 0 to 1.0 0 to 1.5	R ½ R ½	Rolled steel (Black melamine painted)	Poly- carbonate (Hard coated)	Brass Electroless nickel plated	MPa	Cover ring assembly	Page 14-11-10

Pressure Gauge for Clean Series (10-Series)



Note 1) Please consult with SMC for other scale indication units and connecting thread "NPT".

Note 2) Possible for use in panel mounting.

	Outside	Model	Tyrna	Indication	Pressure range	Connection		Material		Indication ⁽¹⁾	Allerdonesia	
	diameter	Wiodei	Туре	precision ±% FS	MPa	thread	Case	Clear cover	Stud	unit	Attachment	
(a) (b) (a) (b) (c) (c) (c) (c) (c) (c) (c) (c) (c) (c	ø44	G49	Back side thread	3	0 to 0.4 0 to 0.7 0 to 1.0	R 1/4	Zinc die-casted [Chrome plated]	Glass	Brass	MPa	_	Page 14-11-11

Pressure Gauge for Clean Regulator



Note 1) Please consult with SMC for other scale indication units and connecting thread "NPT".

	Outside	Model	Tyme	indication		Connection		Material		Indication ⁽¹⁾	A.H I	
With limit indicator	diameter	Woder	Туре	precision ±% FS	MPa	thread	Case	Clear cover	Stud	unit	Attachment	
10 mg 2 mg	ø42.5	G46-□ - SRA, B	Back side thread	3	0 to 0.2 0 to 0.4 0 to 0.7 0 to 1.0 0 to 1.5	R ½ R ½	Stainless steel Black melamine painted	Poly- carbonate Hard coated	Stainless steel		Cover ring assembly	Page 14-11-12

Pressure Gauge with Switch



Note 1) Please consult with SMC for other scale indication units and connecting thread "NPT". Note 2) Possible for use in panel mounting

With limit indicator Rolled steel R ½ R ¼ Back side Cover ring MPa ø42.5 GP46 3 0 to 1.0 Black melamine **Brass** 14-11-13 thread assembly painted



Note 1) Please consult with SMC for other scale indication units and connecting thread "NPT".

Note 2) Possible for use in panel mounting.

Page

Pressure Gauge for General Purpose

G15, G27

O.D.: ^{Ø15} Ø26

F.R.L.

AV

ΑU

AF

AR

IR

VEX

AMR

ITV

IC

VBA

VE \Box

VY1

PPA

AL

G



• Be sure to read the precautions on page 14-11-15 for selection and installation.

Standard Specifications

Model Type Back side thread Port size (1) R 1/8: M5 (Female thread) R 1/8: M5 (Female thread) R 1/8: M5 (Female thread) Air Indication precision L5% F.S. (Full span) Case (Surface treatment) Clear cover Polycarbonate Stud (Surface treatment) Zinc die-casted (Black graphite coated) Bourdon tube Brass		р		I			
Port size (1) R 1/6: M5 (Female thread) R 1/6 Fluid (2) Indication precision Case (Surface treatment) Clear cover Stud (Surface treatment) Stud (Surface treatment) R 1/6 Air Air Zinc die-casted (Black graphite coated) Polycarbonate Stud (Surface treatment) Zinc die-casted (Black graphite coated)		Model	G15	G27			
Fluid (2) Indication precision Air Indication precision Case (Surface treatment) Clear cover Stud (Surface treatment) Zinc die-casted (Black graphite coated) Polycarbonate Zinc die-casted (Black graphite coated)	Type		Back side thread				
Indication precision	Port size	(1)	R 1/8: M5 (Female thread)	R ½6			
Material Case (Surface treatment) Clear cover Stud (Surface treatment) Zinc die-casted (Black graphite coated) Polycarbonate Zinc die-casted (Black graphite coated)	Fluid (2)		A	ir			
Material Clear cover Polycarbonate Stud (Surface treatment) Zinc die-casted (Black graphite coated)	Indication	n precision	±5% F.S. (Full span)				
Material Stud (Surface treatment) Zinc die-casted (Black graphite coated)		Case (Surface treatment)	Zinc die-casted (Black graphite coated)				
Stud (Surface treatment) Zinc die-casted (Black graphite coated)	Material	Clear cover	Polycarbonate				
Bourdon tube Brass	Material	Stud (Surface treatment)	Zinc die-casted (Black graphite coated)				
	Bourdon tube		Brass				
Weight (kg) 0.01 0.015	Weight (k	(g)	0.01	0.015			
Applicable model ARM1000/2000 AC1000, AR1000, AW1	Applicabl	e model	ARM1000/2000 AC1000, AR1000, AV				


• Caution on handling: When drain or oil, etc. gets into the gauge, it may result in a malfunction.

Note 1) Indicates the condition at the lower pressure limit.

Use a pipe tape for sealing. Recommended tightening torque is between 3 and 4 N·m for R 1/16 and 7 and 9 N·m for R 1/8.

Note 2) Water cannot be used as an operating fluid. Because the clearance gap of the air passage of the Bourdon tube is very small. Water will block the gap and cause a malfunction. Similarly, when using other fluids, please consult with SMC for fluid compatibility information concerning possible corrosion and response delay, etc.

Dimensions



Model (Standard)

Model	Pressure range ^{Note)}	Indication	Connection thread		
Model	(MPa)	unit	Connection timeau		
G15-10-01	0 to 1.0	MPa	R 1/8, M5 (Female thread)		
G27-10-R1	0 to 1.0	MPa	R ½6		


Note) Do not apply more excessive pressure than max. pressure display. It will be a cause of malfunction.


Model (Made to Order) Other versions of this unit can be made on a made-to-order basis. Please consult with SMC for details, as delivery times may be extended.

Madal	Pressure range ^{Note)}	Indication	Connection thread	
Model	(MPa)	unit	Connection thread	
G27-10-M5-X201	0 to 1.0	MPa	M5 (Female thread)	

Note) Do not apply more excessive pressure than max. pressure display. It will be a cause of malfunction.

G27





Pressure Gauge for General Purpose/With limit indicator

G36, GA36

O.D.: ø37



G36-10-01

Standard Specifications

Mode	I	G36	GA36			
Type		Back side thread	Vertical side thread			
Port size (1)		R $\frac{1}{8}$ (Option M: With M5 female thread)				
Fluid (2)		A	ir			
Indication pr	ecision	±3% F.S.	(Full span)			
	Case (Surface treatment)	Aluminum die-casted (Black disulfide molybdenum coat treated)	Rolled steel (Black melamine painted)			
Clear cover		Polycarbonate (Par	Polycarbonate (Part no.: G36-00-00-3)			
Material	Stud (Surface treatment)	Aluminum die-casted (Black disulfide molybdenum coat treated)	Brass			
	Bourdon tube	Brass				
Weight (kg)		0.04	0.05			
Applicable m	nodel	AC2000/2500/3000 AR2000/2500/3000 AW2000/3000	_			

Note 1) When installing a pressure gauge, be careful not to fasten too tight. Excessive tightening will result in damage. Use a pipe tape for sealing. Recommended tightening torque is R 1/8: Set between 7 and 9 N·m.

Note 2) Not applicable to water as fluid because its stub is made from aluminum die-casted. Water may cause corrosion and block the air passage. Use a pressure gauge with wetted parts made from stainless steel, G46-□-X3. (Note: Take care when using G36-□-01M, whose wetted part is made from brass. Some corrosion may result.) Design system to not be affected by water hammer when using water as fluid. Similarly, when using other fluids, please consult with SMC, to prevent corrosion-related problems.

Model (Standard)

Model	Pressure range Note) MPa	Indication unit	Connection thread	Note
G36-2-01	0 to 0.2			
G36-4-01	0 to 0.4	MPa	R ½	_
G36-7-01	0 to 0.7			
G36-10-01	0 to 1.0			
GA36-10-01	0 to 1.0			


Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.

Model (Made to Order) Other versions of this unit can be made on a made-to-order basis. Please consult with SMC for details, as delivery times may be extended.

	,	,			
Madal	Pressure range Note)	Indication	Connection	Note	
Model	MPa	unit	thread	Note	
G36-10-01-X2	0 to 1.0	.45	R 1/8	Plated stem (Ni)	
G36-15-01	0 to 1.5	MPa	R /8	_	

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.






when piping onto a panel.


[•] Be sure to read the precautions on page 14-11-15 for selection and installation.

Dimensions

G36



GA36



F.R.L.

AV

AF

AR

IR

VEX

AMR

ITV

IC

VBA

VE

VY1

PPA

G

AL

Pressure Gauge for General Purpose/With limit indicator

G46, GA46

O.D.: ø42





G46-10-02M-C

Be sure to read the precautions on page 14-11-15 for selection and installation.

Standard Specifications

Mode	el		G46	GA46				
Туре			Back side thread	Vertical side thread				
Port size ⁽¹⁾			R 1/8, R 1/4 (Option M:	R 1/8, R 1/4 (Option M: with M5 female thread)				
Fluid (2)			A	ir				
Indication precision			±3% F.S. (Full span)				
	Case (Surface treatment)		Aluminum die-casted (Black disulfide molybdenum coated)	Rolled steel (Black melamine painted)				
	Clear cover		Polycarbonate (Par	t no.: G46-00-00-3)				
Material	Stud (Surface treatment)		Aluminum die-casted (Black disulfide molybdenum coated)	Brass				
	Bourdon tube		Brass					
Weight (kg)			0.05	0.075				
Applicable model			AC4000/5000/5500/6000 AR4000/5000/6000 — AW4000					
Attachment:		С	Part no.: 1305104-1A					
With cover ring ass	embly	C ₁	Part no.: 1305104-3A	_				

Model (Standard)

Model	Pressure range ^{Note)} MPa	Indication unit	Connection thread	Note
G46-2-01/ 02	0 to 0.2			
G46-4-01/ 02	0 to 0.4		-1/1/	
G46-7-01/ 02	0 to 0.7		R 1/8, 1/4	
G46-10-01/ 02	0 to 1.0	MDa		
G46-2-01 to 02M	0 to 0.2	MPa		_
G46-4-01 to 02M	0 to 0.4		R 1/8, 1/4	
G46-7-01 to 02M	0 to 0.7		M5 (Female thread)	
G46-10-01 to 02M	0 to 1.0		,	
GA46-10-01 to 02	0 to 1.0		R 1/8, 1/4	

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.

Model (Made to Order) Other versions of this unit can be made on a made-to-order basis. Please consult with SMC for details, as delivery times may be extended.

Model	Pressure	range ^{Note)}	Indication	Connection	Nista	
Model	MPa	psi	unit	thread	Note	
G46-2-01 to 02-C/ C1	0 to 0.2	_				
G46-4-01 to 02-C/ C1	0 to 0.4	_		R ½, ¼		
G46-7-01 to 02-C/ C1	0 to 0.7			11/0, /4		
G46-10-01 to 02-C/ C1	0 to 1.0	_	MPa		With cover	
G46-2-01 to 02M-C/ C1	0 to 0.2	_			ring assembly	
G46-4-01 to 02M-C/ C1	0 to 0.4	_		R ½, ¼		
G46-7-01 to 02M-C/ C1	0 to 0.7	_		M5 (Female thread)		
G46-10-01 to 02M-C/ C1	0 to 1.0	_				
G46-4-02-X30	0 to 0.4	0 to 60	MPo poi	R 1⁄4	_	
G46-10-02-X30	0 to 1.0	0 to 150	MPa, psi			
G46-2-02M-X4	0 to 0.2	_				
G46-4-02M-X4	0 to 0.4	_			Oil-free	
G46-7-02M-X4	0 to 0.7	_		- 17	Oil-free	
G46-10-02M-X4	0 to 1.0	_		R 1/4		
G46-2-02M-C/ C1-X4	0 to 0.2	_	MPa	M5 (Female thread)	Oil for a	
G46-4-02M-C/ C1-X4	0 to 0.4	_	IVII a		Oil-free, With cover	
G46-7-02M-C/ C1-X4	0 to 0.7	_			ring assembly	
G46-10-02M-C/ C1-X4	0 to 1.0	_			3	
G46-10-02-X2	0 to 1.0	_		D 1/	Plated stem (Ni)	
G46-15-01 to 02	0 to 1.5	_		R 1/4	_	


Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.





Note 1) Indicates the condition at the lower pressure limit. Use a pipe tape for sealing. Recommended tightening torque: R 1/8: Set between 7 and 9 N·m, R 1/4: 12 and 14 N·m respectively.

Note 2) Not applicable to water as fluid because its stub is made from aluminum die-casting. Water may cause corrosion and block the air passage. Use G46-III-X3 pressure gauge with wetted parts SUS (wetted parts of G46-III-01M are made of brass and this become lightly corroded. Take precautions when using.) Design system to not be affected by water hammer when using water as fluid. Similarly, when using other fluids, please consult SMC for fluid compatibility information concerning corrosive potential SMC for fluid compatibility information concerning corrosive potential.


How to Order







G46: With cover ring assembly (For panel mount)





F.R.L.

ΑV

AU

AF

AR

IR

VEX

AMR

ITV

IC

VBA

VE \Box

VY1

G

PPA

ΑL

Pressure Gauge for General Purpose

G33, GA33

O.D.: ø30






Standard Specifications

Mode	əl	G33	GA33	
Type		Back side thread	Vertical side thread	
Port size (1)		R	1/8	
Fluid (2)		Air		
Indication pr	recision	±3% F.S. (Full span)		
	Case	Stainless steel		
Material	Clear cover	Glass		
Material	Stud	Brass		
	Bourdon tube	Brass		
Applicable n	nodel	IP5000, IP6000, IR1000	, IT1000, ARM2500/3000	


- Note 1) When mounting a pressure gauge, use caution not to tighten excessively. Excessive tightening will cause product to be damaged. Use a pipe tape for sealing. Recommended tightening torque: R 1/8: Set between 7 and 9 N·m.
- Note 2) When using other fluids, please consult with SMC for fluid compatibility information concerning corrosive potential.

Dimensions

G33



G33-□□-01



Model (Standard)


Model	Pressure range ^{Note)} MPa	Indication unit	Connection thread	Note
G33-2-01	0 to 0.2			
G33-3-01	0 to 0.3			
G33-4-01	0 to 0.4			
G33-6-01	0 to 0.6			
G33-10-01	0 to 1.0	MPa	R 1/8	_
GA33-2-01	0 to 0.2			
GA33-4-01	0 to 0.4			
GA33-7-01	0 to 0.7			
GA33-10-01	0 to 1.0			

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.

Model (Made to Order)

Model	Pressure range ^{Note)} MPa	Indication unit	Connection	Note
G33-2-01-X2	0 to 0.2	9.7.1.2		
G33-3-01-X2	0 to 0.3			X2: Stud parts
G33-4-01-X2	0 to 0.4			electroless
G33-6-01-X2	0 to 0.6			nickel plated
G33-10-01-X2	0 to 1.0	MPa	R 1/8	
GA33-2-01-X2	0 to 0.2			
GA33-4-01-X2	0 to 0.4			X2: Stud parts
GA33-7-01-X2	0 to 0.7			nickel plated
GA33-10-01-X2	0 to 1.0			
G33-10-01-X4	0 to 1.0			X4: Oil-free (Wetted parts degreasing)

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.





Pressure Gauge for General Purpose

G43

O.D.: ø43

F.R.L.

AV

AU

AF

AR

IR

VEX

AMR

ITV

IC

VBA

VE \Box

VY1


PPA

AL



G43-10-01

External Dimensions (Except made-to-order products)



The dimensions in (): Connecting thread R $\frac{1}{4}$

Standard Specifications

G43	
Back side thread	
R 1/8, R 1/4	
Air	
±3% F.S. (Full span)	
Stainless steel	
Glass	
Brass	
Brass	
IP200/600, IT600, IR2000/3000, IT2000/4000	

Note 1) When mounting a pressure gauge, use caution not to tighten excessively. Excessive tightening will cause product to be damaged. Use a pipe tape for sealing. Recommended tightening torque: R 1/8: Set between 7 and 9 N·m, R 1/4: 12 and 14 N·m respectively.

Note 2) When using with water, use G43-□-X3 (wetted parts stainless steel) and use caution not to apply water hammer. When using the other fluids, please consult with SMC for fluid compatibility information concerning corrosive potential.

Model (Standard)


Model	Pressure range ^{Note)} MPa	Indication unit	Connection thread	Note
G43-2-01 to 02	0 to 0.2		R 1/8, R 1/4	
G43-4-01 to 02	0 to 0.4	N /8, N /4		
G43-6-01	0 to 0.6	MPa	R 1/8	<u> </u>
G43-7-01 to 02	0 to 0.7		D 1/ D 1/	
G43-10-01 to 02	0 to 1.0		R 1/8, R 1/4	

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.

Model (Made to Order)

Model	Pressure range ^{Note)} MPa	Indication unit	Connection thread	Note
G43-2-01 to 02-X2	0 to 0.2		R 1/8, R 1/4	
G43-4-01 to 02-X2	0 to 0.4		H 78, H 74	X2: Stud parts
G43-6-01-X2	0 to 0.6		R 1/8	nickle plated
G43-7-01 to 02-X2	0 to 0.7		R 1/8, R 1/4	mono piatoa
G43-10-01 to 02-X2	0 to 1.0		n /8, n /4	
G43-2-01 to 02-X3	0 to 0.2		R ½, R ¼	
G43-4-01 to 02-X3	0 to 0.4		H 78, H 74	X3: Wetted parts
G43-6-01-X3	0 to 0.6	MPa	R 1/8	stainless steel
G43-7-01 to 02-X3	0 to 0.7		D 1/ D 1/	
G43-10-01 to 02-X3	0 to 1.0		R 1/8, R 1/4	
G43-2-01 to 02-X4	0 to 0.2		R 1/8, R 1/4	
G43-4-01 to 02-X4	0 to 0.4		H /8, H /4	X4: Oil-free
G43-6-01-X4	0 to 0.6] [R 1/8	(Wetted parts
G43-7-01 to 02-X4	0 to 0.7		R 1/8, R 1/4	degreasing)
G43-10-01 to 02-X4	0 to 1.0		11 / 8, 11 / 4	

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.





Oil-free/External Parts Copper-free Pressure Gauge/With Limit Indicator

G46E

O.D.: ø42





G46E-10-02M


G46E-10-02M-C

· Be sure to read the precautions on page 14-11-15 for selection and installation.


Dimensions

Dimensions in: B 1/4 connecting thread


G46E





G46E (Type DT): With cover ring assembly (For panel mounting)



Type C







Standard Specifications

Model			G46E	
Туре			Back side thread	
Port size (1)			R ¹ / ₈ , R ¹ / ₄ (Option M: with M5 female thread)	
Fluid (2)			Air	
Indication precision			±3% F.S. (Full span)	
Fluid contact part cl	eaning		Wetted parts degrease washing	
Ca (Sur treatr			Rolled steel (Black melamine painted)	
	Clear cover (Surface treatment)		Polycarbonate (Hard coated) Part no.: G46-00-00-2	
	Stud (Surface treatment)		Brass (Electroless nickel plated)	
	Bourdo	n tube	Brass (3)	
Weight (kg)			0.08	
Attachment:		С	Part no.: 1305104-1A	
With cover ring assembly		C ₁	Part no.: 1305104-3A	

Note 1) When mounting a pressure gauge, use caution not to tighten excessively. Excessive tightening will cause product failure. Use a pipe tape for sealing. Recommended tightening torque: R1/8: Set between 7 and 9 N·m, R1/4: 12 and 14 N·m respectively.

Note 2) When fluid is water, use G46-□-X3. Wetted parts are made of stainless steel construction. (Some corrosion

may be caused by water because this product's wetted parts are made of brass.) Design system to not be affected by water hammer when using water as fluid. Similarly, when using other fluids, please consult with SMC for fluid compatibility information concerning corrosive potential.

Note 3) Bourdon tube and internal movable parts (gear, etc.) are made of brass and are not electrolessly nickel plated. This is not an internally copper-free product.

Model (Standard)


Model	Pressure range ^{Note)}	Indication	Connection	Note
Model	MPa	unit	thread	
G46E-2-01 to 02M	0 to 0.2		R 1/8	
G46E-4-01 to 02M	0 to 0.4	MPa	R 1/4 M5 (Female thread)	
G46E-7-01 to 02M	0 to 0.7	IVII a		_
G46E-10-01 to 02M	0 to 1.0		Wo (i emale meau)	

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.

Model (Made to Order) Other versions of this unit can be made on a made-to-order basis. Please consult SMC for details, as delivery times may be extended.

. , , , , , , , , , , , , , , , , , , ,							
Model	Pressure range ^{Note)}	Indication	Connection	Note			
iviodei	MPa	unit	thread				
G46E-2-01 to 02M-C/ C1	0 to 0.2		R 1/8				
G46E-4-01 to 02M-C/ C1	0 to 0.4	MPa	B 1/4	With cover			
G46E-7-01 to 02M-C/ C1	0 to 0.7	IVIFA	M5 (Female thread)	ring assembly			
G46E-10-01 to 02M-C/ C1	0 to 1.0		INIS (I elliale lilleau)				

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.





Pressure Gauge for Clean Series (10-series)


G49

O.D: ø44



• Be sure to read the precautions on page 14-11-15 for selection and installation.

Dimensions



an and to our particle generation from the procedure gauge molac.	
G49	
Back side thread	
R 1/4	
Air	
±3% F.S. (Full span)	
Zinc die-casted (Chromate plated)	
Glass	
Brass (Nickle plated for external parts only)	
Brass (3)	
0.095	


- Note 1) When mounting a pressure gauge, use caution not to tighten excessively. Excessive tightening will cause product failure. Use a pipe tape for sealing. Recommended tightening torque: Set between 12 and 14 N·m.
- Note 2) When fluid is water, use G46-□-X3. Wetted parts of G46-□-X3 are made of Stainless steel. Use caution as some corrosion may be caused by water. Standard G49 pressure gauge conact area is made of brass. When using water, use caution not to apply water hammer. Similarly, when using other fluids, consult SMC for fluid compatibility information concerning corrosive potential.
- Note 3) Bourdon tube and internal movable parts (gear, etc.) are made of brass, and are not nickel plated.

Model (Standard)

Model	Pressure range Note)	Indication	Connection	Note
Model	MPa	unit	thread	Note
G49-4-02	0 to 0.4			
G49-7-02	0 to 0.7	MPa	R 1/4	_
G49-10-02	0 to 1.0			

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.

How to Order



- Op	lion
Symbol	Specifications
Nil	_
Х3	Wetted parts stainless steel

Note 1) Cover ring assembly is not available.

Note 2) Movable parts (gear, etc) inside pressure gauge are made of brass.

Note 3) Part number for pressure gauge with MPa-psi units is G49-P**-**-X30. This will no longer be sold for use in Japan after the new Weight and Measure Act has been implemented (October, 1999)

F.R.L.

ΑV

AU

ΑF

AR

IR

VEX

AMR

ITV

IC

VBA

VE□

VY1



AL



Pressure Gauge for Clean Regulator/With Limit Indicator

-∎–SRA, B G46-

O.D.: ø42




G46-10-02-SR A, B

• Be sure to read the precautions on page 14-11-15 for selection and installation.

Dimensions Dimensions in ():
R 1/4 connectingthread G46-□-□- SRA. B 44.5(46.5) 26.5

R1/8 (R1/4)

G46-□-□- SRB: With cover ring assembly (For panel mount)



Standard Specifications

Model			G46-□-SRA	G46-□-SRB		
Туре			Back side thread			
Port size (1)			R ⅓, R ⅓			
Fluid (2)			Air			
Indication pred	cision		±3% F.S. (Full span)			
Fluid contact part	cleaning (Wet	ted part)	Precision cleaning	General degreasing		
Assembly/environment			Clean room M5.5 (Class 10000)	General production line		
Oil/Water free			Oil/Water-free ⁽³⁾			
	Case		Stainless steel 304 (Black melamine painted)			
Material (4)	Clear cover (Surface treatment)		Polycarbonate (Hard coated) Part no.: G46-00-00-2			
	Stud		Stainless steel 316			
	Bourdon tube		Stainless steel 316			
Attachment:	Attachment: C		Part no.: 1305104-6A			
cover ring assembly C ₁		Part no.: 1305104-7A				
Packaging		 Polyethylene cap for stud parts. Airtight polyethylene bag Polyethylene cap for stud Polyethylene bag 				
Weight (kg)			0.085			

Note 1) When mounting a pressure gauge, use caution not to tighten excessively. Excessive tightening will cause product failure. Use a pipe tape for sealing. Recommended tightening torque: R 1/8: Set between 7 and 9 N·m, R 1/4: 12 and 14 N·m respectively.

Note 2) When using water, use caution not to apply water hammer. When using other fluids, please consult with SMC for compatibility information concerning corrosion potential.


Note 3) When manufacturing pressure gauge, SMC uses caution not to allow water to remain in the wetted

Note 4) Movable parts (gear, etc) inside pressure gauge are made of brass.

Model (Standard) Made-to-order products, (not including models above) may take longer leadtime. Please consult with SMC beforehand.

Model	Pressure range MPa	Indication unit	Connection thread	Note
G46-2-01 to 02-SRA	0 to 0.0	- MPa	R ½ R ½	_
G46-2-01 to 02-SRB	0 to 0.2			
G46-4-01 to 02-SRA	0 to 0.4			
G46-4-01 to 02-SRB	0 10 0.4			
G46-7-02-SRA	0 to 0.7			
G46-7-02-SRB	0 10 0.7			
G46-10-02-SRA	0 to 1.0			
G46-10-02-SRB	0 10 1.0			

Note) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.





Pressure Gauge with Switch


GP46 O.D.: ø42





- A pressure switch function has been added to the gauge.
- **■** The pressure switch is equipped with a light for verifying operation.
- The pressure gauge is equipped with a limit indicator.
- To be used for verifying the supply pressure.

Circuit Example



· Be sure to read the precautions in page 14-11-15 for selection and installation.

Standard Specifications

Ottaliaara Opeomoations					
Model			GP46		
Type			Back side thread		
Ambient and fluid temperature			−5 to 60°C (No freezing)		
Indicated pressure range			0 to 1.0 MPa		
Port size (1)			R 1/8, 1/4 (Option M: with M5 female thread)		
Fluid (2)			Air		
Indication precision			±0.03 MPa		
Setting range (3)(4)			1 to 0.8 MPa		
Hysteresis			0.07 MPa		
Pointer error (5)			±0.05 MPa (5 to 40°C)		
			±0.08 MPa (-5 to 60°C) No freezing		
Contact			With light: 1a (Normally open)		
			Without light: 1ab (Normally open/ Normally closed)		
Wiring			Lead wire (Length: 300 mm)		
Indicator light	AC		Neon light		
	DC		Light emitting diode (LED)		
Attachment: With cover ring assembly			Part no.: 1305104-4A		
Weight (kg)			0.12		
	Model Type Ambient and fluid ten Indicated pressure ra Port size (1) Fluid (2) Indication precision Setting range (3)(4) Hysteresis Pointer error (5) Contact Wiring Indicator light Attachment: With cover ring asset	Model Type Ambient and fluid temperature Indicated pressure range Port size (1) Fluid (2) Indication precision Setting range (3)(4) Hysteresis Pointer error (5) Contact Wiring Indicator light AC DC Attachment: With cover ring assembly	Model Type Ambient and fluid temperature Indicated pressure range Port size (1) Fluid (2) Indication precision Setting range (3)(4) Hysteresis Pointer error (5) Contact Wiring Indicator light AC DC Attachment: With cover ring assembly		

Note 1) Indicates the condition at the lower pressure limit. Use a pipe tape for sealing. Recommended tightening torque: R 1/8: Set between 7 and 9 N·m, R 1/4: 12 and 14 N·m respectively

Note 2) Water is not an acceptable fluid. When using the other fluids, please consult with SMC for compatibility information concerning corrosion.

Note 3) Set value of pressure switch is indicated by pointer (green). It is the point where the circuit between N.O. (white) and COM (black) is turned off during pressure decrease. To set the value, turn needle in clockwise position to the correct value. When setting; if desired set position has been passed, turn needle in a counterclockwise direction back again beyond the desired value and then once again return needle in a clockwise direction stopping at the desired value. Value must be set while needle is traveling in a clockwise direction.

Note 4) Make sure to provide a minimum difference of 0.1 MPa between the set pressure and the operating pressure (including the pressure drop). If the difference is smaller, it could lead to improper operation. Refer to page 14-11-15 for details on how to set the setting needle. Use caution: Operating pressure should be the sum of the pressure of the setting needle error (±0.05 MPa), the hysteresis (0.07 MPa), and the display accuracy (±0.05 MPa) on the set pressure value, or the circuit between N.O. (white) and COM (black) may not turn ON while pressure is increasing.

Note 5) Maximum error value: Add the pressure gauge indicator error of 0.03 MPa to the setting needle error.

Other versions of this unit can be made on a made-to-order basis. Please consult with SMC for details, as delivery times may be extended. Model (Standard)

Model	Pressure range ⁽¹⁾	Indication	Connection	Note	
Wodei	MPa	unit	thread	NOLE	
GP46-10-01 to 02		MPa	R ½		
GP46-10-01 to 02L2	0 to 1.0		/ .	_	
GP46-10-01 to 02L5			R 1/4		

Note 1) Do not apply pressure more than the maximum display pressure. This will cause a malfunction.

Micro-switch Rated Voltage

Load	Load resistant		
Rated voltage	30 VDC	125 VAC	250 VAC
Operating current range	0.01 to 0.5 A	0.01 to 0.3 A	0.01 to 0.2 A

Model				GP46		
Gauge	Type			Back side thread		
	Ambient and fluid temperature			−5 to 60°C (No freezing)		
	Indicated pressure range			0 to 1.0 MPa		
	Port size (1)			R 1/8, 1/4 (Option M: with M5 female thread)		
	Fluid (2)			Air		
	Indication precision			±0.03 MPa		
	Setting range (3)(4)			1 to 0.8 MPa		
	Hysteresis			0.07 MPa		
ch	Pointer error (5)			±0.05 MPa (5 to 40°C)		
switch	Folliter error · ·			±0.08 MPa (-5 to 60°C) No freezing		
	Contact			With light: 1a (Normally open)		
sn				Without light: 1ab (Normally open/ Normally closed)		
Pressure	Wiring			Lead wire (Length: 300 mm)		
<u>п</u>	Indicator light	AC		Neon light		
		DC		Light emitting diode (LED)		
	Attachment: With cover ring assembly			Part no.: 1305104-4A		
	Weight (kg)	-		0.12		

AF

F.R.L.

ΑV

AU

AR

IR

VEX

AMR

ITV

IC

VBA


 $\mathsf{VE}\Box$

VY1

PPA

AL

How to Order




Note) Option C1 (Clear cover has protrusion. / Clear cover is removable.) is not compliant.




Pressure Gauge Guide

Circuit Diagram

Without indicator light




With indicator light




The arrow in the diagram indicates the direction of the pressure increase. The light turns OFF when the pressure becomes higher than the set pressure and turns ON when the pressure becomes lower than the set pressure.

Dimensions



GP46: With cover ring assembly (For panel mounting)


Clear cover is not removable.






Procedure for Setting the Limit Gauge Indicator


(1) Before setting the (green) limit indicator, turn the cover counterclockwise (approximately 6 to 7 mm) until it stops. Then, remove by pulling it towards you.



(2) Use a flat head screwdriver (with a 2.9 mm blade width) to set the (green) limit indicator. Be careful not to bend the other needle or damage the dial plate.



(3) After completing the setting, replace the cover. Fit the cover by aligning the cutout in the cover to the groove on the top of the black case. Turn the cover clockwise (approximately 6 to 7 mm) until it stops. Make sure that the matching mark on the cover is aligned with the groove on the top of the



⚠ Precautions

Be sure to read before handling. Refer to pages 14-21-3 to 14-21-4 for Safety Instructions and Common Precautions.

Selection

- 1. Do not apply high load voltage (current) or surge current as this can cause the switch to malfunction.
- Make sure that no direct impact or vibrations are applied to the body.
- If operating under pressure pulsations or in high frequency operations, please contact SMC.


Mounting

∧Caution


- 1. During transport and installation, do not apply shock to the product, such as by dropping doing so will affect its precision.
- Regarding the installation posture, place it perpendicular to the ground, with the zero point on the reading of a pressure gauge facing down.
- **3.** Do not install it in an area that is exposed to high temperature or humidity, because doing so will lead to improper operation.
- 4. To screw in the pressure gauge, make sure to turn the gauge by placing a wrench over the square wrench flats. If the pressure gauge is screwed in by holding it on some other area, air leakage or damage may result.

Procedure for Setting the Limit Gauge Indicator and the Setting Needle

(1) Before setting the limit indicator and the (green) setting needle, turn the cover counterclockwise (approximately 6 to 7 mm) until it stops. Then, remove by pulling it towards you.



(2) Use a flat head screwdriver (with a 2.9 mm blade width) to set the (green) limit indicator. Be careful not to bend the other needle or damage the dial plate.



(3) Before setting the setting needle, use a flat head screwdriver (with a 2.9 mm blade width) to turn the setting screw and set the setting needle to the set pressure.




In the case of turning the set screw

- Clockwise Increase of setting press.
 Counterclockwise
- Counterclockwise
 Decrease of setting press.

Flat head screwdriver

(4) After completing the setting, replace the cover. Fit the cover by aligning the cutout in the cover to the groove on the top of the black case. Turn the cover clockwise (approximately 6 to 7 mm) until it stops. Make sure that the matching mark on the cover is aligned with the groove on the top of the case.



F.R.L.

ΑV

ΑU

ΑF

AR

IR

VEX

AMR

ITV

IC

VBA

 $\mathsf{VE}\Box$

VY1




PPA


AL

Procedure for Assembling the Cover Ring Assembly

Pressure gauge for general purpose



Pressure gauge with switch



- 1. Remove the small screw (1 position) from the pressure gauge.
- 2. Place the cover ring on the pressure gauge.
- **3.** Using the small screw that is provided with the cover ring, install the cover ring. The installation torque is 0.3 to 0.5 N·m.





Safety Instructions

These safety instructions are intended to prevent a hazardous situation and/or equipment damage. These instructions indicate the level of potential hazard by labels of **"Caution"**, **"Warning"** or **"Danger"**. To ensure safety, be sure to observe ISO 4414 Note 1), JIS B 8370 Note 2) and other safety practices.

Caution: Operator error could result in injury or equipment damage.

Warning: Operator error could result in serious injury or loss of life.

Danger: In extreme conditions, there is a possible result of serious injury or loss of life.

Note 1) ISO 4414: Pneumatic fluid power--General rules relating to systems.

Note 2) JIS B 8370: General Rules for Pneumatic Equipment

△Warning

1. The compatibility of pneumatic equipment is the responsibility of the person who designs the pneumatic system or decides its specifications.

Since the products specified here are used in various operating conditions, their compatibility for the specific pneumatic system must be based on specifications or after analysis and/or tests to meet your specific requirements. The expected performance and safety assurance will be the responsibility of the person who has determined the compatibility of the system. This person should continuously review the suitability of all items specified, referring to the latest catalog information with a view to giving due consideration to any possibility of equipment failure when configuring a system.

2. Only trained personnel should operate pneumatically operated machinery and equipment.

Compressed air can be dangerous if an operator is unfamiliar with it. Assembly, handling or repair of pneumatic systems should be performed by trained and experienced operators.

- 3. Do not service machinery/equipment or attempt to remove components until safety is confirmed.
 - 1. Inspection and maintenance of machinery/equipment should only be performed once measures to prevent falling or runaway of the driver objects have been confirmed.
 - When equipment is to be removed, confirm the safety process as mentioned above. Cut the supply pressure for this equipment and exhaust all residual compressed air in the system.
 - 3. Before machinery/equipment is restarted, take measures to prevent shooting-out of cylinder piston rod etc.
- 4. Contact SMC if the product is to be used in any of the following conditions:
 - 1. Conditions and environments beyond the given specifications, or if product is used outdoors.
 - Installation on equipment in conjunction with atomic energy, railway, air navigation, vehicles, medical equipment, food and beverages, recreation equipment, emergency stop circuits, clutch and brake circuits in press applications, or safety equipment.
 - An application which has the possibility of having negative effects on people, property, or animals, requiring special safety analysis.





Common Precautions

Be sure to read before handling. For detailed precautions on every series, refer to main text.

Selection

Marning

1. Confirm the specifications.

Products represented in this catalog are designed for use in compressed air appllications only (including vacuum), unless otherwise indicated.

Do not use the product outside their design parameters. Please contact SMC when using the products in applications other than compressed air (including vacuum).

Mounting

\land Warning

1. Instruction manual

Install the products and operate them only after reading the instruction manual carefully and understanding its contents. Also keep the manual where it can be referred to as necessary.

2. Securing the space for maintenance

When installing the products, please allow access for maintenance.

3. Tightening torque

When installing the products, please follow the listed torque specifications.

Piping

⚠ Caution

1. Before piping

Make sure that all debris, cutting oil, dust, etc, are removed from the piping.

2. Wrapping of pipe tape

When screwing piping or fittings into ports, ensure that chips from the pipe threads or sealing material do not get inside the piping. Also, when the pipe tape is used, leave 1.5 to 2 thread ridges exposed at the end of the threads.

Air Supply

⚠ Warning

1. Operating fluid

Please consult with SMC when using the product in applications other than compressed air (including vacuum). Regarding products for general fluid, please ask SMC about applicable fluids.

2. Install an air dryer, aftercooler, etc.

Excessive condensate in a compressed air system may cause valves and other pneumatic equipment to malfunction. Installation of an air dryer, after cooler etc. is recommended.

3. Drain flushing

If condensate in the drain bowl is not emptied on a regular basis, the bowl will over flow and allow the condensate to enter the compressed air lines.

If the drain bowl is difficult to check and remove, it is recommended that a drain bowl with the auto-drain option be installed.

For compressed air quality, refer to "Air Preparation Equipment" catalog.

4. Use clean air

If the compressed air supply is contaminated with chemicals, cynthetic materials, corrosive gas, etc., it may lead to break down or malfunction.

Operating Environment

⚠ Warning

- 1. Do not use in environments where the product is directly exposed to corrosive gases, chemicals, salt water, water or steam.
- 2. Do not expose the product to direct sunlight for an extended period of time.
- 3. Do not use in a place subject to heavy vibrations and/or shocks.
- 4. Do not mount the product in locations where it is exposed to radiant heat.

Maintenance

⚠ Warning

Maintenance procedures are outlined in the operation manual.

Not following proper procedures could cause the product to malfunction and could lead to damage to the equipment or machine.

2. Maintenance work

If handled improperly, compressed air can be dangerous. Assembly, handling and repair of pneumatic systems should be performed by qualified personnel only.

3. Drain flushing

Remove drainage from air filters regularly. (Refer to the specifications.)

4. Shut-down before maintenance

Before attempting any kind of maintenance make sure the supply pressure is shut of and all residual air pressure is released from the system to be worked on.

5. Start-up after maintenance and inspection

Apply operating pressure and power to the equipment and check for proper operation and possible air leaks. If operation is abnormal, please verify product set-up parameters.

6. Do not make any modifications to be product.

Do not take the product apart.

