


**FL IF MEM 2TX-D**

Order No.: 2832483

<http://eshop.phoenixcontact.de/phoenix/treeViewClick.do?UID=2832483>Memory module, 2 port twisted pair module for saving the switch  
configuration**Ethernet****Commercial data**

GTIN (EAN)	 4 017918 974497
sales group	K000
Pack	1 pcs.
Customs tariff	85176200
Catalog page information	Page 187 (AX-2009)

**Product notes**WEEE/RoHS-compliant since:  
07/03/2007

<http://www.download.phoenixcontact.com>  
Please note that the data given here has been taken from the online catalog. For comprehensive information and data, please refer to the user documentation. The General Terms and Conditions of Use apply to Internet downloads.

**Technical data****Interfaces**

Interface 1	Ethernet 10/100 Base T
No. of ports	2
Connection method	RJ45 female connector
Transmission physics	Copper

---

Transmission speed	10/100 MBit/s
Transmission length	100 m

**Function**

Basic functions	Configuration memory (plug-in)
-----------------	--------------------------------

**Supply voltage**

Supply voltage	(via head station)
Typical current consumption	10 mA

**General data**

Width	31 mm
Height	78 mm
Depth	72.5 mm
Mounting type	In the host system
Type AX	Fine granularity
Weight	70 g
Degree of protection	IP20
Ambient temperature (operation)	0 °C ... 55 °C (no condensation)
Ambient temperature (storage/transport)	-20 °C ... 70 °C
Permissible humidity (operation)	10 % ... 95 % (no condensation)
Permissible humidity (storage/transport)	10 % ... 95 % (no condensation)
Housing material	PA
Noise emission	EN 61000-6-3/-4
Noise immunity	EN 61000-6-2:2005

**Conformity with EMC directives**

Developed in acc. with standard	IEC 61000-6.2
Test standard	IEC 61000-4-2 (ESD)
Test result	Criterion B
Test standard	IEC 61000-4-3 (immunity to radiated interference)
Test result	Criterion A
Test standard	IEC 61000-4-4 (burst)
Test result	Criterion A
Test standard	IEC 61000-4-5 (surge)
Test result	Criterion A
Test standard	IEC 61000-4-6 (immunity to conducted interference)

Test result	Criterion A
Test standard	IEC 61000-4-8 (immunity to magnetic fields)
Test result	Criterion A
Test standard	EN 55022 (emitted interference)
Test result	Criterion A

**Certificates / Approvals**



Certification

ABS, BV, CUL, DNV, GL, UL

**Address**

PHOENIX CONTACT Inc., USA  
586 Fulling Mill Road  
Middletown, PA 17057, USA  
Phone (800) 888-7388  
Fax (717) 944-1625  
<http://www.phoenixcon.com>



© 2011 Phoenix Contact  
Technical modifications reserved;