# Compact PLC series

## A versatile controller for up to 192 I/O points in an ultra-compact package

## SYSMAC CPM2C



An extensive range of models assures efficient machine control in an ultracompact package. CPU Units (DC power supply only) are available with relay or transistor output, terminal block or various connector options, and an optional real-time clock function. Select the output type, number of I/O points and other specifications to meet your needs. Expansion I/O Units with 8 to 32 I/O points make it possible to configure a control system with a maximum of 192 I/O points.

#### CPU Units Depth: 65 mm 10 I/O Points 20 I/O Points 32 I/O Points Relay Output CPU Units ■Relay Output CPU Units (Terminal-block type) (Terminal-block type) CPM2C-10CDR-D (No clock) CPM2C-20CDR-D (No clock) CPM2C-10C1DR-D (Clock) CPM2C-20C1DR-D (Clock) Input points: 6, DC input Input points: 12, DC input Output points: 4 Output points: 8 Transistor Output (Sink) CPU Units Transistor Output (Sink) CPU Units Transistor Output (Sink) CPU Units (Connector type) (Connector type) (Connector type) CPM2C-10CDTC-D (No clock) CPM2C-20CDTC-D (No clock) CPM2C-32CDTC-D (No clock) (MIL-connector type) CPM2C-10C1DTC-D (Clock) CPM2C-20C1DTC-D (Clock) (MIL-connector type) (MIL-connector type) CPM2C-32CDTM-D (No clock) CPM2C-10CDTM-D (No clock) CPM2C-20CDTM-D (No clock) Transistor Output (Source) CPU Units CPM2C-20C1DTM-D (Clock) CPM2C-10C1DTM-D (Clock) (Connector type) CPM2C-32CDT1C-D (No clock) Transistor Output (Source) CPU Units Transistor Output (Source) CPU Units (MIL-connector type) (Connector type) (Connector type) CPM2C-10CDT1C-D (No clock) CPM2C-20CDT1C-D (No clock) CPM2C-32CDT1M-D (No clock) CPM2C-10C1DT1C-D (Clock) CPM2C-20C1DT1C-D (Clock) Input points: 16, DC input (MIL-connector type) (MIL-connector type) Output points: 16 CPM2C-10CDT1M-D (No clock) CPM2C-20CDT1M-D (No clock) CPM2C-10C1DT1M-D (Clock) CPM2C-20C1DT1M-D (Clock) Input points: 6, DC input Input points: 12, DC input Output points: 4 Output points: 8 Programmable DeviceNet Slaves CPU Units with CompoBus/S Master Function AC Power Supply Unit Transistor Output (Sink) Transistor Output (Sink) **CPU Unit** CPU Unit (Connector type) (Connector type) CPM2C-S100C-DRT (Clock) CPM2C-S100C (Clock) CPM2C-PA201 Transistor Output (Source) ●100- to 240-V AC input Transistor Output (Source) CPU Unit **CPU Unit** ●24-V AC/600-mA output (Connector type) (Connector type) CPM2C-S110C-DRT (Clock) CPM2C-S110C (Clock) Input points: 6, DC input Input points: 6, DC input Output points: 4 Output points: 4

wnloaded from Elcodis.com electronic components distributor

86



•

#### Specifications

#### General

Item	CPU Unit Specificat	ion					
	CPU Units with 10 I/O points (relay outputs)	CPU Units with 10 I/O points (transistor outputs)	CPU Units with 20 I/O points (relay outputs)	CPU Units w 20 I/O points (transistor o	vith s outputs)	CPU Units with 32 I/O points (transistor outputs)	CPM2C-S CPU Unit with 10 I/O points (transistor outputs)
Supply voltage	24 V DC						
Operating voltage range	20.4 to 26.4 V DC						
Power consumption (Add Ex- pansion Unit consumption from following tables.)	4 W	3 W	4 W	3 W		3 W	3 W
Inrush current	25 A max.						
Insulation resistance	20 M $\Omega$ min. (at 500 V	DC) between isolated	l circuits				
Dielectric strength	2,300 V AC for 1 min	(between isolated circ	cuits)				
Noise immunity	Conforms to IEC6100	00-4-4, 2 kV (power lin	ies)				
Vibration resistance	Conforming to IEC 60 tions for 80 minutes 6	0068-2-6, JIS C0040: 1 each (Time coefficient;	10 to 57 Hz, 0.075-m 8 minutes $\times$ coeffici	m amplitude, 57 ent factor 10 = t	' to 150 H otal time	z, acceleration: 9.8 m/s 80 minutes)	<sup>2</sup> in X, Y, and Z direc-
Shock resistance	Conforming to IEC 60	068-2-27, JIS C0041:	: 147 m/s <sup>2</sup> three time	s each in X, Y, a	and Z dire	ections	
Ambient temperature	Operating: 0° to 55° Storage: –20° to 75°	Derating: 0° to 55°C Storage: –20° to 75°C (except for the battery)					
Humidity	10% to 90% (with no	condensation)					
Atmosphere	Must be free from co	rrosive gas					
I/O interface	Terminal block	Connector	Terminal block	Connector			
Power interrupt time	2 ms min.						
Weight	200 g max.	200 g max.	250 g max.	200 g max.		200 g max.	160 g max.
	Expansion I/O Unit w	ith 10 I/O points (relay	v outputs)	2	00 g max		
	Expansion I/O Unit w	ith 20 I/O points (relay	v outputs)	2	00 g max		
	Expansion I/O Units with 24 I/O points (transistor outputs)						
	Expansion I/O Unit with 32 I/O points (transistor outputs)				200 g max.		
	Expansion I/O Unit w	ith 8 input points		1	50 g max		
	Expansion I/O Unit with 16 input points				50 g max		
	Expansion I/O Units	with 8 output points (tr	ansistor outputs)	1	150 g max.		
	Expansion I/O Units	with 16 output points (	transistor outputs)	1	150 g max.		
	Expansion I/O Unit w	ith 8 output points (rel	ay outputs)	2	200 g max.		
	Simple Communicati	ons Unit		1	150 g max.		
	Peripheral/RS232C Adapter Unit 150 g max.						
	HS422/HS232C Adapter Unit 150 g max.						
	AC Power Supply Un	lit		2	50 g max		
	Analog I/O Unit	Linit		2	00 g max		
	CompoRuo/S I/O Lin			2	50 g max		
	CompoBus/S I/O Link Unit						

#### **CPM2C Power Consumption**

Use the following power consumption tables to calculate the total power capacity required when using a CPM2C PLC. The rated output for the CPM2C-PA201 AC Power Supply Unit is 15 W. Any surplus power not required for the PLC directly can be used as service power supply for sensors and other devices.

CPU Unit	Power consumption (W)
CPM2C-10C(1)DR-D	4
CPM2C-20C(1)DR-D	4
CPM2C-S1D0C-DRT1	3
CPM2C-S1□0C	3
CPM2C-10C(1)DT(1)□-D	3
CPM2C-20C(1)DT(1)□-D	3
CPM2C-32C(1)DT(1)□-D	3

The power consumption of the CPU Unit includes power for the Programming Consoles and Adapter Units.

Add the following consumptions when using Expansion I/O Units.

Expansion I/O Unit	Power consumption (W)
CPM2C-10EDR	1
CPM2C-20EDR	2
CPM2C-24EDT(1)	1
CPM2C-32EDT(1)	1
CPM2C-MAD11	3.5
CPM2C-SRT21	1
CPM2C-TS001/002	1.5
CPM2C-8ED /16ED	1
CPM2C-8ER	2
CPM2C-8ET(1)□/16ET(1)□	1

Programmable Controllers

#### **CPM2C Characteristics**

۲

Item		CPI I Unit Specit	fication					
item		CPU Units with 10 I/O points (relay outputs)	CPU Units with 10 I/O points (transistor out- puts)	CPU Units with 20 I/O points (relay outputs)	CPU Units with 20 I/O points (transistor out- puts)	CPU Units with 32 I/O points (transistor out- puts)	CPM2C-S CPU Unit with 10 I/O points (transistor outputs) and CompoBus/S Master function	
Control metho	bd	Stored program i	nethod	•		•		
I/O control me	ethod	Cyclic scan with	direct output (Imr	nediate refreshing	can be performed	d with IORF(97).)		
Programming	language	Ladder diagram						
Instruction len	ngth	1 step per instruc	tion, 1 to 5 words	s per instruction				
Instructions		Basic instructions Special instruction	s: 14 ns:105 instructio	ns, 185 variations				
Execution time	e	Basic instructions Special instruction	s: 0.64 μs (LD ins ns:7.8 μs (MOV i	truction) nstruction)				
Program capa	acity	4,096 words						
I/O capacity	CPU Unit only With Expansion I/O Units	10 points 170 points max.		20 points 180 points max.		32 points 192 points max.	10 points 362 points max. (106 local + 256 remote)	
Input bits		IR 00000 to IR 00	0915 (Words not	used for input bits	can be used for w	vork bits.)	1	
Output bits		IR 01000 to IR 0	1915 (Words not	used for output bit	s can be used for	work bits.)		
CompoBus/S	input bits					,	128 inputs: IR 02000 I/O bits not used for I/	
CompoBus/S	output bits						128 outputs: IR 03000 to IR 03715	
Work bits		928 bits:IR 02000 IR 20000 to IR 22	0 to IR 04915 (Wo 2715 (Words IR 2	ords IR 020 to IR 0 00 to IR 227)	049) and		672 bits: IR 02800 to IR 02915 (Words IR 028 to IR 029), IR 03800 to IR 04915 (Words IR 038 to IR 049)and IR 20000 to IR 22715 (Words IR 200 to IR 227	
Special bits (S	SR area)	448 bits: SR 228	00 to SR 25515 (	Words SR 228 to 3	SR 255)			
Temporary bit	ts (TR area)	8 bits (TR0 to TF	87)					
Holding bits (H	HR area)	320 bits: HR 000	0 to HR 1915 (W	ords HR 00 to HR	19)			
Auxiliary bits (	(AR area)	384 bits: AR 000	0 to AR 2315 (Wo	ords AR 00 to AR 2	23)			
Link bits (LR a	area)	256 bits: LR 000	0 to LR 1515 (Wo	rds LR 00 to LR 1	5)			
		10-ms timers: TIMH(15) 100-ms timers: TIM 1-s/10-s timers: TIML(						
Data memory		Read/Write: 2,048 words (DM 0000 to DM 2047)* Read-only: 456 words (DM 6144 to DM 6599) PC Setup: 56 words (DM 6600 to DM 6655) *The Error Log is contained in DM 2000 to DM 2021.						
CompoBus/S	master functions						Connects to up to 32 slaves with up to 256 I/O link points	
DeviceNet sla	we functions						DeviceNet remote I/O link (DRT model only) Up to 1,024 I/O link points Explicit messages Read/write of specified areas from PLC with Master Unit	
Basic inter-	Interrupt pro-	2 interrupts	2 interrupts	4 interrupts	4 interrupts	4 interrupts	2 interrupts	
rupts	cessing	Shared by the ex	ternal interrupt in	puts (counter mod	le) and the quick-r	response inputs.		
	Interval timer in- terrupts	1 (Scheduled Inte	errupt Mode or Si	ngle Interrupt Mod	le)			
High- speed counter	High-speed counter	One high-speed Counter interrupt	counter: 20 kHz s :: 1 (set value con	ingle-phase or 5 k nparison or set-val	Hz two-phase (lin ue range compari	ear count method son)	)	
High-	Interrupt inputs	2 inputs	2 inputs	4 inputs	4 inputs	4 inputs	2 inputs	
speed	(Counter mode)	Shared by the ex	ternal interrupt in	puts and the quick	-response inputs.	•	•	
counter	Counter inter-	2 inputs	2 inputs	4 inputs	4 inputs	4 inputs	2 inputs	
rupts Shared by the extern		by the external interrupt inputs and the quick-response inputs.						
Pulse output		Two points with no acceleration/deceleration, 10 Hz to 10 kHz each, and no direction control. One point with trapezoid acceleration/deceleration, 10 Hz to 10 kHz, and direction control. Two points with variable duty-ratio outputs (using PWM(—)). (Pulse outputs can be used with transistor outputs only, they cannot be used with relay outputs )						
Synchronized	pulse control	One point: A pulse output can be created by combining the high-speed counter with pulse outputs and multiplying the frequency of the input pulse es from the high-speed counter by a fixed factor. (This output is possible with transistor outputs only, it cannot be used with relevoutputs.)						
Quick-respons	se inputs	2 inputs	2 inputs	4 inputs	4 inputs	4 inputs	2 inputs	
		Shared by the ex	ternal interrupt in width: 50 us max	puts and the inter	rupt inputs (counte	er mode).	, ·	
Input time cor (ON response OFF response	nstant e time = e time)	Can be set for al (1 ms, 2 ms, 3 m	l input points. s, 5 ms, 10 ms, 2	0 ms, 40 ms, or 80	) ms)			
Clock function	, 1	Shows the year	month day of the	week day hour	minute and seco	nd (Battery backu	n)	

 $( \bullet )$ 

Item	CPU Unit Specification					
	CPU Units with 10 I/O points (relay outputs)	CPU Units with 10 I/O points (transistor out- puts)	CPU Units with 20 I/O points (relay outputs)	CPU Units with 20 I/O points (transistor out- puts)	CPU Units with 32 I/O points (transistor out- puts)	CPM2C-S CPU Unit with 10 I/O points (transistor outputs) and CompoBus/S Master function
Communications functions	Peripheral port: Supports Host Link, peripheral bus, no-protocol, or Programming Console connections. RS-232C port: Supports Host Link, no-protocol, 1:1 Slave Unit Link, 1:1 Master Unit Link, or 1:1 NT Link connections. A CPM2C-CN111, CS1W-CN114, or CS1W-CN118 Connecting Cable, or an Interface Unit (CPM2C-CIF01-V1 or CPM2C-CIF11) is required to connect to the CPM2C's communications port.					
Memory protection	HR area, AR area	a, program conter	nts, read/write DM	area contents, an	d counter values a	are maintained during power interruptions.
Memory backup	Flash memory: Program, read-only DM area, and PC Setup Memory backup: The read/write DM area, HR area, AR area, and counter values are backed up. With CPU Units that are equipped with a clock, the battery will backup memory for 2 years at 25° C. With CPU Units that are not equipped with a clock, if a battery is not installed, the internal capacitor will backup memory for 10 days at 25° C. If a battery (optional CPM2C-BAT01 Battery) is installed, it will backup memory for 5 years at 25° C.					
Self-diagnostic functions	CPU Unit failure	(watchdog timer),	I/O bus error, batt	tery error, and me	mory failure	
Program checks	No END instruction	on, programming	errors (checked w	hen operation is s	tarted)	

#### **CPM2C I/O Specifications**

#### **1. CPU Unit Input Specifications**

Item	Specifications			Circuit configuration
	Units with 10 I/O points	Units with 20 I/O points	Units with 32 I/O points	
Input volt- age	24 V DC <sup>+10%</sup> / <sub>-15%</sub>			
Input impedance	IN00000 to IN00001: 2.7 kΩ IN00002 to IN00004: 3.9 kΩ IN00005: 4.7 kΩ	IN00000 to IN00001: 2.7 kΩ IN00002 to IN00006: 3.9 kΩ IN00007 and up: 4.7 kΩ	IN00000 to IN00001: 2.7 kΩ IN00002 to IN00006: 3.9 kΩ IN00007: 4.7 kΩ IN00100 to IN00107: 4.7 kΩ	
Input current	IN00000 to IN00001: 8 mA IN00002 to IN00004: 6 mA IN00005: 5 mA	IN00000 to IN00001: 8 mA IN00002 to IN00006: 6 mA IN00007 and up: 5 mA	IN00000 to IN00001: 8 mA IN00002 to IN00006: 6 mA IN00007: 5 mA IN00100 to IN00107: 5 mA	Units with 10 I/O points: 00002 to 00004 Units with 20/32 I/O points: 00002 to 00006 IN O W 3.9k Q S S S S S S S S S S S S S S S S S S
ON voltage/ current	IN00000 to IN00001:17 V DC IN00002 and up:14.4 V DC m	, 5 mA nin., 3.5 mA		
OFF voltage/ current	5.0 V DC max., 1.1 mA			Input LED 5
ON delay	1 to 80 ms max. Default: 10 r	ms (See note.)		Units with 20 I/O points: 00007 to 00011
OFF delay	1 to 80 ms max. Default: 10 r	ns (See note.)		

Note: The input time constant can be set to 1, 2, 3, 5, 10, 20, 40, or 80 ms in the PC Setup.

High-speed Counter Inputs The following CPU Unit input bits can be used as high-speed counter inputs. The maximum count frequency is 5 kHz in differential phase mode and 20 kHz in the other modes.

Input	Function				
	Differential phase mode	Pulse plus direction input mode	Up/down input mode	Increment mode	
IN00000	A-phase pulse input	Pulse input	Increment pulse input	Increment pulse input	
IN00001	B-phase pulse input	Direction input	Decrement pulse input	Normal input	
IN00002	Z-phase pulse input or hardware res	Z-phase pulse input or hardware reset input (IN00002 can be used as a normal input when it is not used as a high-speed counter input.)			

#### Interrupt Inputs

90

CPM2C PCs have inputs that can be used as interrupt inputs (interrupt input mode or counter mode) and quick-response inputs. The minimum pulse width for these inputs is 50  $\mu s.$ 

In CPU Units with 10 I/O points, inputs IN00003 and IN00004 can be used as interrupt inputs. In CPU Units with 20 or 32 I/O points, inputs IN00003 through IN00006 can be used as interrupt inputs.

•

#### 2. Expansion I/O Unit Input Specifications



Note: The input time constant can be set to 1, 2, 3, 5, 10, 20, 40, or 80 ms in the PC Setup.

#### 3. CPM2C Output Specifications (CPU Units and Expansion I/O Units)

#### **Relay Output**

 $( \bullet )$ 



#### Transistor Outputs (Sinking or Sourcing) for CPU Units and Expansion I/O Units

Item	Specification
Max. switching capacity	CPU Units with 10 or 20 I/O Points 01000 to 01007: 40 mA at 4.5 V DC to 300 mA at 20.4 V DC, 300 mA (20.4 to 26.4 V) CPU Units with 32 I/O Points 01000 to 01007: 40 mA at 4.5 V DC to 300 mA at 20.4 V DC, 300 mA (20.4 to 26.4 V) 01100 to 01107: 40 mA at 4.5 V DC to 100 mA at 20.4 V DC, 100 mA (20.4 to 26.4 V) (See note.) Expansion I/O Units 01□00 to 01□07: 40 mA at 4.5 V DC to 300 mA at 20.4 V DC, 300 mA (20.4 to 26.4 V) 01□00 to 01□15: 40 mA at 4.5 V DC to 100 mA at 20.4 V DC, 100 mA (20.4 to 26.4 V)
Min. switching capacity	0.5 mA
Max. inrush current	0.9 A for 10 ms (charging and discharging waveform)
Leakage current	0.1 mA max.
Residual voltage	0.8 V max.
ON delay	OUT01000 and OUT01001:20 μs max. OUT01002 and up:0.1 ms max.
OFF delay	OUT01000 and OUT01001:40 µs max. for 4.5 to 26.5 V, 10 to 300 mA 0.1 ms max. for 4.5 to 30 V, 0.5 to 10 mA OUT01002 and up:1 ms max.
Fuse	1 fuse for each 2 outputs (The fuse cannot be replaced by the user.)

•

 $( \bullet )$ 



Note: Connect dummy resistance as required and maintain the load current between 10 and 150 mA when using 01000 and 01001 for pulse outputs. The ON/OFF response time will increase if the load current is below 10 mA, preventing outputting high-speed pulses. The transistors will heat if the output current is greater than 150 mA, possibly destroying the elements.

### CPM2C-S1 DOC CPU Units with CompoBus/S Master

#### Ultra-compact CPM2C CPU unit with CompoBus/S master offering high speed remote I/O communication.

- The compact design makes this unit ideal for local control applications.
   At 40 x 90 x 65 mm (W x H x D) with 10 I/O points and CompoBus/S master offering versatile expand-
- ability it is possible to fullfill constrol systems needs.
  A large number of expansion I/O points reduces system construction cost. Up to three Expansion Up to three expansion terminals can be connected to the CPU unit. Furthermore, CompoBus/S remote I/O terminals can be used for expansion I/O points. Not only in-panel wiring but also external wiring is simplified. The miniaturization of the control panel reduces cable, terminal block, and wiring cost.
- Easy system designing, modification, and expansion by CompoBus/S remote I/O terminals. With this high-speed communication bus and no complicated wiring they can be used as expansion terminal blocks with minimal modifications to the system layout as long as room for expansion is reserved at the first designing stage.
- A calendar/clock ensures timed machine control, including data collection and error logs with date and time stamps.





•

(

#### **Ordering Information**

Unit		Inputs	Outputs	Clock	Model
10 points (6 inputs/4 out-	Connector model	6 points at 24 V DC	4 transistor sinking outputs	Yes	CPM2C-S100C
puts)			4 transistor sourcing outputs	Yes	CPM2C-S110C

#### Specifications

#### **General Specifications**

Item		Specification				
Control method		Stored program method				
I/O control method		Cyclic scan method				
		[Immediate refreshing can be performed with IORF(97).]				
Programming langua	ge	Ladder diagram				
Instruction length		1 step per instruction				
Instructions	Decis instructions	1 to 5 words per instruction				
Instructions	Basic Instructions					
Europetice times	Special Instructions	105 instructions, 185 variations				
Execution time	Basic Instructions	U-04 µS (LD Instruction)				
Program consoity	Special Instructions					
Max 1/O capacity		-, uso words				
Max. 1/O capacity		Expansion I/O Unit 96 points (32-point Expansion I/O Unit x 3)				
		(Up to 3 Expansion Units can be connected.)				
		CompoBus/S: 256 points (362 points in total)				
Input bits		IR 00000 to IR 00915				
-		(Bits not used for input bits can be used for work bits.)				
Output bits		IR 01000 to IR 01915				
CompoRuo/C input bi	to.	(bits not used for output bits can be used for work bits.)				
CompoBus/S input bi	lS hite	126 bits. In 02000 to In 02715 (words in 020 to In 027)				
Work bite	DIIS	126 bits. In 03000 to IR 02715 (words IR 028 to IR 020)				
WOIK DIIS		IB 03800 to IB 03915 (words IB 038 to IB 039)				
		IR 04000 to IR 04915 (words IR 040 to IR 049)				
		IR 20000 to IR 22715 (words IR 200 to IR 227)				
Special bits (SR area	)	440 bits: SR 22800 to SR 25507 (words SR 228 to SR 255)				
Temporary bits (TR a	irea)	8 bits: (TR 0 to TR 7)				
Holding bits (HR area)		320 bits: HR 0000 to HR 1915 (words HR 00 to HR 19)				
Auxiliary bits (AR are	a)	384 bits: AR 0000 to AR 2315 (words AR 00 to AR 23)				
Listative (LD susse)		These include Composition States (and the page with the page of th				
Link bits (LR area)		256 points: LR 0000 to LR 1515 (words LR 00 to LR 15)				
Timers/Counters		255 timets/counters: Thi/CNT 000 to Thi/CNT 255				
		10-ms timers: TIMH (15)				
		100-ms timers TIM				
		1-s/10-s timers: TIML ()				
		Decrementing counters: UNI Reversible counters: CNTR (12)				
Data momony	Pood/Write	Reversible counters. CNTR (12)				
Data memory	neau/white	The Error Log is contained in DM 2000 to DM 2021.				
	Read only	456 words (DM 6144 to DM 6599)				
	PC Setup	56 words (DM 6600 to DM 6655)				
Basic interrupt func-	Interrupt inputs	2 interrupts (Used for both counter mode interrupts inputs and quick-response inputs.				
tions	Scheduled interrupts	1 interrupt				
High-speed counter	High-speed counters	1 counter (single phase at 20 kHz or 2 phases at 5 kHz)				
functions	Counter interrupts	1 interrupt (set value comparison or set-value range comparison)				
	Interrupt inputs	2 interrupts (Used for both external interrupts inputs and quick-response inputs.)				
	(counter mode)					
	Count-up interrupts	2 interrupts (Used for both external interrupts inputs and quick-response inputs.)				
Quick-response input	IS	2 points (Used for both external interrupts inputs and counter mode interrupt inputs.)				
D data se data d		Min. input pulse width: 50 µs max.				
Puise output		2 points with no acceleration/deceleration,				
		10 Hz to 10 kHz each, and no one clone control. I point with unapezoid acceleration deceleration, 10 Hz to 10 kHz with direction control or 2 points with variable duty-ratio outputs				
Synchronized pulse control						
Input time constant		, can be set for CPU Unit inputs and Expansion Unit inputs only				
(ON response time = OFF response time)		(1, 2, 3, 5, 10, 20, 40, or 80 ms)				
Clock		Equipped with clock (built-in RTC)				
Communications functions		Peripheral port: Supports Host Link, peripheral bus, no-protocol communications, and Programming Console connec-				
		tions.				
Dama fall	(	HS-232C port: Supports Host Link, no-protocol communications, 1-to-1 Link, or 1-to-1 NT Link connections.				
Power failure backup	function	Data in HH, AH, Counter (CNT), and Data Memory (DM) areas is held.				
Memory backup		Non-volatile (flash) memory: Program, read-only DM area, and PC Setup				
		Internet provide the second se				
Self-diagnostic function	ons	UPU error (watchdog timer), memory errors, communications errors, setting errors, battery errors, and expansion I/O				
Program check		No END instruction, programming errors (checked when operation is started)				
r lografit check		The Line metadologi, programming errors (checked when operation is statted)				

94

 $(\mathbf{\bullet})$ 

rogrammable Controllers

Item		Specification
Programming devic- es	Programming Console	C200H-PRO27, CQM1-PRO01, or CQM1H-PRO01
	CX-One	Windows 2000 / XP

Note: Connecting Cable (CPM2C-CN111, CS1W-CN114, or CS1W-CN118) is required to connect to the communications peripheral /RS-232C port.

#### **Communications Specifications**

Communications metho	d	Special CompoBus/S protocol				
Coding method		Manchester coding				
Connection form		Combination of multi-drop method and T-branch connections (see note 1)				
Baud rate		High-speed Communications Mode: 750 kbps Long-distance Communications Mode: 93.75 kbps (see note 2)				
Communications cycle	High-speed	0.5 ms (with 8 input and 8 output slaves connected)				
time	Communications Mode	0.8 ms (with 16 input and 16 output slaves connected)				
	Long-distance Commu-	4.0 ms (with 8 input and 8 output slaves connected)				
	nications Mode	6.0 ms (with 16 input and 16 output slaves connected)				
Communications media		2-conductor cable (VCTF 0.75 x 2), 4-conductor cable (VCTF 0.75 x 4), or Special Flat Cable				
Communications dis-	High-speed	2-conductor VCTF cable:				
tance	Communications Mode	Main line length:100 m max.				
		Branch line length:3 m max.				
		I otal branch line length:50 m max.				
		Special Flat Cable, 4-conductor VCTF cable:				
		Main line length: 30 m max.				
		Dialici ilie lengui.o in max.				
		When Special Elat Cable is used to connect fewer than 16 Slaves, the main line can be up to 100 m long and the				
		(which opecial had cable is used to connect level that to claves, the main me can be up to too mining and the				
	Long-distance Commu-					
	nications Mode	Main line length 500 m max				
		Branch line lendth 6 m max				
		Total branch line length 120 m max				
		Special Flat Cable, 4-conductor VCTF cable:				
		Variable branch wiring (total cable length 200 m max.)				
		(There are no limits on the branching format or main, branch, or total line lengths.				
		The terminator must be connected to the point in the system farthest from the master.)				
Maximum number of no	des	32				
Error control checks		Manchester code check, frame length check, and parity check				

Note: 1. A terminator must be connected to the point in the system farthest from the Master.

2. The baud rate is switched using DM settings (default setting is 750 kbps).

#### Dimensions

Note: All units are in millimeters unless otherwise indicated.



Note: Refer to CPM2C-S Programmable Controller Operation Manual (W377) for detailed specifications.

#### CPM2C-S10C-DRT

## **Programmable Slave PLC**

#### Multi-functional programmable slave for distributed control

A part of an installation consisting of sensors, actuators and control is handled as one DeviceNet slave.

The distribution of device control enables the production of standard units with standardized programs and decreasing the load on the system master PLC. Conventional distributed I/O control networks do not allow I/O checks or operation checks until all devices on the networks are assembled and connected. Programmable slaves, however, allow I/O and operation checks

on any distributed unit independently.

- DeviceNet slave functionality
- Supports multi-word I/O links and explicit message communication, making it possible for the master to control the data of all the slaves on the network. Data that does not need immediate transmission, such as log data, can be transmitted in blocks using explicit message communication.
- CompoBus/S master functionality Connects to remote signal lights, pushbutton switches, terminal blocks, and pneumatic valves from other companies over VCTF or easy-to-branch flat cable.
- RS-232C Communications Barcodereaders and PTs can be connected to serial port. The data then will be processed locally and thus reduces the load on the central controlling PLC.
- Expansion unit (Up to three units) A wide variaty of different expansion units is available to fit the application needs.





#### **Ordering Information**

Unit		Inputs	Outputs	Clock	Model
10 points (6 inputs/4 out-	Connector model	6 points at 24 V DC	4 transistor sinking outputs	Yes	CPM2C-S100C-DRT
puts)			4 transistor sourcing outputs	Yes	CPM2C-S110C-DRT

#### Specifications

•

#### **General Specifications**

Item		Specification			
Control method		Stored program method			
I/O control method		Cyclic scan method (Immediate refreshing can be performed with IORF(97).)			
Programming language		Ladder diagram			
Instruction length		1 step per instruction			
Ŭ		1 to 5 words per instruction			
Instructions	Basic instructions	14			
	Special instructions	105 instructions, 185 variations			
Execution time	Basic instructions	0.64 µs (LD instruction)			
	Special instructions	7.8 μs (MOV instruction)			
Program capacity		4,096 words			
Max. I/O capacity		CPU Unit only: 10 points Expansion I/O Unit: 96 points (32-point Expansion I/O Unit x 3) (Up to 3 Expansion Units can be connected.) CompoBus/S: 256 points (362 points in total)			
Input bits		IR 00000 to IR 00915 (Bits not used for input bits can be used for work bits.)			
Output bits		IR 01000 to IR 01915 (Bits not used for output bits can be used for work bits.)			
CompoBus/S input bit	ts	128 bits: IR 02000 to IR 02715 (words IR 020 to IR 027)			
CompoBus/S output b	pits	128 bits: IR 03000 to IR 03715 (words IR 030 to IR 037)			
WORK DITS		IR 03800 to IR 02915 (words IR 028 to IR 029) IR 03800 to IR 03915 (words IR 038 to IR 039) IR 04000 to IR 04915 (words IR 040 to IR 049) IR 20000 to IR 22715 (words IR 200 to IR 227)			
Special bits (SR area)	)	440 bits: SR 22800 to SR 25507 (words SR 228 to SR 255)			
Temporary bits (TR a	rea)	8 bits: (TR 0 to TR 7)			
Holding bits (HR area	)	320 bits: HR 0000 to HR 1915 (words HR 00 to HR 19)			
Auxiliary bits (AR area	a)	384 bits: AR 0000 to AR 2315 (words AR 00 to AR 23) These include CompoBus/S slave status flags (words AR 04 to AR 07).			
Link bits (LR area)		256 points: LR 0000 to LR 1515 (words LR 00 to LR 15)			
Timers/Counters		256 timers/counters: TIM/CNT 000 to TIM/CNT 255 1-ms timers: TIMH () 10-ms timers: TIMH (15) 100-ms timers TIM 1-s/10-s timers: TIML () Decrementing counters: CNT Reversible counters: CNTR (12)			
Data memory	Read/Write	2,048 words (DM 0000 to DM 2047) The Error Log is contained in DM 2000 to DM 2021.			
	Read only	456 words (DM 6144 to DM 6599)			
	PC Setup	56 words (DM 6600 to DM 6655)			
DeviceNet slave functions		DeviceNet Remote I/O Link No. of I/O Link points: 1,024 max. Explicit message communications Any PC data area can be accessed from the master.			
Basic interrupt func-	Interrupt inputs	2 interrupts (Used for both counter mode interrupts inputs and quick-response inputs.			
tions Scheduled interrupts		1 interrupt			

Item		Specification				
High-speed counter	High-speed counters	1 counter (single phase at 20 kHz or 2 phases at 5 kHz)				
functions	Counter interrupts	1 interrupt (set value comparison or set-value range comparison)				
	Interrupt inputs	2 interrupts (Used for both external interrupts inputs and quick-response inputs.)				
	(counter mode)					
	Count-up interrupts	2 interrupts (Used for both external interrupts inputs and quick-response inputs.)				
Quick-response input	S	2 points (Used for both external interrupts inputs and counter mode interrupt inputs.) Min. input pulse width: $50 \ \mu s \ max$ .				
Pulse output		2 points with no acceleration/deceleration,				
		10 Hz to 10 kHz each, and no direction control: 1 point with trapezoid acceleration/deceleration, 10 Hz and 10 kHz with no direction control: or 2 points with variable duty-ratio outputs				
Synchronized pulse of	control	1 point				
Input time constant		Can be set for CPU Unit inputs and Expansion Unit inputs only				
(ON response time =	OFF response time)	(1, 2, 3, 5, 10, 20, 40, or 80 ms)				
Clock		Equipped with clock (built-in RTC)				
Communications fund	otions	Peripheral port: Supports Host Link, peripheral bus, no-protocol communications, and Programming Console connec- tions.				
		HS-232C port: Supports Host Link, no-protocol communications, 1-to-1 Link, or 1-to-1 NT Link connections.				
Power failure backup	function	Data in HR, AR, Counter (CNT), and Data Memory (DM) areas is held.				
Memory backup		Non-volatile (flash) memory: Program, read-only DM area, and PC Setup				
		Memory backup (lithium battery: 2 years lifetime): DM area, HR area, AR area, and counter values				
Self-diagnostic functions		CPU error (watchdog timer), memory errors, communications errors, setting errors, battery errors, and expansion I/O bus errors				
Program check		No END instruction, programming errors (checked when operation is started)				
Programming devices	Programming Console	C200H-PRO27, CQM1-PRO01, or CQM1H-PRO01				
	CX-One	Windows 2000 / XP				

Note: Connecting Cable (CPM2C-CN111, CS1W-CN114, or CS1W-CN118) is required to connect to the communications peripheral /RS-232C port.

#### **Communications Specifications**

#### **DeviceNet**

Communications protoc	ol	DeviceNet				
Connection form		Combination of multi-drop and T-branch connections (see note 1)				
Baud rate		500, 250, or 125 kbps (switchable)				
Communications media Special 5-conductor cable (2 signal lines, 2 power supply lines, and 1 shield line)		Special 5-conductor cable (2 signal lines, 2 power supply lines, and 1 shield line)				
Communications dis- tance	Baud rate	500 kbps: Max. network length (see note 2):100 m max. (see note 3) Main line length:6 m max. Total branch line length:39 m max. 250 kbps: Max. network length (see note 2):250 m max. (see note 3) Main line length:6 m max. Total branch line length:78 m max. 125 kbps: Max. network length (see note 2):500 m max. (see note 3) Main line length:6 m max. Total branch line length:156 m max.				
Max. number of connec	ting nodes	64 (63 slaves and 1 master)				
Error control checks		CRC error, node address duplication check, and scan list verification				

Note: 1. A terminator must be connected to both ends of the trunk line.

2. The maximum network length is the lenght of the trunk line.

3. When Thin Cable is used for the main line, the main line must be 100 m or less in length.

#### CompoBus/S

Communications method		Special CompoBus/S protocol				
Coding method		Manchester coding				
Connection form		Combination of multi-drop method and T-branch connections (see note 1)				
Baud rate		High-speed Communications Mode: 750 kbps Long-distance Communications Mode: 93.75 kbps (see note 2)				
Communications cycle	High-speed Communi-	0.5 ms (with 8 input and 8 output slaves connected)				
time	cations Mode	0.8 ms (with 16 input and 16 output slaves connected)				
	Long-distance Commu-	4.0 ms (with 8 input and 8 output slaves connected)				
	nications Mode	6.0 ms (with 16 input and 16 output slaves connected)				
Communications media		2-conductor cable (VCTF 0.75 x 2), 4-conductor cable (VCTF 0.75 x 4), or Special Flat Cable				
Communications dis- tance	High-speed Communications Mode	2-conductor VCTF cable: Main line length:100 m max. Branch line length:3 m max. Total branch line length:50 m max. Special Flat Cable, 4-conductor VCTF cable: Main line length:30 m max. Branch line length:3 m max. Total branch line length:30 m max. (When Special Flat Cable is used to connect fewer than 16 Slaves, the main line can be up to 100 m long and the total branch line length can be up to 50 m.)				
	Long-distance Commu- nications Mode	2-conductor VCTF cable: Main line length:500 m max. Branch line length:6 m max. Total branch line length:120 m max. Special Flat Cable, 4-conductor VCTF cable: Variable branch wiring (total cable length 200 m max.) (There are no limits on the branching format or main, branch, or total line lengths. The terminator must be connected to the point in the system farthest from the master.)				
Maximum number of no	des	32				
Error control checks		Manchester code check, frame length check, and parity check				

Note: 1. A terminator must be connected to the point in the system farthest from the Master.

2. The baud rate is switched using DM settings (default setting is 750 kbps).

#### Dimensions

Note: All units are in millimeters unless otherwise indicated.



Note: Refer to CPM2C-S Programmable Controller Operation Manual (W377) for detailed specifications.

# AC Power Supply Unit

• The CPM2C-PA201 is a slim and compact AC Power Supply Unit of the same shape as the CPM2C's CPU Unit. It can be connected simply using the connecting cable (23 cm) provided. It can also be used for CPM1A and CPM2A CPU Units and as display power supply (wired by the user).

AC Power Supply Unit



Service power supply for external devices such as sensors (24 V).





#### Specifications

Item			Specification		
Rated output			15 W		
Output voltage			24 V		
Output current			600 mA		
Efficiency			75% min. (at rated output)		
Input conditions	Rated voltage		100 to 240 V AC		
	Allowable voltage rai	nge	85 to 264 V AC		
	Frequency		47 to 63 Hz		
	Current	100 V	0.4 A		
		200 V	0.2 A		
	Leakage current	100 V	0.5 mA max. (at rated output)		
		200 V	1 mA max. (at rated output)		
	Inrush current	100 V	15 A max. (at 25°C cold start)		
		200 V	30 A max. (at 25°C cold start)		
Output	Output voltage accur	acy	10%/-15% (including input, load, and temperature fluctuations)		
characteristics	Minimum output curr	ent	30 mA		
	Ripple noise voltage		2% (p-p) max.		
	Input fluctuation		0.75% max.		
	Load fluctuation		4% max.		
	Temperature fluctuat	ion	0.05%/°C max.		
	Startup time		300 ms max. (at input voltage of 100 V AC or 200 V AC and the rated output)		
	Output hold time		10 ms (at input voltage of 100 V AC or 200 V AC and the rated output)		
Overcurrent protection			Self-resetting, operates at 105% to 335% of the rated current, suspended and independent operation		
Overvoltage protection			None		
Ambient operating ter	mperature		0° to 55°C		
Ambient storage temp	perature		-20° to 70°C (no condensation or icing)		
Ambient operating hu	midity		10% to 90% (no condensation)		
Dielectric strength			2,000 V for 1 min between all inputs and GR Leakage current: 10 mA 3,000 V for 1 min between all inputs and all outputs Leakage current: 10 mA 1,000 V for 1 min between all outputs and GR Leakage current: 10 mA		
Insulation resistance			100 $M\Omega$ min. at 500 V DC between all outputs and any input, and between all outputs and GR		
Vibration resistance			10 to 57 Hz, amplitude, 57 to 150 Hz, acceleration: $9.8 \text{ m/s}^2$ in X, Y, and $\overline{Z}$ directions for 80 minutes according (Time coefficient: 8 minutes × coefficient factor 10 = total time 80 min.)		
Shock resistance			147 m/s <sup>2</sup> 3 times each in X, Y, and Z directions		
Noise terminal voltage			FCC class A		
Weight			250 g max.		

100

# Analog I/O Unit

- Up to four CPM2C-MAD11 Analog I/O Units can be connected to the CPM2C. Each Unit provides 2 analog inputs and 1 analog output, i.e., up to 8 analog inputs and 4 analog outputs can be supported by one CPM2C.
- Example Application: Packaging Machines



#### Specifications

-						
Item		Voltage I/O	Current I/O			
Analog	Number of inputs	2 (allocated 2 words)				
inputs	Input signal ranges	0 to 5 V, 1 to 5 V, 0 to 10 V, -10 to 10 V	0 to 20 mA, 4 to 20 mA			
	Maximum rated input	±15 V	±30 mA			
	External input impedance	1 MΩ min.	Approx. 250 Ω			
	Resolution	1/6,000 (full scale)				
	Overall precision	25° C:±0.3% of full scale	25° C:±0.4% of full scale			
		0 to 55° C:±0.6% of full scale	0 to 55° C:±0.8% of full scale			
	Converted A/D data	Binary data (4-digit hexadecimal) -10 to 10 V: F448 to 0BB8 Hex full scale Other:0000 to 1770 Hex full scale				
	Averaging	Supported (set for each input with DIP switch)				
	Disconnected line detection	Supported				
Analog	Number of outputs	1 (allocated 1 word)				
output	Output signal ranges	1 to 5 V, 0 to 10 V, -10 to 10 V	0 to 20 mA, 4 to 20 mA			
	External output allowed load resistance	1 kΩ min.	600 Ω max.			
	External output impedance	0.5 Ω max.				
	Resolution	1/6,000 (full scale)	·			
	Overall precision	25° C:±0.4% of full scale				
		0 to 55° C:±0.8% of full scale	0 to 55° C:±0.8% of full scale			
	D/A data setting	Binary data (4-digit hexadecimal) -10 to 10 V: F448 to 0BB8 Hex full scale Other:0000 to 1770 Hex full scale				
Conversi	on time	2 ms/point (6 ms/all analog I/O)				
Isolation method		Photocoupler isolation between analog I/O an isolated.)	Photocoupler isolation between analog I/O and internal circuits. (Individual analog I/O signals are not isolated.)			
Power co	nsumption	3.5 W				
Weight		200 g max.				

#### CPM2C-TS001/-TS101

## **Temperature Sensor Units**

- Up to four CPM2C-TS001/TS101 Temperature Sensor Units can be connected to the CPM2C. Each Unit provides 2 input points for temperature sensors, including thermocouples or temperature resistance thermometers, i.e., up to 8 temperature sensors can be input to one CPM2C.
- Application Examples: Foodstuff Equipment and Packaging Machines

#### Specifications

#### General

Item	CDM2C-TS001	CPM2C-TS101			
nem	CFM2C-13001	CFW2C-13101			
Temperature sensor	Thermocouple	Temperature resistance thermometer			
Input types	or J selectable (The same input type must be used for all inputs.) Pt100, JPt1100 selectable (The same input type must all inputs.)				
Number of inputs	2 (2 words allocated)				
Accuracy	$\pm 0.5\%$ or $\pm 2^\circ C$ of the stored value whichever is larger $\pm 1$ digit max. (see note)	<ul> <li>t. ±0.5% or ±1°C of the stored value whichever is larger (see not 1 digit max.</li> </ul>			
Conversion cycle	250 ms/2 inputs				
Converted temperature data	Binary data (4-digit hexadecimal)				
Isolation method	Photocoupler isolation between input signals				
Power consumption	1.5 W				
Weight	200 g max.				

Note: Accuracy for K thermocouples at temperatures less than  $-100^{\circ}$  C:  $\pm 4^{\circ}$  C  $\pm 1$  digit max.

#### Input Temperature Ranges for CPM2C-TS001

The input type is selected with a rotary switch. The ranges for each of the input types are shown in the following table.

Item	Range in ° C	Range in ° F
К	-200 to 1,300	-300 to 2,300
	0.0 to 500.0	0.0 to 900.0
J	-100 to 850	-100 to 1,500
	0.0 to 400.0	0.0 to 750.0

#### Input Temperature Ranges for CPM2C-TS101

The input type is selected with a rotary switch. The ranges for each of the input types are shown in the following table.

Item	Range in ° C	Range in ° F
Pt100	-200.0 to 650.0	-300 to 1,200.0
JPt100	-200.0 to 650.0	-300 to 1,200.0

Programmable Controllers

# Simple Communications Unit

Easy initial settings enable data exchange between the CPM2C and components.

# <complex-block>

#### **Connectable Devices**

#### A Wide Range of Devices Supporting CompoWay/F or SYSWAY Communications

Classification	Product	Model	SYSWAY		CompoWay/F	Remarks
				Segments	-	
Controllers	Temperature Controllers	E5GN	Yes	1	Yes	
		E5CN	Yes	1	Yes	
		E5EN	Yes	1	Yes	
		E5AN	Yes	1	Yes	
	Modular Temperature Controller	E5ZN	No		Yes	
	Digital Controllers	E5CK	Yes	1	No	
		E5EK	Yes	1	No	
		E5AK	Yes	1	No	
	Digital Controllers for control valves	E5EK	Yes	1	No	Valve system com- munications not sup- ported.
		E5AK	Yes	1	No	
	Digital Controller, basic type	E5CK-T	No		No	
		E5EK-T	No		No	
		E5AK-T	No		No	
	Digital Controllers for control valves,	E5EK-T	No		No	
	programmable	E5AK-T	No		No	
	Temperature Controllers	E5EJ	Yes	1	No	
		E5AJ	Yes	1	No	
	Fuzzy Temperature Controller	E5AF	Yes	1	No	
Timers	Electronic Timer/Counter	H8GN	No		Yes	

Classification	Product	Model	SYSWAY		CompoWay/F	Remarks
				Segments		
Digital Panels	Digital Panel Meter	K3GN	No		Yes	
	Process Meter	K3NX	Yes	2	Limited	Some commands
	Weighing Meter	K3NV	Yes	2	Limited	cannot be used with some models (op- tions). Only the Com- poWay/F variable area can be read.
	Frequency/Rate Meter	K3NR	Yes	2	Limited	
	Period Meter	K3NP	Yes	2	Limited	
	Up/Down Counter Meter	K3NC	Yes	2	Limited	
	Temperature Meter	K3NH	Yes	2	Limited	
	Intelligent Signal Processor	КЗТЅ	Yes	2	No	SYSWAY communi- cations only (See note 2.)

Limited: Connection possible for limited functions.

Note: 1. SYSWAY segment 1 and SYSWAY segment 2 can be combined.

2. When a K3TS is connected, connect the other components via SYSWAY as well.

#### **Component Parameters Supported for Communications**

The communications protocol for components can be set in the CPM2C's DM Area to CompoWay/F or SYSWAY. The data that can be read and written depends on the protocol that is set.

#### CompoWay/F

Reading and writing is possible for all component data (except for some Digital Panel Meters). The amount of data that can be read/written in one operation per component is limited to 12 data items for reading and 12 data items for writing. Reading and writing is enabled by setting the address for each parameter in DM.

#### **SYSWAY**

Reading and writing is possible for the data shown in the following table.

Segment	Read/write	Item	Command group				
			1	2	3	4	5
1: Controllers	Read	Present temperature	Yes	Yes	Yes	Yes	Yes
		Status	Yes	Yes	Yes	Yes	Yes
		Temperature set value	Yes	Yes	Yes	Yes	Yes
		Alarm 1 set value			Yes	Yes	Yes
		Alarm 2 set value			Yes	Yes	Yes
		Proportional band				Yes	Yes
		Integral time				Yes	Yes
		Derivative time				Yes	Yes
		Heater current					Yes
		Heater current status				es Yes Yes es Yes Yes es Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes es Yes Yes es Yes Yes es Yes Yes es Yes Yes es Yes Yes Yes Yes	Yes
	Write	Temperature set value	Yes	Yes	Yes	Yes	Yes
		Operation command		Yes	Yes	Yes	Yes
		Alarm 1 set value			Yes	Yes	Yes
		Alarm 2 set value			Yes	Yes	Yes
		Proportional band				Yes	Yes
		Integral time				Yes	Yes
		Derivative time				Yes	Yes
		Heater burnout detection val	-				Yes
		ue					
2: Digital Meters	Read	Display value	Yes	Yes	Yes	Yes	Yes
		Display status	Yes	Yes	Yes	Yes	Yes
		Peak hold		Yes	Yes		Yes
		Peak hold status		Yes	Yes		Yes
		Bottom hold		Yes	Yes		Yes
		Bottom hold status		Yes	Yes		Yes
		HH comparison value				Yes	Yes
		H comparison value				Yes	Yes
		L comparison value				Yes	Yes
		LL comparison value				Yes	Yes
	Write	Operation command			Yes		Yes
		HH comparison value				Yes	Yes
		H comparison value				Yes	Yes
		L comparison value				Yes	Yes
		LL comparison value				Yes	Yes

The command groups for which reading or writing is performed are determined by settings in the DM area.

#### Specifications

#### General

•

Item		Specification
Applicable PLC		CPM2C
RS-485/422 (top port)	Maximum number of connectable compo- nents	32
	Component connection port	Components connected to RS-485/422 terminal block. Connected to CPM2C CPU Unit via peripheral port (see diagram below).
	Baud rate for connection to components	9.6, 19.2, 38.4, or 57.6 kbps
	Baud rate for connection to CPU Unit	9.6 or 19.2 kbps
RS-232C (bottom port)	Signal conversion	Output from CPU Unit's RS-232C interface with no conversion
	Communications functions	One of the following: Host Link, no-protocol, 1:1 Link, 1:1 NT Link
Power supply		From CPU Unit
Power consumption		1 W
Weight		150 g max.

#### System Configuration

#### Internal



•

•

# RS-232C / RS-422 / RS-485 Adapter Units

#### **System Configuration**

#### **External Configuration**



#### **Internal Configuration**



Note: When using the CS1W-CN226/CN626 Connecting Cable for personal computer connection, turn ON the switch.



CPM2C-CIF11



Note: A Programming Console cannot be connected to the RS-422 port.

#### **Specifications**

#### General

Item		Specification	
		CPM2C-CIF01-V1	CPM2C-CIF11
Upper port	Signal con- version	Outputs signals from the CPU Unit's CMOS interface without conver- sion, or converts CMOS level (CPU Unit side) to RS-232C (connected device side).	Converts CMOS level (CPU Unit side) to RS-422 or RS-485 (connected device side). The externally connected device is insulated.
	Function	Host Link, peripheral bus, no-protocol, or Programming Console con- nections.	Host Link, peripheral bus, or no-protocol connections.
Lower	Signal con-	Outputs signals from the CPU Unit's CMOS interface without conver-	Outputs signals from the CPU Unit's CMOS interface without conver-
port	version	sion.	sion.
	Function	Host Link, no-protocol, 1:1 Link, or 1:1 NT Link connections.	Host Link, no-protocol, 1:1 Link, or 1:1 NT Link connections.
Power su	pply	Power supplied from CPU Unit.	
Current c	onsumption	0.3 A max. at 5 V	
Weight		150 g max.	

Note: Neither the CPM2C-CIF01-V1 nor the CPM2C-CIF11 can be used with any PLC other than the CPM2C. A CPM2C-CIF11 or another CPM2C-CIF01-V1 cannot be connected to the CPM2C if a CPM2C-CIF01-V1 is already connected to it.

#### CPM2C-SRT21

## **CompoBus/S I/O Link Unit**

#### I/O Link Unit for CPM2C

- Operates as a Slave of the CompoBus/S Master Unit.
- Exchanges eight inputs and eight outputs with the Master.



#### **Ordering Information**

#### **CompoBus I/O Link Unit**

Name	Specifications	Model
CompoBus/S I/O Link Unit	Number of points for I/O links: 8 inputs and 8 outputs	CPM2C-SRT21

#### **Application Examples**

#### **Conveyor Line**

Processing speed can be increased and system setup labor reduced by creating a distributed system with a CPM2C at each conveyor.



#### Specifications

Item	CPM2C-SRT21
Master/Slave	CompoBus/S Slave
Number of I/O points	8 inputs and 8 outputs
Number of words occupied in CPM2C's I/O memory	1 input word and 1 output word (allocated in the same way as for other Expansion Units)
Node address setting	DIP switch
Power consumption	1 W
Weight	150 g

Note: For details of CPM2C PLCs, refer to the CPM2C catalog (Cat. No. P049).

## **CPM2C General Information**

#### System Configuration



Unit Model number Inputs Outputs CPU Unit CPM2C-20CDTC-D IR 000 IR 010 Expansion I/O Unit CPM2C-24EDTC IR 001 IR 011 Expansion Output Unit CPM2C-16ETC IR 012 Analog I/O Unit CPM2C-MAD11 IR 002 IR 013 IR 003 Temperature Sensor Unit CPM2C-TS001 IR 004 IR 005 CompoBus/S I/O Link Unit CPM2C-SRT21 IR 006 IR 014

#### CPU Unit

#### Number of Connectable Units

Up to 5 Units can be connected to a CPM2C CPU Unit except for the CPM2C-S1 OC-DRT Programmable Slave and CPM2C-S1 OC CompoBus/S Master Unit, which are limited to 3 Units. The number of words that can be used by Expansion Units, however, is limited, and these limits must not be exceeded.

Model	Max. No. of Units	Applicable I/O words
CPU Units except those listed below	5	Inputs: IR 001 to IR 009 (CPU Unit uses IR 000) Outputs: IR 011 to IR 019 (CPU Unit uses IR 010)
CPU Units with 32 I/O points (CMP2C-32CDT□C-D)	5	Inputs: IR 002 to IR 009 (CPU Unit uses IR 000 and IR 001) Outputs: IR 012 to IR 019 (CPU Unit uses IR 010 and IR 011)
CPM2C-S1 OC-DRT Pro- grammable Slave and CPM2C-S1 OC CompoBus/ S Master Unit	3	Inputs: IR 001 to IR 009 (CPU Unit uses IR 000) Outputs: IR 011 to IR 019 (CPU Unit uses IR 010)

#### Number of I/O Words Allocated to Expansion Units

Unit	Model number	Input words	Output words
Expansion Input Units	CPM2C-8ED	1	
	CPM2C-16ED	1	
Expansion Output Units	CPM2C-8ER		1
	CPM2C-8ET(1)		1
	CPM2C-16ET(1)		1
Expansion I/O Units	CPM2C-10EDR	1	1
	CPM2C-24EDT(1)	1	1
Expansion I/O Units	CPM2C-20EDR	1	1
	CPM2C-32EDT(1)	1	1
Analog I/O Unit	CPM2C-MAD11	2	1
Temperature Sensor Units	CPM2C-TS001	2	
	CPM2C-TS101	2	
CompoBus/S I/O Link Unit	CPM2C-SRT21	1	1

Note: 1. An AC Power Supply Unit can be used for the CPU Units.

2. The CPM2C-CIF01-V1/CIF11/CIF21 can be used with the CPU Units

#### **CPM2C** Power Consumption

Use the following power consumption tables to calculate the total power capacity required when using a CPM2C PC. The rated output for the CPM2C-PA201 AC Power Supply Unit is 15 W. Any surplus power not required for the PC directly can be used as service power supply for sensors and other devices.

#### **CPM2C** Power Supplies

CPU Unit	Power consumption (W)
CPM2C-10C(1)DR-D	4
CPM2C-20C(1)DR-D	4
CPM2C-S1D0C-DRT1	3
CPM2C-S1D0C	3
CPM2C-10C(1)DT(1)□-D	3
CPM2C-20C(1)DT(1)□-D	3
CPM2C-32C(1)DT(1)□-D	3

The power consumption of the CPU Unit includes power for the Programming Consoles and Adapter Units.

Add the following consumptions when using Expansion I/O Units.

Expansion I/O Unit	Power consumption (W)
CPM2C-10EDR	1
CPM2C-20EDR	2
CPM2C-24EDT(1)	1
CPM2C-32EDT(1)	1
CPM2C-MAD11	3.5
CPM2C-SRT21	1
CPM2C-TS001/002	1.5
CPM2C-8ED /16ED	1
CPM2C-8ER	2
CPM2C-8ET(1)□/16ET(1)□	1

## Dimensions

#### **CPU Units**

CPU Units with Relay Outputs (CPM2C-10C(1)DR-D, CPM2C-20C(1)DR-D)



CPU Units with Relay Outputs (CPM2C-S1□0C)





Note: All dimensions are in mm.

CPU Units with Transistor Outputs (CPM2C-10C(1)DT(1)C-D, CPM2C-10C(1)DT(1)M-D, CPM2C-20C(1)DT(1)C-D, CPM2C-20C(1)DT(1)M-D, CPM2C-32CDT(1)C-D, CPM2C-32CDT(1)M-D)



CPU Units with Transistor Outputs (CPM2C-S1□0C-DRT)



#### I/O Expansion Units

Units with Relay Outputs

(CPM2C-8ER, CPM2C-10EDR, CPM2C-20EDR)





**Units with Transistor Outputs** 

(CPM2C-24EDT(1)C, CPM2C-24EDT(1)M, CPM2C-32EDT(1)C, CPM2C-32EDT(1)M)



65

Units with Transistor Outputs Only and Units with Inputs Only (CPM2C-8ED(1), CPM2C-8ET(1)C, CPM2C-8ET(1)M, CPM2C-16ED(1), CPM2C-16ET(1)C, CPM2C-16ET(1)M)

65



Note: All dimensions are in mm.

AC Power Supply Unit (CPM2C-PA201)





Simple Communications Unit (CPM2C-CIF21)

90



65

**Temperature Sensor Unit** 

90

(CPM2C-TS001, CPM2C-TS101)

65

#### Peripheral/RS-232C Adapter Unit (CPM2C-CIF01-V1)



RS-422/RS-485/RS-232C Adapter Unit (CPM2C-CIF11)



CompoBus/S I/O Link Unit (CPM2C-SRT21)



Programmable Controllers

**()** 

## **CPM2C Ordering Information**

#### International Standards

The products shown in the attached tables are those that conform to the UL, CSA, cULus, cUL, NK, Lloyd's Register, and EC Directives as of September 2003.

(U: UL, C: CSA, UC: cULus, CU: cUL, N: NK, L: Lloyd, CE: EC Directives) Please contact OMRON representative for application conditions.

#### **CPM2C CPU Units**

CPU Unit		Inputs	Outputs	Internal clock	Model	Standards	
Units with 10 I/O points	I/O terminal	6 inputs	4 relay outputs		CPM2C-10CDR-D	U, C, CE	
	block	(24 V DC)		Yes	CPM2C-10C1DR-D	U, C, CE	
Inputs: 6							
Unite with 10 1/O points	0 Eulitou con	6 inputo	4 einking transister outpute				
onits with to i/O points	2 Fujiisu con-	(24  V  DC)	4 sinking transistor outputs			U, C, CE	
Inputs: 6	11001013	(24 0 00)	4 coursing transistor outputs	res	CPM2C-TUCTUTC-D	U, C, CE	
Outputs: 4			4 sourcing transistor outputs	 Voo	CPM2C-10CDTTC-D	U, C, CE	
	0.0411	C immute		res		U, C, CE	
	2 MIL connec-	(24  V  DC)	4 sinking transistor outputs			U, C, CE	
		4 sinking transistor outputs	Yes		-		
			4 sourcing transistor outputs		CPM2C-10CDT1M-D	-	
		10.1	4 sourcing transistor outputs	Yes	CPM2C-10C1D11M-D		
Units with 20 I/O points	2 terminal	12 inputs	8 relays		CPM2C-20CDR-D	U, C, CE	
Innute: 12	DIOCKS	(24 V DC)	(24 V DC)		Yes	CPM2C-20C1DR-D	
Outputs: 8 necto	2 Fujitsu con-		8 sinking transistor outputs		CPM2C-20CDTC-D	U, C, CE	
	nectors			Yes	CPM2C-20C1DTC-D	U, C, CE	
			8 sourcing transistor outputs		CPM2C-20CDT1C-D	U, C, CE	
				Yes	CPM2C-20C1DT1C-D	U, C, CE	
	2 MIL connec-	12 inputs	8 sinking transistor outputs		CPM2C-20CDTM-D	U, C, CE	
	tors	(24 V DC)	8 sinking transistor outputs	Yes	CPM2C-20C1DTM-D		
			8 sourcing transistor outputs		CPM2C-20CDT1M-D		
			8 sourcing transistor outputs	Yes	CPM2C-20C1DT1M-D		
Units with 32 I/O points	2 Fujitsu con-	16 inputs	16 sinking transistor outputs		CPM2C-32CDTC-D	U, C, CE	
	nectors	(24 V DC)	16 sourcing transistor outputs		CPM2C-32CDT1C-D		
Inputs: 16 Outpute: 16	2 MIL connec-	IL connec- 16 inputs	16 sinking transistor outputs		CPM2C-32CDTM-D	U, C, CE	
Oulpuis. 10	tors	(24 V DC)	16 sourcing transistor outputs		CPM2C-32CDT1M-D		
Programmable Slave with De-	1 Fujitsu con-	6 inputs	4 sinking transistor outputs	Yes	CPM2C-S100C-DRT	U, C, CE	
viceNet slave and CompoBus/S	nector	(24 V DC)	4 sourcing transistor outputs	Yes	CPM2C-S110C-DRT	1	
Master, 10 I/O points							
Inpute: 6							
Outputs: 4							
Units with CompoBus/S Master.	1 Fuiitsu con-	6 inputs	4 sinking transistor outputs	Yes	CPM2C-S100C	U. C. CE	
10 I/O points	nector	(24 V DC)	4 sourcing transistor outputs	Yes	CPM2C-S110C	-, -, -	
Inputs: 6							
Outputs: 4							

#### **Power Supply Unit**

Unit	Input	Output	Model	Standards
AC Power Supply Unit	100 to 240 V AC	24 V DC/600 mA	CPM2C-PA201	U, C, CE

#### **Expansion I/O Units**

Expansion I/O Unit		Inputs	Outputs	Model	Standards
Units with inputs only	1 Fujitsu connector	8 inputs (24 V DC)		CPM2C-8EDC	U, C, CE
Inputs: 8	1 MIL connector	8 inputs (24 V DC)		CPM2C-8EDM	U, C, CE
Units with inputs only	1Fujitsu connector	16 inputs (24 V DC)		CPM2C-16EDC	U, C, CE
Inputs: 16	1 MIL connector	16 inputs (24 V DC)		CPM2C-16EDM	U, C, CE
Units with relay outputs only	I/O terminal block		8 relay outputs	CPM2C-8ER	U, C, CE
	1 Fujitsu connector		8 sinking transistor outputs	CPM2C-8ETC	U, C, CE
Outputs: 8			8 sourcing transistor outputs	CPM2C-8ET1C	U, C, CE
	1 MIL connector		8 sinking transistor outputs	CPM2C-8ETM	U, C, CE
			8 sourcing transistor outputs	CPM2C-8ET1M	U, C, CE
Units with transistor outputs only	1 Fujitsu connector		16 sinking transistor outputs	CPM2C-16ETC	U, C, CE
			16 sourcing transistor outputs	CPM2C-16ET1C	U, C, CE
Outputs: 8	1 MIL connector		16 sinking transistor outputs	CPM2C-16ETM	U, C, CE
			16 sourcing transistor outputs	CPM2C-16ET1M	U, C, CE
Units with 10 I/O points	1 I/O terminal block	6 inputs (24 V DC)	4 relay outputs	CPM2C-10EDR	U, C, CE
Inputs: 6 Outputs: 4					

Expansion I/O Unit		Inputs	Outputs	Model	Standards
Units with 20 I/O points	1 I/O terminal block	12 inputs (24 V DC)	8 relay outputs	CPM2C-20EDR	U, C, CE
Inputs: 12 Outputs: 8					
Units with 24 I/O points	2 Fujitsu connectors	16 inputs (24 V DC)	8 sinking transistor outputs	CPM2C-24EDTC	U, C, CE
			8 sourcing transistor outputs	CPM2C-24EDT1	U, C, CE
Inputs: 16	2 MIL connectors	16 inputs (24 V DC)	8 sinking transistor outputs	CPM2C-24EDTM	U, C, CE
Outputs: 8			8 sourcing transistor outputs	CPM2C-24EDT1M	U, C, CE
Units with 32 I/O points	2 Fujitsu connectors	16 inputs (24 V DC)	16 sinking transistor outputs	CPM2C-32EDTC	U, C, CE
			16 sourcing transistor outputs	CPM2C-32EDT1C	U, C, CE
Inputs: 16	2 MIL connectors	16 inputs (24 V DC)	16 sinking transistor outputs	CPM2C-32EDTM	U, C, CE
			16 sourcing transistor outputs	CPM2C-32EDT1M	U, C, CE

#### Analog I/O Units

Product	Specifications	Model	Standards
Analog I/O Unit	2 analog inputs and 1 analog output	CPM2C-MAD11	CE

#### Temperature Sensor Unit

Product	Specifications	Model	Standards
Temperature Sensor Unit	2 inputs for thermocouples	CPM2C-TS001	CE
	2 inputs for temperature resistance thermometers	CPM2C-TS101	

#### CompoBus/S I/O Link Units

Product	Specifications	Model	Standards
CompoBus/S I/O Link Units	I/O Links: 8 inputs, 8 outputs	CPM2C-SRT21	CE

#### I/O Connectors

(Connectors are not provided with CPU Unit. Select the appropriate ones from the following table. One CPU Unit requires two sets of Connectors.)

#### **Fujitsu Connectors**

Connection method	From OMRON		From Fujitsu
Soldered	C500-CE241	1 set	FCN-361J024-AUConnector FCN-360C024-J2Connector Cover
Crimped	C500-CE242		FCN-363J024Housing FCN-363J-AUContacts FCN-360C024-J2Connector Cover
Pressure-welded	C500-CE243		FCN-367J024-AU/F

#### **MIL Connectors**

Connection method	Model	Number in box	Specifications
Pressure-welded	XG4M-2030-T	100	Poles: 20

Note: Any commercially available 20-pole (IDC) connectors, according to MIL-C-83503, DIN 41651 or IEC 60603-1 specification, can be used.

#### **Programming Consoles and Cables**

Product	Model	Standards	
Programming Console (2-m cable attached)	CQM1-PRO01-E	U, C, CE, N	
Programming Console (Requires separate cable. See below.)	C200H-PRO27-E	U, C, N, CE	
Connecting Cable for connecting CQM1-PRO01-E to a peripheral port		CS1W-CN114	CE
Connecting Cable for C200H-PRO27-E	2-m cable	C200H-CN222	N
	4-m cable	C200H-CN422	
Connecting Cable for C200H-PRO27-E allowing direct connection to the CPM2C	2-m cable	CS1W-CN224	CE
CPU Unit	6-m cable	CS1W-CN624	CE

#### Support Software

Product	Functions	Model	Standards
CX-One	Omron's integrated software for programming and configuration of all control system components, in- cluding PLCs, HMI, drives, temperature controllers and advanced sensors.	CX-ONE-AL□□C-E <sup>*1</sup>	

<sup>\*1</sup> □□ = Number of licenses (01, 03, 10)

Product	Model	Standards
Expansion Memory Unit	CPM1-EMU01-V1	
EEPROM (256 K)	EEROM-JD	

 $( \bullet )$ 

#### Peripheral Port Adapters and Connecting Cables

Description		Computer port	Length	Model	Standards
Personal Com-		For a D-sub 9-pin port	2 m	CS1W-CN226	CE
puter Connect-			6 m	CS1W-CN626	CE
ing Cables			3.3 m	CQM1-CIF02	U, C, N, L, CE
	Peripheral Port Cable		0.05 m	CS1W-CN114	CE

#### **RS-232C Cables**

Product	Computer port	Specifications	Length	Model	Standards
RS-232C Cable	For a D-sub 9-pin port		2 m	XW2Z-200S-V	
			5 m	XW2Z-500S-V	
		Can be used with a periph-	2 m	XW2Z-200S-CV	
		eral bus or Host Link. Uses connector that prevents ESD (electrostatic dis- charge.)	5 m	XW2Z-500S-CV	

#### **Communications Port Connecting Cables**

Description	Cable length	Model	Standards
Converts to a Peripheral port and RS-232C port.	0.1 m (about 4")	CPM2C-CN111	CE
Converts to a Peripheral port only.	0.05 m (about 2")	CS1W-CN114	CE
Converts to an RS-232C port only.	0.1 m (about 4")	CS1W-CN118	CE

#### Simple Communications Unit

Product	Specifications	Model	Standards
Simple Communications Unit	RS-485/RS-232C ports for connection to components	CPM2C-CIF21	U, C, CE

#### Adapters

Product	Function		Model	Standards
Peripheral/RS 232C Adapter Unit	Peripheral po	ort level conversion	CPM2C-CIF01-V1	
RS-422/RS-485/RS-232C Adapter Unit			CPM2C-CIF11	U, C, CE
Link Adapter	RS-232C to RS-422A	For personal computer connection (Can also be connected to the CPM2A.)	3G2A9-AL004-E	
RS-422A Adapter	conversion	For CPM2A connection (Can also be connected to a personal computer, but re- quires an external 5-V power supply.)	NT-AL001	

#### Battery

Product	Function	Model	Standards
Battery	Backs up memory in the CPM2C CPU Unit.	CPM2C-BAT01	CE

#### I/O Terminal Blocks and Connecting Cables

Product	Description	No. of inputs/ outputs	Model	Comments
I/O Terminal Blocks	Slim type with M3 slotted screw ter- minal block	20	XW2D-20G6	For more information refer to "Wiring Systems" on
	Flat cable connector with M2.5 slot- ted screw terminal block	20	XW2B-20G4	page 384
Common terminals (3-tier inputs)			XW2E-20G5-IN16	
Common terminals (2-tier outputs)			XW2C-20G6-IO16	

Product Cable length			Model	Comments
Special Connecting Cable With Fujitsu connector	With Fujitsu connector	0.5 m	XW2Z-050A	For more information refer
	1 m	XW2Z-100A	to "Wiring Systems" on	
		1.5 m	XW2Z-150A	page 384
		2 m	XW2Z-200A	
		3 m	XW2Z-300A	
		5 m	XW2Z-500A	
	With MIL connector	2.5 m	G79-025C	
		5 m	G79-050C	

Relay I/O Terminals and	Connecting	Cables
-------------------------	------------	--------

Product	Mounted relay	I/O points	Processing	Rated voltage	Model	Standards	Output	Fujitsu con- nector	MIL connector														
Relay I/O terminals	G7TC	16 inputs	NPN (- common)	24 V DC	G7TC-ID16			G79-□00C	G79-O□00C														
				100 (110) V AC	G7TC-IA16	1		G79-□00C	G79-O□00C														
	20	200 (220) V AC				G79-□00C	G79-O□00C																
		16 outputs	NPN (+ common, sinking output)	24 V DC	G7TC-OC16	]	Sink	G79-□00C	G79-O□00C														
		16 outputs	PNP (– common, sourcing output)	24 V DC	G7TC-OC16-1	1	Source	G79-□00C	G79-O⊡00C														
		8 outputs	NPN (+ common, sinking output)	24 V DC	G7TC-OC08		Sink	G79-□00C	G79-O⊡00C														
	G6D	16 outputs	NPN (+ common, sinking output)	24 V DC	G70D-SOC16		Sink	G79-□00C	G79-O⊡00C														
			PNP (– common, sourcing output)	24 V DC	G70D-SOC16-1		Source		G79-I□00C														
	G3DZ (Power MOS FET	SFET	NPN (+ common, sinking output)	24 V DC	G70D-FOM16		Sink	G79-□00C	G79-O□00C														
	Relay)			1					1								PNP (– common, sourcing output)	24 V DC	G70D-FOM16-1		Source		G79-I□00C
	G6D		NPN (+ common, sinking output)	24 V DC	G70D-VSOC16		Sink	G79-□00C	G79-O□00C														
	G3DZ (Power MOS FET Relay)		FET	G3DZ (Power MOS FET Relay)	NPN (+ common, sinking output)	24 V DC	G70D-VFOM16		Sink	G79-□00C	G79-O⊟00C												
	(Sold separately) G2R		NPN (+ common, sinking output)	24 V DC	G70A-ZOC16-3		Sink	G79-⊡00C	G79-O⊡00C														
	G3R G3RN H3RN		PNP (– common, sourcing output)	]	G70A-ZOC16-4		Source		G79-I□00C														

Product	Cable length		Model	Comments
Connecting Cable with connector (1:1)	With Fujitsu connector	1 m	G79-100C	For more information refer
		1.5 m	G79-150C	to "Wiring Systems" on
		2 m	G79-200C	page 384
		3 m	G79-300C	
		5 m	G79-500C	7
	With MIL connector	0.25 m	G79-O25C	7
		5 m	G79-O50C	
		0.25 m	G79-I25C	
		0.5 m	G79-I50C	

#### **DC Power Supplies**

Product	Output voltage/current	Input voltage	Model	Standards
DC Power Supply (3 W)	24 V DC, 0.13 A	85 V AC to 264 V AC	S82K-00324	U, C
DC Power Supply (7.5 W)	24 V DC, 0.3 A	85 V AC to 264 V AC	S82K-00724	U, C
DC Power Supply (15 W)	24 V DC, 0.6 A	85 V AC to 264 V AC	S82K-01524	U, C
DC Power Supply (30 W)	24 V DC, 1.3 A	85 V AC to 264 V AC	S82K-03024	U, C
DC Power Supply (50 W)	24 V DC, 2.1 A	85 V AC to 264 V AC	S82K-05024	U, C

Programmable Controllers

ALL DIMENSIONS SHOWN ARE IN MILLIMETERS. To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

Cat. No. P06E-EN-03A

In the interest of product improvement, specifications are subject to change without notice.

#### **Compact PLC series**

## CPM2A/CPM2B/CPM2C

#### Advanced functions and high performance in a compact shape. Ideal for automation of packaging and conveyor systems. Provides increased performance and added value to any compact machine.

#### **High Performance**

#### Versatile Functions for More Advanced Systems

- · High-speed counter inputs for position sensing or object counting.
- Synchronous control simplifies timing adjustment.
- · High-speed processing with an interrupt function for immediate response.
- · Supports both stand-alone and distributed control.

#### Compact block-type PLCs SYSMAC CPM2A

#### **AC Power Supply**





	Nº CO	1000	and the second	CAURY-
19:14 19:	******	172-042	Longer and	ALC: NO
0840	SYSMAC CPM2A			
10		STAR & ACM		
-114	TENNE		Barris	

# 

#### **DC Power Supply**









#### **Highly Economical**

The combination of advanced functions and high performance in an economical PLC range will add value to your machines.

#### Compact

#### Fits into your available space

A choice of three different compact form factors means you can more easily fit the functions you need in the space you have available in your control cabinet or machine.

#### **Modular Board PLCs**

#### SYSMAC CPM2B

Proven CPM2 technology to fit in the tightest spaces. And if the standard models do not fit, we'll make the exact shape and I/O combination you need.



**Compact slim-line PLCs** SYSMAC CPM2C

10 I/O Points

20 I/O Points

**Communication Adapter** 

32 I/O Points







Expansion I/O: Digital, Analog







**Temperature Sensor** 



#### CPM2A/CPM2B/CPM2C

wnloaded from Elcodis.com electronic components distributor





#### A full line-up to fit your needs

A wide range of models is available to achieve the machine or line controller that you require. Select from 16 CPU types, for AC power, DC power, relay output, transistor output, etc. Match the power supply, output, number of I/O points, and size to your particular needs. Expansion I/O Units can also be easily added to increase I/O points.

#### Removable Terminal Blocks for Easy Maintenance

Removable terminal blocks\* simplify installation, troubleshooting and machine maintenence. (\*CPU Unit only)



#### Expandable up to 140 I/O Points

Even with its ultracompact size, the CPM2C features a wide range of models for efficient machine control. Ten CPU types, all with DC power supply, allow selection of relay output or transistor output, terminal block or connector wiring, clock function, and other functions. Choose the output type, number of I/O points and other features to meet your needs. Expansion I/O Units (8, 10, 16, or 24 I/O points) are also available to provide control for a maximum of 140 I/O points.

#### Easy-to-Read LED Display

The LED display on the upper part of the CPM2C is easy to read, even when cables are connected.



#### **Built-in RS-232C Port**

The built-in RS-232C port enables connection with a variety of equipment. The communication port can be used for configuration, maintenance, troubleshooting, visualisation or general-purpose serial communication.

#### **PT Connection**

Compatible with the OMRON Programmable Terminal's Programming Console functions. Maintenance is simplified with the on-screen programming operations.



#### Host Link

Host Link allows reading and writing of the I/O memory and operation modes of the CPM2A or CPM2C by a personal computer. The following RS422/RS-232C Communications Adapters also provide 1:n communications.

CPM2A: CPM1-CIF11 CPM2C: CPM2C-CIF11



#### **One-to-one Link**

A 1:1 PLC Link connection can be established with another CPM2C, or a CQM1(H), CPM1, CPM1A, CPM2A, SRM1(-V2), C200HS, or C200HX/HG/HE PLC.

#### Windows-based Programming Support

The Windows-based CX-One Support Software is available for programming all OMRON PLC's, including the CPM2A or CPM2C. Being able to program in the Windows environment reduces programming steps, and gives you access to a large number of display monitor and debugging functions. It also means that you can use existing Windows applications to help with CPM2A or CPM2C programming, which adds up to a highly advanced programming environment.

## **CPM2-series Features**

#### The illustrations in this section show CPM2A PLCs, but the same functions are available in CPM2B/CPM2C PLCs unless otherwise stated.

#### Interrupts

The CPM2-series PLCs provide the following kinds of interrupt processing.

#### **Interrupt Inputs**

Interrupt programs are executed when inputs to the CPU Unit's built-in input points (00003 to 00006) are turned from OFF to ON. Interrupt subroutine numbers 000 to 003 are allocated to input points 00003 to 00006.

#### Interval Timer Interrupts

Interval timer interrupt programs are executed with a precision of 0.1 ms. Interrupt subroutine numbers 000 to 049 are allocated by instructions.

#### **Count-up Interrupts**

Input signals to the CPU Unit's built-in input points (00003 to 00006) are counted at high speed (up to 2 kHz), and the normal program is stopped and an interrupt program is executed when the count reaches the SV. Interrupt subroutine numbers 000 to 003 are allocated to input points 00003 to 00006.

#### **Count-check Interrupts Using the High-speed Counter**

Pulse inputs to the CPU Unit's built-in input points (00000 to 00002) are counted at high speed (up to 20 kHz or 5 kHz), and an interrupt program is executed when the present value matches the target value or falls within a given range. Interrupt subroutine numbers 000 to 049 are allocated by instructions.

#### **Interval Timer Interrupts**

The CPM2 has one interval timer (precision: 0.1 ms) that can be set from 0.5 ms to 319,968 ms. There are two interrupt modes: the single-interrupt mode, in which a single interrupt is executed when the time is up, and the scheduled-interrupt mode, in which interrupts are executed at regular intervals.



Item	Single-interrupt mode	Scheduled-interrupt mode
Operation	Interrupt is executed once when time has elapsed.	Interrupts are executed at regular intervals.
Set time	0.5 to 319,968 ms (Unit: 0.1 ms)	
Interrupt response time	0.3 ms (from when time has elapsed until execution of interrupt program)	

#### **High-speed Counters**

The CPM2 CPU Unit has a built-in high-speed counter that can count input pulses at up to 20 kHz. When combined with the interrupt function, the high-speed counter can be used for target-value comparison or range comparison control that is unaffected by the cycle time.



Input	Response fre- quency	Input mode (count value)	Counter PV Storage	Control method
00000	5 kHz	Differential phase input mode (-8,388,608 to 8,388,607)	SR 248 and SR 249	Target value comparison
00001 00002	20 kHz	Pulse + direction input mode (-8,388,608 to 8,388,607) Up/down pulse input mode (-8,388,608 to 8,388,607) Increment mode (0 to 16,777,215)		interrupts Range comparison inter- rupts

#### Interrupt Inputs (Counter Mode)

The four built-in interrupt inputs in the CPM2 CPU Unit can be used in counter mode to count inputs of up to 2 kHz. These inputs can be used as either incrementing counters or decrementing counters and can trigger an interrupt (i.e., execute an interrupt subroutine) when the count matches the set value.



Input	Counter number	Set value location	Present value loca- tion	Response frequency	Input mode (count value)	Control method
00003	Counter 0	SR 240	SR 244	2 kHz	Incrementing counter (0000 to FFFF)	Count-up inter-
00004	Counter 1	SR 241	SR 245		Decrementing counter (0000 to FFFF)	rupts
00005	Counter 2	SR 242	SR 246			
00006	Counter 3	SR 243	SR 247			

Programmable Controllers

#### **Pulse Outputs**

The CPM2 has two pulse outputs. The PLC Setup can be set to use these outputs as two single-phase outputs without acceleration and deceleration, two variable duty-ratio pulse outputs, or pulse outputs with trapezoidal acceleration/deceleration (one pulse + direction output and one up/ down pulse output). The pulse output's PV coordinate system can also be specified in the PC Setup as either relative or absolute.



Item		Single-phase pulse out-	Variable duty-ratio pulse	Single-phase pulse output with trapezoidal acceleration/deceleration			
		put without accel/decel	output	Pulse + direction output		Up/down pulse output	
Controlling instruction(s)		PULS(65) and SPED(64)	PWM(—)	PULS(65) and ACC(—)			
Output	01000	Pulse output 0 (See note.)	Pulse output 0 (See note.)	Pulse output	Pulse output	Pulse output	CW pulse output
number	01001	Pulse output 1 (See note.)	Pulse output 1 (See note.)	0	Direction output	0	CCW pulse output
Output frequence	y range	10 Hz to 10 kHz	0.1 Hz to 999.9 Hz	10 Hz to 10 kH	Ηz	10 Hz to 10 kH	Ηz
	Pitch	10 Hz	0.1 Hz	10 Hz		10 Hz	
Duty ratio		50%	0 to 100%	50%		50%	

Note: With single-phase pulse outputs, pulse outputs 0 and 1 can each be output independently.

#### Synchronized Pulse Control

The CPM2's high-speed counter function can be combined with the pulse output function to generate an output pulse at a specified multiple of the input pulse frequency.



Item		Input mode					
		Phase differential input mode	Pulse + direction input mode	Up/down pulse input mode	Increment mode		
Input number 00000		A-phase input Count input		CW input	Count input		
	00001	B-phase input	Direction input	CCW input	See note 1.		
Input method		Phase differential quadruple input	Single-phase input	Single-phase input	Single-phase input		
Input frequency range		10 Hz to 500 Hz (accuracy ±1 Hz) 20 Hz to 1 kHz (accuracy ±1 Hz) 300 Hz to 20 kHz (accuracy ±25 Hz) (See note 2.)					
Output frequency range		10 Hz to 10 kHz (accuracy 10 Hz)					
Frequency ratio (scaling factor)		1 % to 1,000% (Can be specified in units of 1%.)					
Synchronized control cycle		10 ms					

Note: 1. Can be used as an ordinary input.

2. The accuracy is  $\pm 10$  Hz when the input frequency is 10 kHz or less.

#### **Quick-response Inputs**

The CPM2A/CPM2B CPU Units and CPM2C CPU Units with 20 I/O points have four inputs that can be used for quick-response inputs. The CPM2C CPU Units with 10 I/O points have two inputs that can be used for quick response inputs. These inputs are shared with interrupt inputs and 2-kHz high-speed counter inputs. Quick-response inputs are received into an internal buffer, so signals that change status within a cycle can be received.



Input number	Min. input signal
00003	50 μs
00004	
00005	
00006	

Inputs 00003 through 00006 can be used as interrupt inputs, 2-kHz high-speed counter inputs, or quick-response inputs. These inputs can be used as ordinary inputs if they are not used as interrupt inputs, 2-kHz high-speed counter inputs, or quick-response inputs. Inputs 00005 and 00006 cannot be used with the CPM2C CPU Unit with 10 I/O points.

#### Analog Controls (CPM2A Only)

The CPM2A CPU Unit has two analog controls that can be used for a wide range of timer and counter analog settings. As these controls are turned, values from 0 to 200 (BCD) are stored in the SR Area.

Control	Storage area	Set value (BCD)
Analog control 0	SR 250	0000 to 0200
Analog control 1	SR 251	0000 to 0200

#### **Clock Function**

The CPM2A and some CPM2B/2Cs have a built-in clock (accuracy: ±1 minute/month) that allows the date and time to be read from the ladder program. The time can be overwritten from a Programming Console or other Programming Device, but the CPM2A is also equipped with a 30-second Compensation Bit. The time will be rounded off to the nearest minute when this bit is turned ON, so the time can be set very accurately by turning ON this bit when the "time tone" is heard on the radio.

(The CPM2B/CPM2C CPU Units have models with the clock function and models without.)

1	5 8	7 0			
AR17	Hour	Minute			
AR18	Minute	Second		2 digits BCI	D each.
AR19	Date	Hour		the year are	e displayed.)
AR20	Year	Month		-	
AR21		Day of week		00 to 06: Su	nday to Saturday
	1				
	AR211	5 Clock Set	Bit		
	40011		- Dit		

AR2114 Clock Stop Bit AR2113 30-second Adjustment Bit

#### **Additional Timer Functions**

VERY HIGH-SPEED TIMER	Starts a very high-speed decrementing ON-delay timer with the specified timer number. The set value can be 0 to 9,999 ms.
(Units: 1 ms)	(Set in 1-ms units.)
LONG TIMER	Starts a long-term decrementing ON-delay timer with the specified timer number. The set value can be 0 to 9,999 s (when
(Units: 1 s or 10 s)	set in 1-s units) or 0 to 99,990 s (when set in 10-s units).

#### **NT Links**

The CPM2 can be connected to an OMRON PT (Programmable Terminal) in NT Link mode (1:1). A communications program is not required in the CPM2. The RS-232C port can be used for the NT Link.



#### Terms and Conditions of Sale

- Offer: Acceptance. These terms and conditions (these "Terms") are deemed part of all quotes, agreements, purchase orders, acknowledgments, price lists, catalogs, manuals, brochures and other documents, whether electronic or in writing, relating to the sale of products or services (collectively, the "<u>Products</u>") by Omron Electronics LLC and its subsidiary companies ("<u>Omron</u>"). Omron objects to any terms or conditions proposed in Buyer's purchase order or other
- documents which are inconsistent with, or in addition to these Terms. <u>Prices: Payment Terms.</u> All prices stated are current, subject to change with-out notice by Omron. Omron reserves the right to increase or decrease prices 2. on any unshipped portions of outstanding orders. Payments for Products are due net 30 days unless otherwise stated in the invoice.
- Discounts. Cash discounts, if any, will apply only on the net amount of invoices sent to Buyer after deducting transportation charges, taxes and duties, and will be allowed only if (i) the invoice is paid according to Omron's payment terms З.
- and (ii) Buyer has no past due amounts. Interest. Omron, at its option, may charge Buyer 1-1/2% interest per month or the maximum legal rate, whichever is less, on any balance not paid within the 4 stated terms
- Orders. Omron will accept no order less than \$200 net billing.
- Governmental Approvals. Buyer shall be responsible for, and shall bear all 6 costs involved in, obtaining any government approvals required for the impor-tation or sale of the Products.
- Taxes. All taxes, duties and other governmental charges (other than general real property and income taxes), including any interest or penalties thereon, imposed directly or indirectly on Omron or required to be collected directly or 7. indirectly by Omron for the manufacture, production, sale, delivery, importa-tion, consumption or use of the Products sold hereunder (including customs duties and sales, excise, use, turnover and license taxes) shall be charged to and remitted by Buyer to Omron.
- Financial. If the financial position of Buyer at any time becomes unsatisfactory 8. to Omron, Omron reserves the right to stop shipments or require satisfactory security or payment in advance. If Buyer fails to make payment or otherwise secondly with these Terms or any related agreement, Omron may (without liabil-ity and in addition to other remedies) cancel any unshipped portion of Prod-ucts sold hereunder and stop any Products in transit until Buyer pays all amounts, including amounts payable hereunder, whether or not then due, which are owing to it by Buyer. Buyer shall in any event remain liable for all unpaid ecounts. unpaid accounts.
- Cancellation; Etc. Orders are not subject to rescheduling or cancellation unless Buyer indemnifies Omron against all related costs or expenses.
- 10. Force Majeure. Omron shall not be liable for any delay or failure in delivery resulting from causes beyond its control, including earthquakes, fires, floods, strikes or other labor disputes, shortage of labor or materials, accidents to machinery, acts of sabotage, riots, delay in or lack of transportation or the requirements of any government authority.
- <u>Shipping: Delivery</u> Unless otherwise expressly agreed in writing by Omron:
   a. Shipments shall be by a carrier selected by Omron; Omron will not drop ship except in "break down" situations.
  - b. Such carrier shall act as the agent of Buyer and delivery to such carrier shall constitute delivery to Buyer; c. All sales and shipments of Products shall be FOB shipping point (unless of
  - erwise stated in writing by Omron), at which point title and risk of loss shall pass from Omron to Buyer; provided that Omron shall retain a security interest in the Products until the full purchase price is paid; d. Delivery and shipping dates are estimates only; and e. Omron will package Products as it deems proper for protection against nor-
- and handling and extra charges apply to special conditions.
   <u>Claims</u>. Any claim by Buyer against Omron for shortage or damage to the Products occurring before delivery to the carrier must be presented in writing to Omron within 30 days of receipt of shipment and include the original trans-portation bill signed by the carrier noting that the carrier received the Products from Omron in the candition claims of the products. from Omron in the condition claimed.
- Warranties. (a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed 13 (b) <u>Limitations</u>. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABIL-

#### Certain Precautions on Specifications and Use

- Suitability of Use. Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, 1. Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases but the following is a (i) Outdoor use, uses involving potential chemical contamination must be given:
   (ii) Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this document.

 (ii) Use in consumer products or any use in significant quantities.
 (iii) Energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equip-(iv) Systems, machines and equipment that could present a risk to life or prop-erty. Please know and observe all prohibitions of use applicable to this Product

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO

ITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. Omron further disclaims all warranties and responsibility of IN ISNDED USE. Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or oth-erwise of any intellectual property right. (c) <u>Buyer Remedy</u>. Omron's sole obli-gation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsi-ble for warapty consisting the non-the complex of the non-complying Product the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Compa-nies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty See http://www.omron247.com or contact your Omron representative for published information

- lished information. Limitation on Liability: Etc. OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY. Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted. Indemnities. Buyer shall indemnify and hold harmless Omron Companies and their employees from and against all liabilities, losses, claims, costs and expenses (including attorney's fees and expenses) related to any claim inves-
- 15 expenses (including attorney's fees and expenses) related to any claim, inves-tigation, litigation or proceeding (whether or not Omron is a party) which arises or is alleged to arise from Buyer's acts or omissions under these Terms or in any way with respect to the Products. Without limiting the foregoing, Buyer (at its own expense) shall indemnify and hold harmless Omron and defend or setthe any action brought against such Companies to the extent based on a claim that any Product made to Buyer specifications infringed intellectual property
- that any Product made to buyer specifications immiged interfectual property rights of another party. <u>Property: Confidentiality.</u> Any intellectual property in the Products is the exclusive property of Omron Companies and Buyer shall not attempt to duplicate it in any way without the written permission of Omron. Notwithstanding any charges to Buyer for engineering or tooling, all engineering and tooling shall remain the exclusive property of Omron. All information and materials supplied to the Products are confidential and proprietary. 16 by Omron to Buyer relating to the Products are confidential and proprietary, and Buyer shall limit distribution thereof to its trusted employees and strictly
- Export Controls. Buyer shall comply with all applicable laws, regulations and licenses regarding (i) export of products or information; (iii) sale of products to 17 "forbidden" or other proscribed persons; and (ii) disclosure to non-citizens of regulated technology or information. <u>Miscellaneous</u>. (a) <u>Waiver</u>. No failure or delay by Omron in exercising any right
- 18 <u>Miscellaneous</u>. (a) <u>Waiver</u>. No failure or delay by Omron in exercising any right and no course of dealing between Buyer and Omron shall operate as a waiver of rights by Omron. (b) <u>Assignment</u>. Buyer may not assign its rights hereunder without Omron's written consent. (c) <u>Law</u>. These Terms are governed by the law of the jurisdiction of the home office of the Omron company from which Buyer is purchasing the Products (without regard to conflict of law princi-ples). (d) <u>Amendment</u>. These Terms constitute the entire agreement between Buyer and Omron relating to the Products, and no provision may be changed or waived unless in writing signed by the parties. (e) <u>Severability</u>. If any provi-sion hereof is rendered ineffective or invalid, such provision shall not invalidate any other provision. (f) <u>Setoff</u>. Buyer shall have no right to set off any amounts against the amount owing in respect of this invoice. (a) Definitions. As used against the amount owing in respect of this invoice. (g) <u>Definitions</u>. As used herein, "<u>including</u>" means "including without limitation"; and "<u>Omron Compa-nies" (or similar words) mean Omron Corporation and any direct or indirect</u> subsidiary or affiliate thereof.

ADDRESS THE RISKS, AND THAT THE OMRON'S PRODUCT IS PROP-ERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

- 2.
- Programmable Products. Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof. <u>Performance Data</u>. Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitabil-ity and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application require-ments. Actual performance is subject to the Omron's Warranty and Limitations of Linbility. 3. of Liability.
- <u>Change in Specifications</u>. Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our pracchanged at any time based on improvements and other reasons. It is our prac-tice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifica-tions of the Product may be changed without any notice. When in doubt, spe-cial part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product. <u>Errors and Omissions</u>. Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clarical typographical or proofreading errors or omissions.
- for clerical, typographical or proofreading errors or omissions.

#### omron

Complete "Terms and Conditions of Sale" for product purchase and use are on Omron's website at www.omron247.com - under the "About Us" tab, in the Legal Matters section.

ALL DIMENSIONS SHOWN ARE IN MILLIMETERS. To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

## MROI

#### **OMRON ELECTRONICS LLC**

1 Commerce Drive Schaumburg, IL 60173 Tel: 847.843.7900 For U.S. technical support or other inquiries: 800.556.6766

#### **OMRON CANADA, INC.**

885 Milner Avenue Toronto, Ontario M1B 5V8 Tel: 416.286.6465

#### **MEXICO SALES OFFICES**

Mexico, D.F. 555.660.3144 Ciudad Juárez 656.623.7083 Monterrey, N.L. 818.377.4281 Querétaro 442.135.4510 **BRAZIL SALES OFFICE** Sao Paulo 55.11.2101.6310 **ARGENTINA SALES OFFICE** Cono Sur 54.114.787.1129 **CHILE SALES OFFICE** 562.206.4592 Santiago **OTHER LATIN AMERICAN SALES** mela@omron.com

#### **OMRON ON-LINE**

Global www.omron.com

USA www.omron247.com

Canada www.omron.ca

Brazil www.omron.com.br

Latin America www.espanol.omron.com

Cat. No. P06E-EN-03A

5/07 Specifications subject to change without notice Printed in USA