

Current Transducer HAL 50..600-S

For the electronic measurement of currents: DC, AC, pulsed..., with galvanic isolation between the primary circuit (high power) and the secondary circuit (electronic circuit).







F	ectr	ical	da	ita
_	CUL	ıvaı	uc	ше

Primary nominal current rms I _{PN} (A)	Primary current measuring range 4) I _{PM} (A)	Туре	RoHS since date code	
50	± 150	HAL 50-S	46180	
100	± 300	HAL 100-S	46065	
200	± 600	HAL 200-S	46090	
300	± 900	HAL 300-S	46142	
400	± 1000	HAL 400-S	46114	
500	± 1000	HAL 500-S	46306	
600	± 1000	HAL 600-S	46059	
I Overload (Canability (Amnere Turns)	30 000 A	

I_P	Overload Capability (Ampere Turns)	30,000	Α
$\mathbf{V}_{\mathrm{OUT}}$	Output voltage (Analog) @ ± I _{PN}	± 4	V
$R_{\scriptscriptstyle L}$	Load resistance @ T _A = 0 + 70°C	> 1	$k\Omega$
	@ T _A = - 25 + 85°C	> 3	$k\Omega$
$V_{\rm c}$	Supply voltage (± 5 %)	± 15	V
I _C	Current consumption	$< \pm 25$	mA
$V_{_{\mathrm{b}}}$	Rated isolation voltage rms ¹⁾	500	V
V _d	Rms voltage for AC isolation test, 50 Hz, 1 min	3	kV
\mathbf{R}_{is}	Isolation resistance @ 500 \mathbf{V}_{DC}	> 500	$M\Omega$

Accuracy - Dynamic performance data

Χ	Accuracy @ I_{PN} , $T_A = 25$ °C, ± 15 V		< ± 1	%
$\overset{\epsilon}{\textbf{v}}_{\text{\tiny OE}}$	Linearity error 2) Eletrical offset voltage @ \mathbf{T}_{A} = 25 $^{\circ}$ C	HAL 50-S HAL 100600-S	< ± 0.5 < ± 20 < ± 10	% of I _{PN} mV mV
\mathbf{V}_{OM}	Magnetic offset voltage $\textcircled{0}$ $\mathbf{I}_{P} = 0$, after an overload of 3 x \mathbf{I}_{PN}	HAL 50-S HAL 100200-S HAL 300600-S	< ± 30 < ± 20 < ± 10	mV mV mV
$\mathbf{TCV}_{\mathrm{OE}}$	Temperature coefficient of $\mathbf{V}_{\text{\tiny OE}}$	HAL 50-S HAL 100600-S	< ± 2.0 < ± 1.0	mV/K mV/K
t _r BW	Temperature coefficient of \mathbf{V}_{OUT} (% of Response time to 90% of \mathbf{I}_{PN} step Frequency bandwidth (- 3 dB) ³⁾		≤ ± 0.05 ≤ 3 DC 50	%/K µs kHz


General data

T _S m	Ambient operating temp Ambient storage temper Mass Standard ⁴⁾		арр.	- 25 + 85 - 25 + 85 75 EN 50178 : EN50082-2: EN50081-1:	1	°C °C g 994 992
	Deviation in output wher	n tested to EN 61000-4-6	i	< 20	% o	f I _{PN}
	Deviation in output wher	n tested to EN 61000-4-3		< 20	% o	f I _{DN}

Notes : 1) Overvoltage Category III, Pollution Degree 2

- 2) Excludes the electrical offset
- 3) Derating is needed to avoid excessive core heating at high frequency.
- 4) Please consult characterisation report for more technical details and application advice.

$I_{PN} = 50 ... 600 A$



Features

- Hall effect measuring principle
- Galvanic isolation between primary and secondary circuit
- Isolation voltage 3000V
- Low power consumption
- Extended measuring range(3 x I_{PN})
- Isolated plastic case recognized according to UL 94-V0

Advantages

- Easy installation
- Small size and space saving
- Only one design for wide current ratings range
- · High immunity to external interference

Applications

- AC variable speed drives
- DC motor drives
- · Battery supplied applications
- Uninterruptable Power Supplies (UPS)
- Switched Mode Power Supplies (SMPS)
- · Power supplies for welding applications.

Application domain


Industrial

Page 1/2

www.lem.com



Dimensions HAL 50..600-S (in mm. 1 mm = 0.0394 inch)



Mechanical characteristics

General tolerance ± 0.5 mm
 Primary through-hole 20 mm x 15 mm
 Connection of secondary Molex 5045-04-A

Remarks

- $\bullet~~{\rm V_{OUT}}$ is positive when ${\rm I_{P}}$ flows in the direction of the arrow.
- Temperature of the primary conductor should not exceed 90°C.
- This is a standard model. For different versions please contact us.

Safety



This transducer must be used in electric/electronic equipment with respect to applicable standards and safety requirements in accordance with the manufacturer's operating instructions.



Caution, risk of electrical shock

When operating the transducer, certain parts of the module can carry hazardous voltage (eg. primary busbar, power supply). Ignoring this warning can lead to injury and/or cause serious damage.

This transducer is a built-in device, whose conducting parts must be inaccessible after installation.

A protective housing or additional shield could be used. Main supply must be able to be disconnected.

Page 2/2

www.lem.com