60116

Miniature Circuit Breaker Multi 9 (C60), 35A, 1-Pole, 240 Vac, 60 Vdc, HACR Rated





List Price \$120.00 USD

Availability Stock Item: This item is normally stocked in our distribution facility.

Technical Characteristics

Ampere Rating	35A
General Application	Short circuit and overcurrent protection
For Use With	OEM Panels and Enclosures
Voltage Rating	120VAC - 60VDC
Terminal Type	Line: Box Lug - Load: Box Lug
HACR Rated	Yes
Mounting Type	Flush, Surface or DIN Rail (35mm)
Weight	4.40 Ounces
Approvals	UL489 Listed - CSA 22.2 #5.1 Certified - IEC Rated 60947-2
Number of Poles	1-Pole
Enclosure Rating	IP40
Marketing Trade Name	Multi 9
Short Circuit Current Rating	5kA@240VAC - 10kA@120VAC
Circuit Breaker Type	Standard
Туре	C60N
Wire Size	#18 to #2 AWG
Height	4.21 Inches (107mm)
Depth	3.00 Inches (76mm)
Trip Curve	C Curve - Magnetic operates between 7 to 10 times
Width	0.71 Inches (18mm)

Shipping and Ordering

Category 00915 - Discount Schedule DE2 GTIN 00785901208556 Package Quantity 1 Weight 0.31 lbs. Availability Code Stock Item: This item is normally stocked in our distribution facility. Returnability Y		
GTIN 00785901208556 Package Quantity 1 Weight 0.31 lbs. Availability Code Stock Item: This item is normally stocked in our distribution facility. Returnability Y	Category	00915 -
Package Quantity Weight O.31 lbs. Availability Code Stock Item: This item is normally stocked in our distribution facility. Returnability Y	Discount Schedule	DE2
Weight 0.31 lbs. Availability Code Stock Item: This item is normally stocked in our distribution facility. Returnability Y	GTIN	00785901208556
Availability Code Stock Item: This item is normally stocked in our distribution facility. Returnability Y	Package Quantity	1
Returnability Y	Weight	0.31 lbs.
	Availability Code	Stock Item: This item is normally stocked in our distribution facility.
Occupation of Oxidia	Returnability	Υ
Country of Origin	Country of Origin	IT

As standards, specifications, and designs change from time to time, please ask for confirmation of the information given in this document.

Generated: 10/26/2011 01:13:06

