CSM\_A3S\_DS\_E\_5\_1

# **Pushbutton Switch Series with Square 40-mm Body**

- Combines miniature design with distinct but soft sense of operation.
- Easy panel mounting from the front and simple lamp replacement without tools.



Refer to Safety Precautions for All Pushbutton Switches and Safety Precautions on page 18.

## **List of Models**

#### **Lighted Pushbutton Switches**

Aj	Model	
Rectangular		A3SJ
Square		A3SA


■ Specifications: Refer to page 12.

■ Accessories: Refer to pages 10 to 11.

■ Dimensions: Refer to page 14.

## **Model Number Structure**

Model Number Legend ..... The model numbers used to order sets are illustrated below. One set comprises the Operation Unit, Lamp, and Socket Unit. For information on combinations, refer to Ordering Information on pages 3 to 4.



## (1) Shape of **Operation Unit**

Sym- bol	Shape
J	Rectan- gular
Α	Square

(2) Switch Specifications Standard Load

Symbol	Operation		
Α	Momentary SPD		
В	Alternate	31 01	
С	Momentary		
D	D Alternate		

#### Microload

Symbol	Operation		
Е	Momentary	SPDT	
F	Alternate	31 01	
G	Momentary	DPDT	
Н	Alternate	DEDI	

- Standard Load 250 VAC, 2 A 125 VDC, 0.4 A
- Microload 125 VAC, 0.1 A 30 VDC, 0.1 A

Minimum applicable load 5 VDC, 1 mA

- Momentary operation ...Self-resetting
- Alternate operation ...Self-holding

#### (3) Screen Pattern Illumination-only models

Эуший	Screen pattern			
	Single screen			
1				
	Vertical 2-split screen			
3				

- (rectangular models only) Models with colored illumination can be ordered individually. Refer to page 5 for details.
- Colored Illumination



The built-in LED is colored.

# **LED-lighted Models**

Symbol	Rated voltage
05E	5 VDC
12E	12 VDC
24E	24 VDC

### Incandescent **Lamp-lighted Models**

Symbol	Rated voltage
06	6 VAC/VDC
14	14 VAC/VDC
28	28 VAC/VDC

## (4) Lighting Method - (5) Operation Unit Color For LED

Symbol	Color
R	Red
Υ	Yellow
G	Green
W	White *

#### ► Incandescent Lamp-lighted Models

Symbol	Color
R	Red
Υ	Yellow
G	Green
Α	Blue
W	White *

\* The color cap is transparent.

#### Number of Built-in LEDs and Incandescent Lamps

			<u> </u>
Model	Screen pattern	LED	Incandescent lamp
	Single screen	2	1
A3SJ	Vertical 2-split screen	2	2
A3SA	Single screen	1	1

## Structure of Split-screen Operation Unit Type Color cap Legend plate \* Dispersion plate Light-separation plate (2-split screen only) Single screen Vertical 2-split screen LED/incandescent (Rectangular models (Rectangular models only) lamp holder and square models) A3SJ Not included for the Square Models (A3SA) with incandescent lamp.

Ordering as a Set ......The model numbers used to order sets of Units are given in the following tables. One set comprises the Operation Unit, Lamp, and Socket Unit.

**Standard Loads** 

Rectangular Models



Single screen

Vertical 2-split screen

2

Single screen

		Contact type	Standard load (250 VAC, 2 A; 125 VDC 0.4 A)		Operation Unit
Output	Lighting	Operation	Momentary operation (Self-resetting)	Alternate operation (Self-holding)	Operation Unit color symbol
		5 VDC	A3SJ-90A1-05E□	A3SJ-90B1-05E□	
	LED	12 VDC	A3SJ-90A1-12E□	A3SJ-90B1-12E□	
SPDT		24 VDC	A3SJ-90A1-24E□	A3SJ-90B1-24E□	Enter the desired color
SEDI	Incandescent	6 VAC/VDC	A3SJ-90A1-06□	A3SJ-90B1-06□	symbol for the Pushbutton in $\square$ .
lamp		14 VAC/VDC	A3SJ-90A1-14□	A3SJ-90B1-14□	
	lamp	28 VAC/VDC	A3SJ-90A1-28□	A3SJ-90B1-28□	R (Red)
		5 VDC	A3SJ-90C1-05E□	A3SJ-90D1-05E□	Y (Yellow)
	LED	12 VDC	A3SJ-90C1-12E□	A3SJ-90D1-12E□	G (Green)
DPDT		24 VDC	A3SJ-90C1-24E□	A3SJ-90D1-24E□	A (Blue) * W (White)
		6 VAC/VDC	A3SJ-90C1-06□	A3SJ-90D1-06□	vv (vviite)
	Incandescent lamp	14 VAC/VDC	A3SJ-90C1-14□	A3SJ-90D1-14□	
	lamp	28 VAC/VDC	A3SJ-90C1-28□	A3SJ-90D1-28□	

<sup>\*</sup> Incandescent lamp only.

Vertical 2-split screen

		Contact type	Standard load (250 VAC, 2 A; 125 VDC 0.4 A)		Operation Unit
Output	Lighting	Operation	Momentary operation (Self-resetting)	Alternate operation (Self-holding)	color symbol
SPDT	LED	24 VDC	A3SJ-90A3-24E□□	A3SJ-90B3-24E□□	Enter the desired color symbol for the Pushbutton
31 21	Incandescent lamp	28 VDC	A3SJ-90A3-28□□	A3SJ-90B3-28□□	in □□.  R (Red)
DPDT	LED	24 VDC	A3SJ-90C3-24E□□	A3SJ-90D3-24E□□	Y (Yellow) G (Green)
וטייט	Incandescent lamp	28 VDC	A3SJ-90C3-28□□	A3SJ-90D3-28□□	W (White) A (Blue) *

<sup>\*</sup> Incandescent lamp only.

#### **Microloads**

Single screen

	C	ontact type	Microload (125 VAC, 0.1 A; 30 VDC 0.1 A)	Operation Unit color
Operation Output Lighting		•	Momentary operation (Self-resetting)	symbol
		5 VDC	A3SJ-90E1-05E□	
	LED	12 VDC	A3SJ-90E1-12E□	Enter the
SPDT		24 VDC	A3SJ-90E1-24E□	desired col-
SFDI	Incan-	6 VAC/VDC	A3SJ-90E1-06□	or symbol
	descent	14 VAC/VDC	A3SJ-90E1-14□	for the
	lamp	28 VAC/VDC	A3SJ-90E1-28□	Pushbutton in □.
		5 VDC	A3SJ-90G1-05E□	III □. R (Red)
DPDT	LED	12 VDC	A3SJ-90G1-12E□	Y (Yellow)
		24 VDC	A3SJ-90G1-24E□	G (Green)
	Incan-	6 VAC/VDC	A3SJ-90G1-06□	A (Blue) *
	descent	14 VAC/VDC	A3SJ-90G1-14□	W (White)
	lamp	28 VAC/VDC	A3SJ-90G1-28	

Individual models: Refer to pages 6 to 9. (The Pushbutton, Lamp, and Switch can be ordered separately.) Vertical 2-split screen

Contact type  Operation		(125 VAC, 0.1 A; 30 VDC 0.1 A)		Operation Unit color symbol
Output	Lig	nting	(Sell-resetting)	
SPDT	LED	24 VDC	A3SJ-90E3-24E□□	Enter the desired col-
SPUI	Incan- descent lamp	28 VDC	A3SJ-90E3-28□□	or symbol for the Pushbutton in □□.
DPDT	LED	24 VDC	A3SJ-90G3-24E□□	R (Red) Y (Yellow) G (Green)
וטיטו	Incan- descent lamp	28 VDC	A3SJ-90G3-28□□	W (White) A (Blue) *

<sup>\*</sup> Incandescent lamp only.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Ordering as a Set ...... The model numbers used to order sets of Units are given in the following tables. One set comprises the Operation Unit, Lamp, and Socket Unit.

## **Standard Loads**



Single screen

Contact type		Standard load (250 VA	Standard load (250 VAC, 2 A; 125 VDC 0.4 A)		
Output	Operation Output Lighting		Momentary operation (Self-resetting)	Alternate operation (Self-holding)	Operation Unit color symbol
		5 VDC	A3SA-90A1-05E□	A3SA-90B1-05E□	
	LED	12 VDC	A3SA-90A1-12E□	A3SA-90B1-12E□	
CDDT	SPDT Incandescent lamp	24 VDC	A3SA-90A1-24E□	A3SA-90B1-24E□	
SPUI		6 VAC/VDC	A3SA-90A1-06□	A3SA-90B1-06□	Enter the desired color
		14 VAC/VDC	A3SA-90A1-14□	A3SA-90B1-14□	— symbol for the Pushbutton in □.
		28 VAC/VDC	A3SA-90A1-28□	A3SA-90B1-28□	R (Red)
		5 VDC	A3SA-90C1-05E□	A3SA-90D1-05E□	Y (Yellow)
	LED	12 VDC	A3SA-90C1-12E□	A3SA-90D1-12E□	G (Green) A (Blue) *
DPDT Incandescen		24 VDC	A3SA-90C1-24E□	A3SA-90D1-24E□	W (White)
		6 VAC/VDC	A3SA-90C1-06□	A3SA-90D1-06□	, , , ,
	lamp	14 VAC/VDC	A3SA-90C1-14□	A3SA-90D1-14□	
	lamp	28 VAC/VDC	A3SA-90C1-28□	A3SA-90D1-28□	

<sup>\*</sup> Incandescent lamp only.

#### Microloads

Single screen

Contact type		Microload (125 VAC, 0.1 A; 30 VDC 0.1 A)	Operation Unit		
Output	Operation tput Lighting		Momentary operation (Self-resetting)	color symbol	
		5 VDC	A3SA-90E1-05E□		
	LED	12 VDC	A3SA-90E1-12E□		
SPDT		24 VDC	A3SA-90E1-24E□		
SPDI		6 VAC/VDC	A3SA-90E1-06□	Enter the desired color	
	Incandescent lamp	14 VAC/VDC	A3SA-90E1-14□	symbol for the Pushbutton in $\square$ .	
lali	lamp	28 VAC/VDC	A3SA-90E1-28□	R (Red)	
		5 VDC	A3SA-90G1-05E□	Y (Yellow)	
	LED	12 VDC	A3SA-90G1-12E□	G (Green) A (Blue) *	
DPDT		24 VDC	A3SA-90G1-24E□	W (White)	
		6 VAC/VDC	A3SA-90G1-06□	( /	
	Incandescent lamp	14 VAC/VDC	A3SA-90G1-14□		
	шпр	28 VAC/VDC	A3SA-90G1-28□		

<sup>\*</sup> Incandescent lamp only.

Individual models: Refer to pages 6 to 9.


(The Pushbutton, Lamp, and Switch can be ordered separately.)

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

## Illumination-only and Colored-illumination LED Models


[Illumination only] describes LED models for which the screen color is the same whether the LED is lit or not. The screen simply becomes brighter when the LED lights.

Example: Red LED



Colored illumination describes LED models for which the screen color is white when the LED is not lit and changes to the color of the LED lamp when the LED is lit.

Example: Red LED




**Ordering** ....... With colored-illumination models, order the Display (Operation Unit), Lamp, and Socket Unit as shown in the following table.

Disp	olay (Operation Ur	nit)	LED	Socket Unit
Single screen	Rectangular models	A3SJ-5801		Select from the Switches on
	Square models	A3SA-5801	Select the LED lamps to suit your desired	
2-split screen	Rectangular models only	A3SJ-5921	coloration from the selection on page 9.	page 9.

Ordering Individually ....... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

Ordering ...... Specify a model number from the following page.



Ordering set combinations: Refer to pages 3 to 4.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Ordering Individually ...... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

## **Operation Unit LED-lighted Models**

(LED is not built in.)

Appearance			Appearance	Rectangular Models (2 LEDs)	Square Models (1 LED)	
					Lac.	
	Caraan nattar	_	Diamley color	(transparent legend	(transparent legend plate built in)	
•	Screen patter	1	Display color	plate built in)		
			White	A3SJ-5801	A3SA-5801	
Single	e screen		Red	A3SJ-5802	A3SA-5802	
			Green	A3SJ-5803	A3SA-5803	
			Yellow	A3SJ-5805	A3SA-5805	
		plit	White/red	A3SJ-5901		
			White/green	A3SJ-5902		
	Standard		White/yellow	A3SJ-5904		
	screen		Red/green	A3SJ-5905	_	
	00.00		Red/yellow	A3SJ-5907		
			Green/yellow	A3SJ-5909		
			Red/white	A3SJ-5911		
2-split			Green/white	A3SJ-5912		
screen *	Reverse		Yellow/white	A3SJ-5914		
	split screen		Green/red	A3SJ-5915	_	
	3010011		Yellow/red	A3SJ-5917		
			Yellow/green	A3SJ-5919		
			White/white	A3SJ-5921	,	
	One-color		Red/red	A3SJ-5922		
	2-split screen		Green/green	A3SJ-5923	_	
	3010011		Yellow/yellow	A3SJ-5925		

Ordering set combinations: Refer to pages 3 to 4.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Note: The color cap is transparent when the display color is white.

\* Two-split screen configurations are given with the OMRON surface of the case downward.

Ordering Individually ...... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

## **Operation Unit**

## **Incandescent Lamp-lighted Models**

(Incandescent lamp is not built in.)

•	Appearance			Rectangular	Square
					Je Je
	Screen patte	rn	Display color	(transparent legend plate built in)	(transparent legend plate built in)
	ocreen patte	One lamp	White	A3SJ-5301	A3SA-5301
		One ramp	Red	A3SJ-5302	A3SA-5302
			Green	A3SJ-5303	A3SA-5303
			Blue	A3SJ-5304	A3SA-5304
		السيا	Yellow	A3SJ-5305	A3SA-5305
Single	e screen	Two lamps	White	A3SJ-5321	
			Red	A3SJ-5322	
			Green	A3SJ-5323	_
			Blue	A3SJ-5324	
			Yellow	A3SJ-5325	
			White/red	A3SJ-5201	
			White/green	A3SJ-5202	
			White/blue	A3SJ-5203	
			White/yellow	A3SJ-5204	
	Standard		Red/green	A3SJ-5205	
	split screen		Red/blue	A3SJ-5206	_
			Red/yellow	A3SJ-5207	
			Green/blue	A3SJ-5208	
			Green/yellow	A3SJ-5209	
			Blue/yellow	A3SJ-5210	
			Red/white	A3SJ-5211	
2 anlit			Green/white	A3SJ-5212	
2-split screen *			Blue/white	A3SJ-5213	
	Davieras		Yellow/white	A3SJ-5214	
	Reverse split		Green/red	A3SJ-5215	_
	screen		Blue/red	A3SJ-5216	
			Yellow/red	A3SJ-5217	
			Blue/green	A3SJ-5218	
			Yellow/green	A3SJ-5219	
			Yellow/blue	A3SJ-5220	
			White/white	A3SJ-5221	
	One-color		Red/red	A3SJ-5222	
	2-split screen		Green/green	A3SJ-5223	_
	3016611		Blue/blue	A3SJ-5224	
			Yellow/yellow	A3SJ-5225	

Ordering set combinations: Refer to pages 3 to 4.

■ Specifications: Refer to page 12. ■ Dimensions: Refer to page 14.

Note: The color cap is transparent when the display color is white.

\* Two-split screen configurations are given with the OMRON surface of the case downward.

Ordering Individually ....... Operation Units, Lamps, and Socket Units can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

#### Lamp

## **LED Lamp**

Operating voltage	5 VDC	12 VDC	24 VDC
Color	Model (DC only)	Model (DC only)	Model (DC only)
Red	SLL-05ER	SLL-12ER	SLL-24ER
Yellow	SLL-05EY	SLL-12EY	SLL-24EY
Green	SLL-05EG	SLL-12EG	SLL-24EG
White	SLL-05EW	SLL-12EW	SLL-24EW

Note: The A3SJ (M2SJ) requires two LEDs for each Switch. The A3SA (M2SA) requires one LED.

## **Incandescent Lamp**

Lamp type Operating voltage	Standard lamp	Low-voltage lamp
5 VAC/VDC	SLL-06	SLL-06H
12 VAC/VDC	SLL-14	SLL-14H
24 VAC/VDC	SLL-28	SLL-28H

Note: The low-voltage lamp has an advantage in that it generates less heat.

Switch (common to both LED models and incandescent lamp-lighted models)

Cont	act type	Number of outputs	Appearance Operation	Rectangular models	Square models	Selection precautions	
		1	Momentary operation	A3SJ-8010	A3SA-7010	Use the Socket Unit in	
Stan- dard	Silver		Alternate operation	A3SJ-8020	A3SA-7020	combination with the same shape Operation Unit	
load	contacts	2	Momentary operation	A3SJ-8030	A3SA-7030	(rectangular or square). Example:	
		_	_	Alternate operation	A3SJ-8040	A3SA-7040	For the A3SJ-5801 Rectan- gular Operation Unit, select
	alloy contacts	1	Momentary operation	A3SJ-8050	A3SA-7050	the A3SJ-8□□0	
Micro-		'	Alternate operation	A3SJ-8060	A3SA-7060	Socket Unit.     Momentary operation is self-resetting, and alternate operation is self-holding (i.e.,	
load		2	Momentary operation	A3SJ-8070	A3SA-7070		
		2	Alternate operation	A3SJ-8080	A3SA-7080	push-on, push-off).	

## Accessories, Replacements, and Tools **Accessories for Rectangular Models**

Name	Appearance	Classification	Model	Application precautions
		Short edge Barriers (1 pair)	A3SA-4001	The purpose of a Barrier is to prevent malfunctioning
Barrier		Short intermediate Barriers	A3SA-4002	and to improve design image of the mounting panel.  There is one intermediate Barrier and one pair of
Damei	MMMM	Long edge Barriers (1 pair)	A3SJ-4003	edge Barriers (2 Barriers). Mount Short Barriers horizontally. Mount Long Barriers vertically.
		Long intermediate Barriers	A3SJ-4004	Would Long Damers Vertically.
Switch Guard		-	A3SJ-5050	Cannot be used with Barrier or Seal Cover.
Seal Cover		-	A3SJ-5060	Cannot be used with Barrier or Switch Guard.     Cap material: Vinyl chloride
Long Mounting Plate		1 pair	A3SJ-3002	Use when vertically mounting individual (with Barrier) or multiple Switches (in standard mounting style and with Barrier). A Short Mounting Plate is attached to the Switch; replace it with the long one.

## **Accessories for Square Models**

Name	Appearance	Classification	Model	Application precautions	
Barrier				The purpose of the Barrier is to prevent malfunction ing and to improve design image of the mounting	
Darrier		Short Intermediate Barrier	A3SA-4002	panel.	
Switch Guard	3	-	A3SA-5050	Cannot be used with Barrier or Seal Cover.	
Seal Cover		_	A3SA-5060	Cannot be used with Barrier or Switch Guard.     Cap material: Vinyl chloride	

■ Accessory mounting: Refer to page 19.

## Accessories, Replacements, and Tools **Replacements for Rectangular Models**

Name	Appearance	Classi	Classification		Application precautions
		Wire-wrap terminals		A3SJ-4104	
Socket		PCB terminals		A3SJ-4105	Sockets cannot be used for multiple mounting.
	1 1/11/11/1	Solder terminals		A3SJ-4106	
Dispersion plate		Milk-white	Single screen	A3SJ-5107	-
		Transparent	Single screen	A3SJ-5600	
		White		A3SJ-5601	
		Red		A3SJ-5602	
		Green		A3SJ-5603	Contact your OMRON representative for color
		Blue		A3SJ-5604	
Colon con		Yellow		A3SJ-5605	changes or inscribing.
Color cap		Transparent		A3SJ-5630	If LEDs are to be used, use a color cap that matches the LED color.
	~	White	1	A3SJ-5631	The blue color cap is only for incandescent lamps.
	1	Red	O amlit assess	A3SJ-5632	
		Green	2-split screen	A3SJ-5633	
		Blue		A3SJ-5634	
	7	Yellow	1	A3SJ-5635	
Legend plate		Transparent	<u> </u>	A3SJ-4204	A transparent legend plate is mounted on the
Legend plate		Milk-white		A3SJ-4203	Operation Unit.

## **Replacements for Square Models**

Name	Appearance	Classification	Model	Application precautions
		Wire-wrap terminals	A3SA-4101	
Socket		PCB terminals	A3SA-4102	Sockets cannot be used for multiple mounting.
		Solder terminals	A3SA-4103	
Dispersion plate	9	Milk-white	A3SA-5107	-
		Transparent	A3SA-5600	
		White	A3SA-5601	Contact your OMRON representative for color
Color cap		Red	A3SA-5602	changes or inscribing.
Color cap		Green	A3SA-5603	If LED colors are to be used, use a color cap that
		Blue	A3SA-5604	matches the LED color.
		Yellow	A3SA-5605	
Legend plate		Transparent	A3SA-4204	A transparent color cap is mounted to a standard Display, Legend plates cannot be used, however,
Legend plate		Milk-white	A3SA-4203	with Displays for incandescent lamps.

#### Tools

Name	Appearance	Classification	Model	Application precautions
Extractor		-	A3PJ-5080	Convenient for extracting the Operation Unit.

■ Accessory mounting: Refer to page 19.

## **Specifications**

## **Approved Standard Ratings** UL (File No. E41515), CSA (File No. LR45258)

Standard Load: 3 A at 125 VAC 2 A at 250 VAC Microload: 0.1 A at 125 VAC 0.1 A at 30 VDC

Note: Certification has been obtained for the Switch Unit.

For detailed information on individual products that have received

certification, consult your supplier.

#### Ratings For Standard Loads

	Non-	Non-inductive load (A)			Inductive load (A)			
Rated voltage	Resistive load		Lamp	load		ctive ad	Moto	r load
	NC	NO	NC	NO	NC	NO	NC	NO
125 VAC	3	3	1	0.7		2	1.5	1
250 VAC	2	2	0.7	0.5	1	.5	1	0.7
8 VDC	3	3		1		2	1.	.5
14 VDC	3	3	-	1	1.5		1.	.5
30 VDC	2		1		1	.5	-	1
125 VDC	0.4		0.	05	0.4		0.05	
250 VDC	0.	.2	0.	03	0.2		0.0	03

- Note: 1. The above values are for steady-state currents.
  2. Inductive load: Power factor = 0.4; time constant = 7 ms.
  3. The lamp load has an inrush current of 10 times the steady-state
  - 4. The motor load has an inrush current of 6 times the steady-state current.

The rated values are for testing conducted under the following conditions.
(1) Ambient temperature: 20±2°C
(2) Ambient humidity: 65% ±5%RH

- (3) Operating frequency: 20 times/min

#### **For Microloads**

	0.1 A at 30 VDC (resistive load); 0.1 A at 125 VAC (resistive load)
Minimum applicable load	1 mA at 5 VDC

## **LED Lamp**

Туре	Applied voltage	Rated voltage	Rated current	Built-in limiting resistance
	5 VDC±5%	5 VDC	30 mA	39 Ω
DC only	12 VDC±5%	12 VDC	15 mA	270 Ω
	24 VDC±5%	24 VDC	12.5 mA	1300 Ω

#### **Incandescent Lamp**

Applied	Rated voltage	Standard lamp	Low-power lamp
voltage	Trated Voltage	Rated current	Rated current
5 VAC/VDC	6 VAC/VDC	200 mA	100 mA
12 VAC/VDC	14 VAC/VDC	80 mA	40 mA
24 VAC/VDC	28 VAC/VDC	40 mA	25 mA

## **Characteristics**

	Operating frequency	Mechanical	Momentary operation models: 120 operations/min max. *1	
	irequericy	Electrical	20 operations/min max.	
I	Insulation	n resistance	100 MΩ min. (at 500 VDC)	
		Between terminals of same polarity	1,000 VAC, 50/60 Hz for 1 minute	
		Between terminals of different polarity	2,000 VAC, 50/60 Hz for 1 minute	
	Dielectric strength	Between current- carrying metal part and ground	2,000 VAC, 50/60 Hz for 1 minute	
		Between each terminal and non-current-carry- ing metal part	2,000 VAC, 50/60 Hz for 1 minute	
		Between lamp terminals	1,000 VAC, 50/60 Hz for 1 minute *2	
	Vibration resistance Malfunction		10 to 55 Hz, 1.5-mm double amplitude (1 ms max.)	
	Shock Destruction		500 m/s <sup>2</sup> max.	
ı	resistance	Malfunction	200 m/s <sup>2</sup> max. (1 ms max.)	
	Life expect- ancy	Mechanical	Momentary operation models: 1,000,000 operations min. Alternate operation models: 100,000 operations min. (One operation consists of set and reset operations.)	
		Electrical	100,000 operations min. (rated load)	
1	Weight		Approx. 10 g	
1	Inrush	NC	Standard load: 10 A max.	
•	current	NO	Standard load: 10 A max.	
	Ambient operating temperature Ambient operating humidity Ambient storage temperature Degree of protection		−10 to 50°C (with no icing or condensation)	
1			35% to 85% RH	
			-25 to 65°C (with no icing or condensation)	
			IP00	
	Electric s class	hock protection	Class II	
I	PTI (proo	f tracking index)	175	
	Pollution	degree	3 (IEC 60947-5-1)	
+.	*1 With alternate operation models 6		O aparationa/min may One aparation	

<sup>\*1.</sup> With alternate operation models, 60 operations/min max. One operation cycle consists of set and reset operations.

## **Operating Characteristics**


Operating characteristics	Operation	Momentary operation models	Alternate operation models
Operating force	OF max.	3.92 N	4.90 N
Releasing force	RF min.	0.49 N	0.294 N
Total travel	TT	Approx. 3 mm	Approx. 3 mm
Pretravel	PT max.	2.2 mm	2.2 mm
Lock travel alternate	LTA min.	-	0.5 mm


#### **Contact Form**

Name	Contact Form
Double-throw contacts	COM NO

<sup>\*2.</sup> With no incandescent lamp or LED lamp mounted.

# **Model Structure Operation Unit Structure**






Note: Unless specified, a tolerance of  $\pm 0.4$  mm applies for all dimensions. Use a mounting panel thickness of 1 to 4 mm.

## **Terminal Arrangement**


Bottom View (All are shown with the OMRON logo facing down.)




Note: The arrangements given above are not indicated on the Socket Unit.

## **Contact Type**

Incandescent Lamp-lighted Models (The terminal arrangements are the same as for the LED-lighted models.)



## **LED Lamp-lighted Models**




**Dimensions** (Unit: mm)

# Panel Cutout (If using a Switch Guard or Seal Cover, refer to the panel cutout diagrams on page 17.) Rectangular Models (A3SJ)

Cla	ssification	Mounting design	Panel cutout	Remarks
	Individual mounting, horizontal	17.8±0.2	16.2±0.2 122.4±0.2	Panel cutout spacing between rows of Units:
_	Multiple mounting, horizontal	17.8±0.2 1 2 n	16.2±0.2	<del>    -</del> -3 min.
Flange mount models	Individual mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2	6 min.
	Multiple mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2 17.8n-1.6±0.2	
	Individual mounting, horizontal	19.8	16.2±0.2 16.2±0.2	Panel cutout spacing between rows of Units:
Barrier	Multiple mounting, horizontal	19.8 1 2 n	16.2±0.2 25.3n+1.6±0.2	1.4
mount models	Individual mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2	6 min
	Multiple mounting, vertical	Mount to Long Mounting Plate (A3SJ-3002) before use.	22.4±0.2 19.1n+1.6±0.2	Dotted line indicates the position of each mounting Barrier.

<sup>\*</sup> If the panel is to be finished (e.g., coated), make sure that the panel meets the specified dimensions after the coating.

## Square Models (A3SA)



<sup>\*</sup> If the panel is to be finished (e.g., coated), make sure that the panel meets the specified dimensions after the coating.

**Dimensions** (Unit: mm)

## **Accessory Mounting Dimensions**

## **Legend Plate**


Rectangular Models A3SJ-4203/-4204



Square Models A3SA-4203/-4204




Extractor A3PJ-5080





# Socket-mounting Dimensions Rectangular Models

# Wire-wrap Terminals A3SJ-4104





## Solder Terminals A3SJ-4106





## PCB Terminals A3SJ-4105






## **Terminal Hole Dimensions**




# PCB Cutout (Bottom View)




**Dimensions** (Unit: mm)


## **Square Models**


# Wire-wrap Terminals A3SA-4101





## Solder Terminals A3SA-4103







#### **Terminal Hole Dimensions**




## PCB Terminals A3SA-4102







# PCB Cutout (bottom view)



## **Switch and Guard Mounting Dimensions**



#### **Seal Cover Mounting Dimensions**



Note: 1. Recommended panel thickness: 1.0 to 3.3 mm

2. Unless otherwise specified, a tolerance of  $\pm 0.4$  mm applies to all dimensions.

## **Safety Precautions**

### Refer to Safety Precautions for All Pushbutton Switches.

#### **Precautions for Correct Use**

#### Mounting

 Always make sure that the power is turned OFF before mounting, removing, or wiring the Switch, or performing maintenance. Electric shock or fire may occur.

#### Wiring

- For wiring, use a wire size that is appropriate for the applied voltage and the supplied current. Be sure to perform soldering according to the following conditions. Using the Switch with incomplete soldering may result in errors and heat, which may cause fire.
- (1) Manual soldering: Use a soldering iron with a tip temperature of 350°C maximum and complete soldering within 3 seconds.
- (2) Dip soldering: Solder at 350°C for 3 s or less.

Wait for one minute after soldering before exerting any external force on the solder.

- Use non-corrosive liquid rosin as the flux.
- If screw-tightened terminals are used, hold the Socket Unit Set or Socket Unit and install the lead wiring applying a torque of less than 0.98 N·m to the Socket Unit. Applying a torque of more than 0.98 N·m may result in damage. The tightening torque is 0.59 to 0.78 N·m.
- Make sure that the insulating sheath of the wires does not come in contact with the Unit. If wiring is performed with the insulating sheath of the wires coming in contact with the Unit, use wire with a minimum heat resistance of 100°C.
- After wiring the Switch, make sure that there is a suitable isolation distance.

#### **Operating Environment**


 Do not use in locations that are subject to dust, oil, or metal fillings, because these may penetrate the interior the Switch and cause malfunction.

#### **Using Microloads**

• Using a standard load switch when a microload circuit is opened or closed may cause wear on the contacts. Use the switch within the operating range. (Refer to the diagram below.) Even when using microload models within the operating range shown below, if inrush current occurs when the contacts are opened or closed, it may cause the contact surface to become rough, and so decrease life expectancy. Therefore, insert a contact protection circuit where necessary.

The minimum applicable load is the N-level reference value. This value indicates the malfunction reference level for the reliability level of 60% ( $\lambda$  60) (conforming to JIS C5003).

The equation  $\lambda$  60 = 0.5 x 10<sup>-4</sup>/time indicates that the estimated malfunction rate is less than 1/2,000,000 with a reliability level of 60%.



#### **LED Lamp**

 A current-limiting resistor for the LED lamp is built in, so no external resistor is required.

	Rated voltage	Built-in limiting resistance
	5 VDC	39 Ω
	12 VDC	270 Ω
•	24 VDC	1300 Ω

#### Incandescent Lamp

 It is advantageous in terms of service life and heat generation to apply 80% of the rated voltage (operating voltage) to the incandescent lamp.

#### Operation

 Always mount the Operation Unit before operating the Switch.
 (Using your fingers or tweezers to operate moving parts of the Switch may deform internal parts and cause malfunctions.)

#### **Character Film**

• If the character film is to be specially prepared, use heat-resistant film with a maximum thickness of 0.2 mm.



#### Others


 If the panel is to be finished (e.g., coated), make sure that the panel meets the specified dimensions after the coating.

#### **Application**


#### Replacing Incandescent and LED Lamps and Panel Mounting

#### Removing the Display

- Grasp the groove on the color cap surface, and pull it firmly toward you to remove the Display.
- An Extractor (A3PJ-5080) is available to conveniently remove the Display




#### Mounting and Replacing Incandescent and LED Lamps




#### Inserting the Display into the Socket Unit

Insert the Operation Unit in the proper direction. With the OMRON logo downward, insert the Operation Unit so that the lamp/LED terminals on the inside surface of the Unit case and the contactors of the Display.



## Rated Voltage and Color of LED


The LED voltage rating is indicated on the base. Use the LED within  $\pm 5\%$  of voltage range.



#### Mounting to the Switch Panel


Mount the Socket Unit to the panel by inserting it from the front of the panel.

Mount the Socket Unit so that the OMRON logo is downward.



#### **Barrier Mounting**

- Place the Edge Barrier on the side of the Socket Unit, and then insert it into the panel.
- Insert the Intermediate Barrier between the Switches after inserting the Socket Units into the panel.



# Inscribing Legend Plate Characters

## Inscribing

A3SJ (M2SJ)

- Inscription depth: 0.5 mm max.
- The legend plate is made of polycarbonate, so apply an alcoholbased paint coating, such as melamine, phthalate, or acrylic resin paint when marking the legend.




Legend plate

 When replacing the legend plate, be careful that the coil spring in the Display does not become removed.

# Assembling the Legend Plate (Plunger) A3SA (M2SA)

(LED Lamp)

(1) Assemble the color plate to the plunger, and then assemble the legend plate on top.



(Incandescent Lamp)

(2) Inscribe the surface of the plunger, and then coat the surface.

#### Lighted Square Pushbutton Switches


Assemble models A3SA-5301 to A3SA-5305 so that the hook is toward you.



Hook toward you

Note: Legend plates cannot be used with A3SA Displays for incandescent lamps

(3) Assemble the color cap to the inscribed plunger.



(4) Push in the color in the direction of the arrow to assemble the plunger and the lamp holder.

## Lighted Square Pushbutton Switches

A3SA

Perform the assembly so that the wide groove and the hook on the plunger are in the same direction.



## Indicator

M2SA

Perform the assembly so that the wide groove and the hook on the plunger are in the same direction.



#### Read and Understand This Catalog

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

## Warranty and Limitations of Liability

#### WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

#### **Application Considerations**

#### SUITABILITY FOR USE

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- · Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

#### PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

#### **Disclaimers**

#### **CHANGE IN SPECIFICATIONS**

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

## DIMENSIONS AND WEIGHTS

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

#### PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

#### **ERRORS AND OMISSIONS**

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

2009.9

In the interest of product improvement, specifications are subject to change without notice.

OMRON Corporation Industrial Automation Company

http://www.ia.omron.com/

(c)Copyright OMRON Corporation 2009 All Right Reserved.